

SIEMENS

SIPROTEC

Line Differential Protection / Distance Protection Devices

7SD5, 7SD610

7SA6, 7SA522

V4.6

Breaker Management Relay

7VK61

V4.6

IEC 61850

PIXIT

Preface, Table of Contents

Applications

1

Basics

2

Mapping

3

Literature, Index

Disclaimer of Liability

Although we have carefully checked the contents of this publication for conformity with the hardware and software described, we cannot guarantee complete conformity since errors cannot be excluded. The information provided in this manual is checked at regular intervals and any corrections that might become necessary are included in the next releases. Any suggestions for improvement are welcome.

Subject to change without prior notice.
Document Release V04.20.01
Edition 11.2007

Copyright

Copyright © Siemens AG 2006

The reproduction, transmission or use of this document or its contents is not permitted without express written authority. Offenders will be liable for damages. All rights, including rights created by patent grant or registration of a utility model or design, are reserved.

Registered Trademarks

SIMATIC®, SIMATIC NET®, SIPROTEC®, DIGSI®, SICAM® and SINAUT® are registered trademarks of SIEMENS AG. All other product and brand names in this manual might be trademarks, the use of which by third persons for their purposes might infringe the rights of their respective owners.

Preface

Purpose of this manual

In this Manual, you will find the

- ❑ Specification of the applications of the IEC 61850 interface
- ❑ General information about the effects of configuration of your device to the different Logical Nodes and DOIs
- ❑ Mapping of the information relevant to the device on the Logical Node of protocol IEC61850.

Target audience

This manual is intended mainly for all persons who configure, parameterize and operate a SIPROTEC Device 7SD5, 7SD610, 7SA522, 7SA6 or 7VK61.

Scope of validity of this Manual

SIPROTEC 7SA6, Version 4.60 and higher
SIPROTEC 7SA522, Version 4.60 and higher
SIPROTEC 7SD5, Version 4.60 and higher
SIPROTEC 7SD610, Version 4.60 and higher
SIPROTEC 7VK61, Version 4.60 and higher

Standards

This document has been created according to the ISO 9001 quality standards.

Further Support

If you have questions about SIPROTEC IEC 61850 interface, please contact your Siemens sales representative.

Table of contents

1	Applications	9
1.1	General	10
1.2	Association model	11
1.3	Server model	12
1.4	Data set model	13
1.5	Substitution model	14
1.6	Setting group control model	15
1.7	Reporting model	16
1.7.1	Unbuffered Report	16
1.7.2	Buffered Report	17
1.8	Logging model	19
1.9	Generic substation model	20
1.10	Transmission of sample values model	22
1.11	Control model	23
1.12	Time and time synchronisation model	25
1.13	File transfer model	26
1.14	General items	27
1.15	TISSUES	28
2	Basics	31
2.1	General	32
2.2	Effects of Configuration to the Logical Nodes	34
2.2.1	Function parameters general	34
2.2.2	Function parameters SIPROTEC 7SA6	35
2.2.3	Function parameters SIPROTEC 7SA522	39
2.2.4	Function parameters SIPROTEC 7SD5	43
2.2.5	Function parameters SIPROTEC 7SD610	48
2.2.6	Function parameters SIPROTEC 7VK61	51
2.3	Allocation of Logical Nodes to Logical Devices	54
2.4	Logical Node LLN0	58
2.4.1	Logical Device PROT	58
2.4.2	Logical Devices MEAS, CTRL, DR and EXT	59
2.5	The DOI Behavior	60
2.5.1	Logical Device PROT	60
2.5.2	Logical Devices MEAS, CTRL, DR and EXT	61

3	Mapping	63
3.1	Differential Protection (PDIFx, PTRC _x)	64
3.1.1	I-DIFF> (PDIF1)	64
3.1.2	I-DIFF>> (PDIF2)	65
3.1.3	Differential Protection General Information	67
3.2	Distance Protection (PDIS _x , PTRC2)	74
3.2.1	Distance protection zone 1 (PDIS1)	74
3.2.2	Distance protection zone 1B (PDIS10)	80
3.2.3	Distance protection zone 2 (PDIS2)	86
3.2.4	Distance protection zone 3 (PDIS3)	89
3.2.5	Distance protection zone 4 (PDIS4)	92
3.2.6	Distance protection zone 5 (PDIS5)	95
3.2.7	Distance protection general information (PTRC2)	98
3.3	Power swing detection (RPSB _x)	103
3.3.1	Power swing detection zone 1 (RPSB1)	103
3.3.2	Power swing detection zone 1B (RPSB10)	105
3.3.3	Power swing detection zone 2 (RPSB2)	107
3.3.4	Power swing detection zone 3 (RPSB3)	109
3.3.5	Power swing detection zone 4 (RPSB4)	111
3.3.6	Power swing detection zone 5 (RPSB5)	113
3.3.7	Power swing trip command (RPSB6)	115
3.4	Teleprotection for distance protection (PSCH1)	116
3.5	Earth fault overcurrent protection in earthed systems (PTOC _x)	123
3.5.1	Earth fault 3I0 > (PTOC5)	123
3.5.2	Earth fault 3I0 >> (PTOC6)	125
3.5.3	Earth fault 3I0 >>> (PTOC7)	127
3.5.4	Earth fault 3I0p (PTOC8)	129
3.6	Earth fault detection in non-earthed systems (PSDE1)	131
3.7	Restricted earth fault protection (PDIF3)	135
3.8	Overcurrent protection (PTOC _x)	137
3.8.1	O/C I _p (PTOC1)	137
3.8.2	O/C I _{>} (PTOC2)	138
3.8.3	O/C I _{>>} (PTOC3)	139
3.8.4	O/C I _{>>>} (PTOC4)	141
3.8.5	Directional O/C I _p (PTOC9)	143
3.8.6	Directional O/C I _{>} (PTOC10)	145
3.9	Automatic reclosure function (RREC1)	147
3.10	Synchronism and voltage check (RSYN1)	149

3.11	Under and overvoltage protection (PTUVx, PTOVx)	152
3.11.1	Under voltage protection Uph-e < (PTUV1)	152
3.11.2	Undervoltage protection Uph-e<< (PTUV2)	154
3.11.3	Undervoltage protection Uphph< (PTUV3)	156
3.11.4	Undervoltage protection Uphph<< (PTUV4)	158
3.11.5	Undervoltage protection U1< (PTUV5)	160
3.11.6	Undervoltage protection U1<< (PTUV6)	161
3.11.7	Overvoltage protection Uph> (PTOV1)	162
3.11.8	Overvoltage protection Uph-e>> (PTOV2)	164
3.11.9	Overvoltage protection Uphph> (PTOV3)	166
3.11.10	Overvoltage protection Uphph>> (PTOV4)	168
3.11.11	Overvoltage protection 3U0> (PTOV5)	170
3.11.12	Overvoltage protection 3U0>> (PTOV6)	171
3.11.13	Overvoltage protection U1> (PTOV7)	172
3.11.14	Overvoltage protection U1>> (PTOV8)	173
3.11.15	Overvoltage protection U2> (PTOV9)	174
3.11.16	Overvoltage protection U2>> (PTOV10)	175
3.12	Frequency protection (PTUFx, PTOFx)	176
3.12.1	Underfrequency protection FQS stage f1 (PTUF1)	176
3.12.2	Underfrequency protection FQS stage f2 (PTUF2)	178
3.12.3	Underfrequency protection FQS stage f3 (PTUF3)	180
3.12.4	Underfrequency protection FQS stage f4 (PTUF4)	182
3.12.5	Overfrequency protection FQS stage f1 (PTOF1)	184
3.12.6	Overfrequency protection FQS stage f2 (PTOF2)	186
3.12.7	Overfrequency protection FQS stage f3 (PTOF3)	188
3.12.8	Overfrequency protection FQS stage f4 (PTOF4)	190
3.13	Fault locator (RFLO1)	192
3.14	Circuit breaker failure protection (RBRF1)	194
3.15	Thermal overload protection (PTTR1)	196
3.16	Single-pole / threepole tripping Circuit Breaker (XCBRx)	198
3.16.1	Threepole tripping (XCBR1)	198
3.16.2	Single-pole / threepole tripping (XCBR2, XCBR3, XCBR4)	201
3.17	Tripping Logic of the Entire Device (PTRC1)	208
3.18	Device (LPHD1, CALH1)	212
3.18.1	Alarm-, Warn- and Group alarms (CALH1)	213
3.19	Measurements (MMXUx, MSQI1, MMTR1)	216
3.19.1	Measured values of local device (MMXU1)	216
3.19.2	Remote measured values of relay 1 (MMXU2)	220
3.19.3	Remote measured values of relay 2 (MMXU3)	223
3.19.4	Remote measured values of relay 3 (MMXU4)	226
3.19.5	Remote measured values of relay 4 (MMXU5)	229
3.19.6	Remote measured values of relay 5 (MMXU6)	232
3.19.7	Remote measured values of relay 6 (MMXU7)	235
3.19.8	Measured values, symmetrical components (MSQI1)	238
3.19.9	Power Metering (MMTR1)	240

3.20	Oscillographic Fault Records (RDRE1)	242
------	--	-----

Literature

Index

Applications

Contents

This chapter specifies the protocol implementation extra information for testing (PIXIT) of the IEC 61850 interface in SIPROTEC 7SD / 7SA / 7VK V4.6.

1.1	General	10
1.2	Association model	11
1.3	Server model	12
1.4	Data set model	13
1.5	Substitution model	14
1.6	Setting group control model	15
1.7	Reporting model	16
1.8	Logging model	19
1.9	Generic substation model	20
1.10	Transmission of sample values model	22
1.11	Control model	23
1.12	Time and time synchronisation model	25
1.13	File transfer model	26
1.14	General items	27
1.15	TISSUES	28

1.1 General

This chapter specifies the protocol implementation extra information for testing (PIXIT) of the IEC 61850 interface in SIPROTEC 7SD / 7SA / 7VK V4.6.

It is based on the service subset definition given in the protocol implementation conformance statement (PICS), which is specified within the user manual *SIPROTEC 4 Ethernet Module EN 100 IEC 61850 Electrical/optical Interface 100 MBit, Manual /1/*.

The following applicable ACSI service models are specified:

- Association model
- Server model
- Data set model
- Substitution model
- Setting group control model
- Reporting model
- Logging model
- Generic substitution model
- Transmission of sample values model
- Control model
- Time and time synchronisation model
- File transfer model
- General items

Together with the PICS and the MICS the PIXIT forms the basis for a conformance test according to IEC 61850-10.

The mapping between the IEC 61850 server data model and the SIPROTEC specific data is specified in Chapter 3.

1.2 Association model

Description	Value / Clarification
Maximum number of clients that can set-up an association simultaneously	5
Lost connection detection time range (default range of TCP_KEEPALIVE is 1 – 20 seconds)	10 seconds
Is authentication supported	N
What called association parameters are necessary for successful association ?	Transport selector Y Session selector Y Presentation selector Y AP Title ANY AE Qualifier ANY Where Y means: as defined within the ICD-File ANY means: any value accepted
What is the maximum and minimum MMS PDU size ?	Max MMS PDU size 32768 Min MMS PDU size
What is the typical startup time after a power supply interrupt ?	15 SECONDS
<additional items>	

1.3 Server model

Description	Value / Clarification
Which analogue value (MX) quality bits are supported (can be set by server) ?	Validity: Y Good, Y Invalid, N Reserved, Y Questionable Y Overflow Y OutofRange N BadReference N Oscillatory Y Failure Y OldData N Inconsistent Y Inaccurate Source: Y Process N Substituted Y Test Y OperatorBlocked
Which status value (ST) quality bits are supported (can be set by server) ?	Validity: Y Good, Y Invalid, N Reserved, Y Questionable N BadReference Y Oscillatory Y Failure Y OldData N Inconsistent N Inaccurate Source: Y Process Y Substituted Y Test Y OperatorBlocked
What is the maximum number of data values in one GetDataValues request ?	Not restricted; depends on the max. MMS PDU size given above.
What is the maximum number of data values in one SetDataValues request ?	Not restricted; depends on the max. MMS PDU size given above. No Data Attribute within our object directory is writable with the service SetDataValues.
<additional items>	

1.4 Data set model

Description	Value / Clarification
Maximum number of data elements in one data set	Not limited by an internal configuration parameter. It depends on the available memory.
How many persistent data sets can be created by one or more clients ?	64 data sets for each LD. It depends on the available memory.
How many non-persistent data sets can be created by one or more clients ?	10 data sets. It depends on the available memory.
additional items:	
Maximum number of data sets	Could not be defined, it depends on the available memory space. In principle, this information it not necessary from type conformance testing standpoint.

1.5 Substitution model

This service will not be supported (see also *SIPROTEC 4 Ethernet Module EN 100 IEC 61850 Electrical/optical Interface 100 MBit, Manual /1/*).

1.6 Setting group control model

Description	Value / Clarification
What is the number of supported setting groups for each logical device ?	Setting groups available for LLN0 only in LD PROT. The number of supported setting groups is 1 or 4, it depends on the given configuration. Specified in the ICD-File.
What is the effect of when and how the non-volatile storage is updated ? (compare IEC 61850-8-1 §16.2.4)	Just SelectActiveSG service will supported according to PICS.
<additional items>	

1.7 Reporting model

1.7.1 Unbuffered Report

Description	Value / Clarification
The supported trigger conditions are	Y Integrity Y Data change Y Quality change Y Data update Y General Interrogation
The supported optional fields are	Y Sequence-number Y Report-time-stamp Y Reason-for-inclusion Y Data-set-name Y Data-reference N Buffer-overflow N EntryID Y Conf-rev Y Segmentation
Can the server send segmented reports ?	Y
Mechanism on second internal data change notification of the same analogue data value within buffer period (Compare IEC 61850-7-2 §14.2.2.9)	Send report immediately
Multi client URCB approach (Compare IEC 61850-7-2 §14.2.1)	All clients can access all URCB's
additional items:	
Interrupt of general interrogation	Running GI could not be interrupted. If a new GI request occurs during a running GI, the current GI will be finished first before the second GI request will be processed.
Integrity period	Configurable ≥ 1 second;
Dynamic URCB reservation after an abort of the client/server association	Reservation of the URCB is lost. After a re-establishment of the association the URCB reservation has to be done by the client before. This behavior is implemented to avoid unnecessary memory residuals if temporarily client associations (e.g. for maintenance) are established.
Configured URCB reservation after an abort of the client/server association	Reservation of the URCB is not lost.

1.7.2 Buffered Report

Description	Value / Clarification
The supported trigger conditions are	Y Integrity Y Data change Y Quality change Y Data update Y General Interrogation
The supported optional fields are	Y Sequence-number Y Report-time-stamp Y Reason-for-inclusion Y Data-set-name Y Data-reference Y Buffer-overflow Y EntryID Y Conf-rev Y Segmentation
Can the server send segmented reports ?	Y
Mechanism on second internal data change notification of the same analogue data value within buffer period (Compare IEC 61850-7-2 §14.2.2.9)	Buffer the Entry Send report if the report is enabled
Multi client BRCB approach (Compare IEC 61850-7-2 §14.2.1)	All clients can access all BRCB's
What is the format of EntryID ?	First 2 Byte : Integer Last 6 Bytes: BTime6 time stamp
What is the buffer size for each BRCB or how many reports can be buffered ?	About 1 MB are available for the buffering. Each BRCB has an extension attribute Memory that display the percentage of those 1 MB that have been reserved/forseen for its own entries. Default amount 1 MB/(2*Number of logical devices)
additional items:	
Interrupt of general interrogation	Running GI could not be interrupted. If a new GI request occurs during a running GI, the current GI will be finished first before the second GI request will be processed.
Integrity period	Configurable >=1 second;
Dynamic BRCB reservation after an abort of the client/server association	Reservation of the BRCB has been fixed with TISSUE 453. The value of the attribute ResvTms delivers the time interval during which the reservation is still active after the connection has been lost. In case a BRCB is still reserved, and a client connects with the same IP address as the one used during the reservation, then the BRCB attribute can be written by this client without prior setting the ResvTms attribute as long as the reservation timer has not expired.

<p>Configured BRCB reservation after an abort of the client/server association</p>	<p>Reservation of the BRCB is not lost for BRCBs that have been pre-associated to a specific client (pre-association defined with means of the CLientLN element with the BRCB instantiation in the SCD file).</p> <p>Reservation of a BRCB is lost for BRCBs, that have not been pre-associated to a specific client, after the expiration of the reservation timer set with the ResvTms attribute. In case ResvTms is not set (backward compatibility), ResvTms will get a default value for all preconfigured BRCBs that are not pre-associated to a specific client.</p>
<p>Optional use of a flow control for transmitting history of a BRCB</p>	<p>As specified in the IEC61850-7-2, transmission of entries may required some times, depending of the amount of entries that have to be transmitted.</p> <p>Therefore, the SIPROTEC has an optional flow control feature to accelerate the transmission of the entries: each BRCB has an extended attribute MaxOutReports that can be set from the associated-client to change the transmission strategy of the entries. The number ordered will then be transmitted as long as they exist in the buffer; the server then reset the attribute to 0 and wait for the client to set it again in order to continue the history transmission with MaxOutReports entries. The attribute only influences the flow control of entries while dealing with the history, and not after the history transmission has completed.</p>

1.8 Logging model

This service will not be supported (see also *SIPROTEC 4 Ethernet Module EN 100 IEC 61850 Electrical/optical Interface 100 MBit, Manual /1/*).

1.9 Generic substation model

Description	Value / Clarification
What is the behavior when one subscribed GOOSE message isn't received or syntactically incorrect ?	The telegram will be discarded (i.e not forwarded to the application) since it is corrupt or syntactically incorrect and therefore not readable. The data objects will be declared as invalid after a timeout detection since no telegram have been received by the application.
What is the behavior when a subscribed GOOSE message is out-of-order ?	Error message will be stored into the error buffer (could be accessed by EN100 web-server). All expected data objects will be declared as invalid.
What is the behavior when a subscribed GOOSE message is duplicated ?	The sequence number given in the GOOSE-message is out-of-order. Error message will be stored into the error buffer (could be accessed by EN100 web-server). All expected data objects will be declared as invalid.
additional items:	
Maximum number of GOOSE messages which could be sent	<= 16 ; It depends on the available memory.
Maximum number of GOOSE messages which could be received	<= 128 ; It depends on the available memory.
Interpretation of GOOSE messages at subscriber side	1. Received GOOSE data objects without assigned quality attribute are interpreted as invalid. 2. Received GOOSE data objects which quality attribute are set to questionable are changed to invalid.
GOOSE subscriber behavior in case of missing GOOSE messages	After a GOOSE multicast application association has been interrupted, the reception of the second consecutive GOOSE telegram is required to validate the state of this GOOSE association again. However, the IED tolerates a missing telegram as long as the next telegram (expected n, received n+1) is received within the time allowed to live time out detection (the time allowed to live timeout detection occurs after 2*TAL).
GOOSE subscriber behaviour in case of multiple GOOSE messages	If a message is received twice or more, the IED already reports an error after the second reception. Therefore, network configuration error can be more easily tracked.
What is the behavior when a GOOSE header parameter is mismatching with the expected one? (datSet, goID, confRev, numDatSetEntries, number of allData)	Error message will be stored into the error buffer (could be accessed by EN100 web-server). All expected data objects will be declared as invalid.
What is the behavior when a timeAllowedToLive is 0?	Error message will be stored into the error buffer (could be accessed by EN100 web-server) since the timeAllowedToLive expired. All expected data objects will be declared as invalid.

What is the behavior when there is an out-of-order entry in the allData?	The confRev attribute in the header guarantees that the allData entries are in the correct order. Therefore, it's necessary to check the confRev attribute. There is no chance to detect such an out-of-order.
What is the behavior when no telegram is received within a TAL timeout?	To avoid an incorrect timeout detection, the subscriber detects a timeout after a period of 2×TAL. The information is then declared as questionable, oldData.
What is the behavior when a GOOSE header parameter goCBRef is mismatching with the expected one?	Since the goCBRef shall be unique stationwide, the received telegram with the mismatched goCBRef will be discarded: it has not been published. In that case only the timeout detection will set the data to invalid.
What is the behavior when a GOOSE header parameter APPID is mismatching with the expected one?	The APPID is a link layer parameter. It is used as a filter on link layer. If the APPID is mismatching, the telegram will therefore be discarded on link layer without notifying the application. Only the timeout detection will set the data to invalid.
What is the behavior when a GOOSE header parameter t is not increasing?	The t parameter is not checked. Therefore it doesn't lead to any error detection.
What is the behavior when numDatSetEntries and number of allData are inconsistent?	The telegram is discarded since it is corrupt (not well formed). After the timeout detection (no telegram forwarded to the application) the data objects are declared invalid.

1.10 Transmission of sample values model

Compare the "Implementation Guidelines for Electrical Current and Voltage Transducers according to IEC 60044-7/8 with Digital Output according to IEC 61850-9-2; Version 1.0; as specified by ABB, Areva, Landis+Gyr, OMICRON and SIEMENS

This service will not be supported (see also *SIPROTEC 4 Ethernet Module EN 100 IEC 61850 Electrical/optical Interface 100 MBit, Manual /1/*).

1.11 Control model

Description	Value / Clarification
What control models are supported ?	Y Status-only Y Direct-with-normal-security N Sbo-with-normal-security Y Direct-with-enhanced-security Y Sbo-with-enhanced-security
Is Time activated operate (operTm) supported	N
What is the behavior when the test attribute is set in the SelectWithValue and/or Operate request ?	Will be acknowledged with negative response. The AddCause attribute will be set to "not supported"
What are the conditions for the time (T) attribute in the SelectWithValue and/or Operate request ?	Time attribute is not relevant.
Is "operate-many" supported ?	N
Is pulse configuration supported ?	N
What check conditions are supported ?	Y Synchrocheck Y Interlock-check
What service error types are supported ?	Y Instance-not-available Y Instance-in-use Y Access-violation Y Access-not-allowed-in-current-state Y Parameter-value-inappropriate Y Parameter-value-inconsistent Y Class-not-supported Y Instance-locked-by-other-client Y Control-must-be-selected Y Type-conflict Y Failed-due-to-communications Y Constraint failed-due-to-server-constraint

What additional cause diagnosis are supported ?	N Blocked-by-switching-hierarchy Y Select-failed Y Invalid-position Y Position-reached Y Parameter-change-in-execution Y Step-limit Y Blocked-by-Mode Y Blocked-by-process Y Blocked-by-interlocking Y Blocked-by-synchrocheck Y Command-already-in-execution N Blocked-by-health Y 1-of-n-control Y Abortion-by-cancel Y Time-limit-over N Abortion-by-trip Y Object-not-selected
additional items:	
What additional cause diagnosis extensions are supported ?	Y Plausibility_error Y Parameter_setting_invalid Y Hardware_error Y System_overload Y Internal_fault Y Command_sequence_error
Changing the control services by configuration	N
Inconsistency between Select and (Oper or cancel)	Oper or cancel will be acknowledged with negative response if inconsistencies to the select request are detected. The following attributes will not be checked in this case: T (Time)
Cancel request could be sent after an operate request.	Y
Format of the control time stamp attribute ?	TimeStamp instead of EntryTime acc. to the 7-2 Errata List.
Negative response for select request could be performed only	If test mode is activated or If the selection is always done.

1.12 Time and time synchronisation model

Description	Value / Clarification
What kind of quality bits are supported ?	N LeapSecondsKnown Y ClockFailure Y ClockNotSynchronized
What kind of quality accuracy bits are supported ?	Y Invalid N Unspecified
What is the behavior when the time synchronization signal/messages are lost ?	The quality attribute "ClockFailure" will be set to TRUE after a configured time period.
What is the behaviour when the time synchronisation messages indicate that the stratum is greater than 3?	A stratum with a value greater than 3 with the SNTP time synchronization messages indicates that the time server has a questionable synchronisation. It might also indicate that no GPS connection are available. Therefore the time quality attribute "ClockNotSynchronized" will be set to TRUE as long as the stratum content is greater than 3.
additional items:	
What is the behavior at start up time when a time synchronization via SNTP is configured ?	The "ClockNotSynchronized" attribute is set to TRUE as long as no time synchronization is established.

1.13 File transfer model

Description	Value / Clarification
What is structure of files and directories?	Directory name / COMTRADE / *; Directory name / LD / *; Files according to the comtrade standard.
What is the resulting behavior if no file specification is present in the file directory request?	If no file specification is present in the directory request, all files are returned - not only the files in the root directory.
Is the IETF FTP protocol also implemented ?	N
Directory names are separated from the file name by	"/"
The maximum file name size including path (default 64 chars)	64
Are directory/file name case sensitive	Case sensitive
Maximum file size	Not limited by implementation or configuration. Depends on available memory.
additional items:	
Maximum number of clients that can use the FTP service simultaneously	1
Maximum number of files that can be accessed simultaneously	1

1.14 General items

Description	Value / Clarification
IED behavior when the Logical Device is blocked : LLN0.Mod.stVal = blocked	Unlike the definition of the Data Objects "Mod/Beh" in IEC 61850-7-4, outputs to the process will be generated. Details to this behavior are specified in <i>SIPROTEC 4 Ethernet Module EN 100 IEC 61850 Electrical/optical Interface 100 MBit, Manual /1/</i>
additional items:	
GOOSE Proxy object	To be able to subscribe Data over GOOSE, Proxy Objects are added into the object directory. Typically, they are Data of GGIO logical nodes: SPCSOxx, DPCSOxx, ISCSOxx. The Data Attributes of those Data are ctlVal, q and t. The control model associated to those Data is status-only. They are not controllable from an IEC61850 client, and their function is only to enable the GOOSE subscribing.
What is the type of the attribute actVal in the BCR (Binary Counter Reading) CDC?	The type is integer 32 (INT32).

1.15 TISSUES

Topic	TISSUE -No.	Link	Description	Impact of Interoper.
Object Directory	433	http://www.tissue.iec61850.com/tissue.aspx?issueid=433	Order of attributes in specialized CDCs for control service mapping	-
	422	http://www.tissue.iec61850.com/tissue.aspx?issueid=422	Order of extension data objects and data attributes	-
	168	http://www.tissue.iec61850.com/tissue.aspx?issueid=168	Order of attributes in MMS components	-
Object Model	120	http://www.tissue.iec61850.com/tissue.aspx?issueid=120	Type - Mod.stVal and Mod.ctlVal	-
	146	http://www.tissue.iec61850.com/tissue.aspx?issueid=146	CtxInt	-
	173	http://www.tissue.iec61850.com/tissue.aspx?issueid=173	Ctl modelling harmonization	-
	234	http://www.tissue.iec61850.com/tissue.aspx?issueid=234	New type CtxInt	x
Services	377	http://www.tissue.iec61850.com/tissue.aspx?issueid=377	DeleteDataSet response-	-
	276	http://www.tissue.iec61850.com/tissue.aspx?issueid=276	File Services Negative Responses	-
	183	http://www.tissue.iec61850.com/tissue.aspx?issueid=183	GetNameList error handling	x
	165	http://www.tissue.iec61850.com/tissue.aspx?issueid=165	Improper Error Response for GetDataSetValues	x
	116	http://www.tissue.iec61850.com/tissue.aspx?issueid=116	GetNameList with empty response?	x
Reporting	474	http://www.tissue.iec61850.com/tissue.aspx?issueid=474	GI for URCB	-
	453	http://www.tissue.iec61850.com/tissue.aspx?issueid=453	Reporting & Logging model revision	x
	438	http://www.tissue.iec61850.com/tissue.aspx?issueid=438	EntryTime base should be GMT	-
	349	http://www.tissue.iec61850.com/tissue.aspx?issueid=349	BRCB TimeOfEntry has two definitions	x
	348	http://www.tissue.iec61850.com/tissue.aspx?issueid=348	URCB class and report	x

Reporting	344	http://www.tissue.iec61850.com/tissue.msp?issueid=344	TimeOfEntry misspelled	-
	335	http://www.tissue.iec61850.com/tissue.msp?issueid=335	Clearing of Bufovfl	x
	332	http://www.tissue.iec61850.com/tissue.msp?issueid=332	Ambiguity in use of trigger options	x
	329	http://www.tissue.iec61850.com/tissue.msp?issueid=329	Reporting and BufOvl	x
	322	http://www.tissue.iec61850.com/tissue.msp?issueid=322	Write Configuration attribute of BRCBs	
	301	http://www.tissue.iec61850.com/tissue.msp?issueid=301	SqNum in Buffered Reports	-
	300	http://www.tissue.iec61850.com/tissue.msp?issueid=300	Attribute Resv in BRCB	x
	298	http://www.tissue.iec61850.com/tissue.msp?issueid=298	Type of SqNum	x
	297	http://www.tissue.iec61850.com/tissue.msp?issueid=297	Sequence number	x
	278	http://www.tissue.iec61850.com/tissue.msp?issueid=278	EntryId not valid for a server	x
	275	http://www.tissue.iec61850.com/tissue.msp?issueid=275	Confusing statement on GI usage	x
	191	http://www.tissue.iec61850.com/tissue.msp?issueid=191	BRCB: Integrity and buffering reports	x
	190	http://www.tissue.iec61850.com/tissue.msp?issueid=190	BRCB: EntryId and TimeOfEntry	x
	177	http://www.tissue.iec61850.com/tissue.msp?issueid=177	Ignoring OptFlds bits for URBCB	-
	52	http://www.tissue.iec61850.com/tissue.msp?issueid=52	Ambiguity GOOSE SqNum	x
	49	http://www.tissue.iec61850.com/tissue.msp?issueid=49	BRCB TimeOfEntry?	x
Control Model	46	http://www.tissue.iec61850.com/tissue.msp?issueid=46	Synchro check cancel	x
	44	http://www.tissue.iec61850.com/tissue.msp?issueid=44	AddCause - Object not sel	x
	30	http://www.tissue.iec61850.com/tissue.msp?issueid=30	control parameter T	x

Basics

Contents

This chapter contains general information about the effects of device configuration on Logical Nodes and DOIs.

2.1	General	32
2.2	Effects of Configuration to the Logical Nodes	34
2.3	Allocation of Logical Nodes to Logical Devices	54
2.4	Logical Node LLN0	58
2.5	The DOI Behavior	60

2.1 General

The protocol IEC 61850 was developed to define a standard that can be internationally employed for the transmission of power automation system data.

This cross national standard enables an interoperability between automation systems and devices made by different manufacturers.

The devices and high voltage bay control units of the SIPROTEC 4 series can be equipped with an Ethernet module EN100 via which the protocol IEC 61850 is interpreted.

The configuration of the protocol and the integration of the device with redundant IEC 61850 interfaces in your network are performed via the configuration system DIGSI.

For details please refer to the manuals:

- ❑ *SIPROTEC 4 Ethernet Module EN 100 IEC 61850 Electrical/optical Interface 100 MBit, Manual /1/* and
- ❑ *SIPROTEC 4 System Description /2/*.



Note

The following definitions are taken mainly from standard IEC 61850, Technical Specification IEC TS 61850-2.

Logical Devices

LD Logical Devices represent a functional structuring of the LN Logical Nodes of a SIPROTEC device.

The following Logical Devices are present:

- ❑ Logical Device Protection PROT
- ❑ Logical Device Measurement MEAS
- ❑ Logical Device Disturbance Recorder DR
- ❑ Logical Device Control CTRL
- ❑ Logical Device Extended EXT

Each LD contains LN LLN0 and LN LPHD1.

The allocation of the Logical Nodes to the Logical Devices is listed in Chapter 2.3.

Logical Node LN

Smallest part of a function that exchanges data. A logical node is an object defined by its data and methods.

Data object instance DOI

A Data object is part of a logical node object representing specific information for example status of measurement. From an object-oriented point of view, a data object is an instance of a data class. Specific data classes carry the semantic within a logical node.

Data attribute instance DAI

A Data attribute defines the name (semantic), format, range of possible values, and representation of values while being communicated.

Annunciation types via GOOSE**Generic Object Oriented Substation Event**

A GOOSE report enables high speed trip signals to be issued with a high probability of delivery.

The following types of information can be configured via GOOSE.

- External single point indication O/O
- External single point indication I/O
- External double point indication
- External double point indication, fast
- External operational measured values
- External metered values

2.2 Effects of Configuration to the Logical Nodes

2.2.1 Function parameters general

Depending on the configuration of the function parameters the functions of the SIPROTEC are enabled or disabled. If a function is disabled, the corresponding Logical Node is not available.

The following Logical Nodes are always available:

Logical Device Protection:	LLN0, LPHD1, PTRC1
Logical Device Measurement:	LLN0, LPHD1, MMXU1, MMTR1, MSQ11
Logical Device Disturbance Recorder:	LLN0, LPHD1
Logical Device Control:	LLN0, LPHD1, CALH1

2.2.2 Function parameters SIPROTEC 7SA6

The following table shows which Logical Nodes are available when setting the corresponding function parameter.

The setting (-) implies that no corresponding LN is available.

Table 2-1 SIPROTEC 7SA6 - Effects of Function parameters to the Logical Nodes

No.	Funktion	Setting	Logical Nodes
103	Setting Group Change Option		No effect
	Disturbance Recorder	-	RDRE1
110	Trip mode	3pole only	XCBR1
		1-/3pole	XCBR2, XCBR3, XCBR4
114	Distance protection pickup program	Disabled	-
		Z< (quadrilat.)	PDIS1 – PDIS5, PTRC2
		I> (overcurr.)	-
		U/I	-
		U/I/φ	-
115	Characteristic of distance zones		No effect
120	Power Swing detection	Disabled	-
		Enabled	RPSB1 – RPSB6
121	Teleprotection for Distance protection	Disabled	-
		PUTT (Z1B)	PSCH1
		PUTT (Pickup)	PSCH1
		POTT	PSCH1
		Dir.Comp.Pickup	PSCH1
		Unblocking	PSCH1
		Blocking	PSCH1
		Rev. Interlock	PSCH1
		Pilot wire comp	PSCH1

Table 2-1 SIPROTEC 7SA6 - Effects of Function parameters to the Logical Nodes (Cont.)

No.	Funktion	Setting	Logical Nodes
122	DTT Direct Transfer Trip		No effect
124	Instantaneous HighSpeed SOTF Overcurrent		No effect
125	Weak Infeed (Trip and/or Echo)		No effect
126	Backup overcurrent	Disabled	-
		TOC IEC	PTOC1 - PTOC3
		TOC IEC /w 3ST	PTOC1- PTOC4
		TOC ANSI	PTOC1- PTOC4
130	Sensitive Earth Flt.(comp/ isol. starp.)	Disabled	-
		Enabled	PSDE1
131	Earth fault overcurrent	Disabled	-
		TOC IEC	PTOC5 – PTOC8
		TOC ANSI	PTOC5 – PTOC8
		TOC Logarithm.	PTOC5 – PTOC8
		Definite Time	PTOC5 – PTOC7
		U0 invers	PTOC5 – PTOC8
		Sr inverse	PTOC5 – PTOC8
132	Teleprotection for Earth fault overcurrent		No effect

Table 2-1 SIPROTEC 7SA6 - Effects of Function parameters to the Logical Nodes (Cont.)

No.	Funktion	Setting	Logical Nodes
133	Auto-Reclose Function	Disabled	-
		1 AR-cycle	RREC1
		2 AR-cycles	RREC1
		3 AR-cycles	RREC1
		4 AR-cycles	RREC1
		5 AR-cycles	RREC1
		6 AR-cycles	RREC1
		7 AR-cycles	RREC1
		8 AR-cycles	RREC1
		ADT	RREC1
134	Auto-Reclose control mode		No effect
135	Synchronism and Voltage Check	Disabled	-
		Enabled	RSYN1
136	Over / Underfrequency Protection	Disabled	-
		Enabled	PTOF1 – PTOF4, PTUF1 – PTUF4
137	Under / Overvoltage Protection	Disabled	-
		Enabled	PTUV1 – PTUV6, PTOV1 – PTOV10
		Enabl. w. comp.	PTUV1 –PTUV6, PTOV1 – PTOV10
138	Fault Locator	Disabled	-
		Enabled	RFLO1
		with BCD-output	RFLO1

Table 2-1 SIPROTEC 7SA6 - Effects of Function parameters to the Logical Nodes (Cont.)

No.	Funktion	Setting	Logical Nodes
139	Breaker Failure Protection	Disabled	-
		Enabled	RBRF1
		enabled w/ 3I0>	RBRF1
140	Trip Circuit Supervision	Disabled	-
		1 Trip Circuit	XCBR1.CirSpv - XCBR4.CirSpv
		2 Trip Circuits	XCBR1.CirSpv - XCBR4.CirSpv
		3 Trip Circuits	XCBR1.CirSpv - XCBR4.CirSpv
142	Thermal overload protection	Disabled	-
		Enabled	PTTR1
145	Protection Interface 1 (Port D)	Disabled	-
		Enabled	MMXU2 - MMXU4
147	Number of relays	2 relays, Protection Interface 1 disabled	-
		2 relays, Protection Interface 1 enabled	MMXU2, MMXU3
		3 relays	MMXU2, MMXU3, MMXU4
150	Analog Output B1 (Port B)		No effect
151	Analog Output B2 (Port B)		No effect
152	Analog Output D1 (Port D)		No effect
153	Analog Output D2 (Port D)		No effect

2.2.3 Function parameters SIPROTEC 7SA522

The following table shows which Logical Nodes are available when setting the corresponding function parameter.

The setting (-) implies that no corresponding LN is available.

Table 2-2 SIPROTEC 7SA522 - Effects of Function parameters to the Logical Nodes

No.	Funktion	Setting	Logical Nodes
103	Setting Group Change Option		No effect
	Disturbance Recorder	-	RDRE1
110	Trip mode	3pole only	XCBR1
		1-/3pole	XCBR2, XCBR3, XCBR4
112	Phase Distance	Disabled	-
		Quadrilateral	PDIS1 – PDIS5, PTRC2
		MHO	PDIS1 – PDIS5, PTRC2
113	Earth Distance	Disabled	-
		Quadrilateral	PDIS1 – PDIS5, PTRC2
		MHO	PDIS1 – PDIS5, PTRC2
120	Power Swing detection	Disabled	-
		Enabled	RPSB1 – RPSB6
121	Teleprotection for Distance protection	Disabled	-
		PUTT (Z1B)	PSCH1
		POTT	PSCH1
		Unblocking	PSCH1
		Blocking	PSCH1
		SIGNALv.ProtInt	PSCH1
122	DTT Direct Transfer Trip		No effect
124	Instantaneous HighSpeed SOTF Overcurrent		No effect

Table 2-2 SIPROTEC 7SA522 - Effects of Function parameters to the Logical Nodes (Cont.)

No.	Funktion	Setting	Logical Nodes
125	Weak Infeed (Trip and/or Echo)		No effect
126	Backup overcurrent	Disabled	-
		TOC IEC	PTOC1 – PTOC3
		TOC IEC /w 3ST	PTOC1 - PTOC4
		TOC ANSI	PTOC1 - PTOC4
131	Earth fault overcurrent	Disabled	-
		TOC IEC	PTOC5 – PTOC8
		TOC ANSI	PTOC5 – PTOC8
		TOC Logarithm.	PTOC5 – PTOC8
		Definite Time	PTOC5 – PTOC7
		U0 invers	PTOC5 – PTOC8
		Sr inverse	PTOC5 – PTOC8
132	Teleprotection for Earth fault overcurrent		No effect
133	Auto-Reclose Function	Disabled	-
		1 AR-cycle	RREC1
		2 AR-cycles	RREC1
		3 AR-cycles	RREC1
		4 AR-cycles	RREC1
		5 AR-cycles	RREC1
		6 AR-cycles	RREC1
		7 AR-cycles	RREC1
		8 AR-cycles	RREC1
		ADT	RREC1
134	Auto-Reclose control mode		No effect

Table 2-2 SIPROTEC 7SA522 - Effects of Function parameters to the Logical Nodes (Cont.)

No.	Funktion	Setting	Logical Nodes
135	Synchronism and Voltage Check	Disabled	-
		Enabled	RSYN1
136	Over / Underfrequency Protection	Disabled	-
		Enabled	PTOF1 – PTOF4, PTUF1 – PTUF4
137	Under / Overvoltage Protection	Disabled	-
		Enabled	PTUV1 – PTUV6, PTOV1 – PTOV10
		Enabl. w. comp.	PTUV1 –PTUV6, PTOV1 – PTOV10
138	Fault Locator	Disabled	-
		Enabled	RFLO1
		with BCD-output	RFLO1
139	Breaker Failure Protection	Disabled	-
		Enabled	RBRF1
		enabled w/ 3I0>	RBRF1
140	Trip Circuit Supervision	Disabled	-
		1 Trip Circuit	XCBR1.CirSpv - XCBR4.CirSpv
		2 Trip Circuits	XCBR1.CirSpv - XCBR4.CirSpv
		3 Trip Circuits	XCBR1.CirSpv - XCBR4.CirSpv
145	Protection Interface 1 (Port D)	Disabled (Prot. Interf. 2 disabled)	-
		Disabled (Prot. Interf. 2 enabled)	MMXU2 - MMXU4
		Enabled	MMXU2 - MMXU4

Table 2-2 SIPROTEC 7SA522 - Effects of Function parameters to the Logical Nodes (Cont.)

No.	Funktion	Setting	Logical Nodes
146	Protection Interface 2 (Port E)	Disabled (Prot. Interf. 1 disabled)	-
		Disabled (Prot. Interf. 1 enabled)	MMXU2 - MMXU4
		Enabled	MMXU2 - MMXU4
147	Number of relays	2 relays, no Protection Interface	-
		2 relays, min. 1 Protection Interface	MMXU2, MMXU3
		3 relays	MMXU2, MMXU3, MMXU4

2.2.4 Function parameters SIPROTEC 7SD5

The following table shows which Logical Nodes are available when setting the corresponding function parameter.

The setting (-) implies that no corresponding LN is available.

Table 2-3 SIPROTEC 7SD5 - Effects of Function parameters to the Logical Nodes

No.	Funktion	Setting	Logical Nodes
103	Setting Group Change Option		No effect
	Disturbance Recorder	-	RDRE1
110	Trip mode	3pole only	XCBR1
		1-/3pole	XCBR2, XCBR3, XCBR4
112	Differential protection	Disabled	-
		Enabled	PDIF1, PDIF2, PTRC3
115	Phase Distance	Disabled	-
		Quadrilateral	PDIS1 – PDIS5, PTRC2
		MHO	PDIS1 – PDIS5, PTRC2
116	Earth Distance	Disabled	-
		Quadrilateral	PDIS1 – PDIS5, PTRC2
		MHO	PDIS1 – PDIS5, PTRC2
117	Distance protection pickup program		No effect
120	Power Swing detection	Disabled	-
		Enabled	RPSB1 – RPSB6, RPSB10

Table 2-3 SIPROTEC 7SD5 - Effects of Function parameters to the Logical Nodes (Cont.)

No.	Funktion	Setting	Logical Nodes
121	Teleprotection for Distance protection	Disabled	-
		PUTT (Z1B)	PSCH1
		PUTT (Pickup)	PSCH1
		POTT	PSCH1
		Dir.Comp.Pickup	PSCH1
		Unblocking	PSCH1
		Blocking	PSCH1
		Rev. Interlock	PSCH1
		Pilot wire comp	PSCH1
122	DTT Direct Transfer Trip		No effect
124	Instantaneous HighSpeed SOTF Overcurrent		No effect
125	Weak Infeed (Trip and/or Echo)		No effect
126	Backup overcurrent	Disabled	-
		TOC IEC	PTOC1 – PTOC4, PTOC9, PTOC10
		TOC ANSI	PTOC1 – PTOC4, PTOC9, PTOC10
131	Earth fault overcurrent	Disabled	-
		TOC IEC	PTOC5 – PTOC8
		TOC ANSI	PTOC5 – PTOC8
		TOC Logarithm.	PTOC5 – PTOC8
		Definite Time	PTOC5 – PTOC7
		U0 invers	PTOC5 – PTOC8
		Sr inverse	PTOC5 – PTOC8
132	Teleprotection for Earth fault overcurrent		No effect

Table 2-3 SIPROTEC 7SD5 - Effects of Function parameters to the Logical Nodes (Cont.)

No.	Funktion	Setting	Logical Nodes
133	Auto-Reclose Function	Disabled	-
		1 AR-cycle	RREC1
		2 AR-cycles	RREC1
		3 AR-cycles	RREC1
		4 AR-cycles	RREC1
		5 AR-cycles	RREC1
		6 AR-cycles	RREC1
		7 AR-cycles	RREC1
		8 AR-cycles	RREC1
		ADT	RREC1
134	Auto-Reclose control mode		No effect
135	Synchronism and Voltage Check	Disabled	-
		Enabled	RSYN1
136	Over / Underfrequency Protection	Disabled	-
		Enabled	PTOF1 – PTOF4, PTUF1 – PTUF4
137	Under / Overvoltage Protection	Disabled	-
		Enabled	PTUV1 – PTUV6, PTOV1 – PTOV10
		Enabl. w. comp.	PTUV1 –PTUV6, PTOV1 – PTOV10
138	Fault Locator	Disabled	-
		Enabled	RFLO1
		with BCD-output	RFLO1

Table 2-3 SIPROTEC 7SD5 - Effects of Function parameters to the Logical Nodes (Cont.)

No.	Funktion	Setting	Logical Nodes
139	Breaker Failure Protection	Disabled	-
		Enabled	RBRF1
		enabled w/ 3I0>	RBRF1
140	Trip Circuit Supervision	Disabled	-
		1 Trip Circuit	XCBR1.CirSpv - XCBR4.CirSpv
		2 Trip Circuits	XCBR1.CirSpv - XCBR4.CirSpv
		3 Trip Circuits	XCBR1.CirSpv - XCBR4.CirSpv
141	Restricted earth fault protection	Disabled	-
		Enabled	PDIF3
142	Thermal overload protection	Disabled	-
		Enabled	PTTR1
143	Transformer inside protection zone		No effect
144	Voltage transformers		No effect
145	Protection Interface 1 (Port D)	Disabled (Prot. Interf. 2 disabled)	-
		Disabled (Prot. Interf. 2 enabled)	MMXU2 - MMXU7
		Enabled	MMXU2 - MMXU7
146	Protection Interface 2 (Port E)	Disabled (Prot. Interf. 1 disabled)	-
		Disabled (Prot. Interf. 1 enabled)	MMXU2 - MMXU7
		Enabled	MMXU2 - MMXU7

Table 2-3 SIPROTEC 7SD5 - Effects of Function parameters to the Logical Nodes (Cont.)

No.	Funktion	Setting	Logical Nodes
147	Number of relays	2 relays, no Protection Interface	-
		2 relays, min. 1 Protection Interface	MMXU2, MMXU3
		3 relays	MMXU2, MMXU3, MMXU4
		4 relays	MMXU2, MMXU3, MMXU4, MMXU5
		5 relays	MMXU2, MMXU3, MMXU4, MMXU5, MMXU6
		6 relays	MMXU2, MMXU3, MMXU4, MMXU5, MMXU6, MMXU7
148	GPS synchronization		No effect
149	Charging current compensation		No effect
160	Line sections for fault locator		No effect

2.2.5 Function parameters SIPROTEC 7SD610

The following table shows which Logical Nodes are available when setting the corresponding function parameter.

The setting (-) implies that no corresponding LN is available.

Table 2-4 SIPROTEC 7SD610 - Effects of Function parameters to the Logical Nodes

No.	Funktion	Setting	Logical Nodes
103	Setting Group Change Option		No effect
	Disturbance Recorder	-	RDRE1
110	Trip mode	3pole only	XCBR1
		1-/3pole	XCBR2, XCBR3, XCBR4
112	Differential protection	Disabled	-
		Enabled	PDIF1, PDIF2, PTRC3
122	DTT Direct Transfer Trip		No effect
124	Instantaneous HighSpeed SOTF Overcurrent		No effect
126	Backup overcurrent	Disabled	-
		TOC IEC	PTOC1 – PTOC4, PTOC9, PTOC10
		TOC ANSI	PTOC1 – PTOC4, PTOC9, PTOC10

Table 2-4 SIPROTEC 7SD610 - Effects of Function parameters to the Logical Nodes (Cont.)

No.	Funktion	Setting	Logical Nodes
133	Auto-Reclose Function	Disabled	-
		1 AR-cycle	RREC1
		2 AR-cycles	RREC1
		3 AR-cycles	RREC1
		4 AR-cycles	RREC1
		5 AR-cycles	RREC1
		6 AR-cycles	RREC1
		7 AR-cycles	RREC1
		8 AR-cycles	RREC1
		ADT	RREC1
134	Auto-Reclose control mode		No effect
136	Over / Underfrequency Protection	Disabled	-
		Enabled	PTOF1 – PTOF4, PTUF1 – PTUF4
137	Under / Overvoltage Protection	Disabled	-
		Enabled	PTUV1 – PTUV6, PTOV1 – PTOV10
		Enabl. w. comp.	PTUV1 –PTUV6, PTOV1 – PTOV10
139	Breaker Failure Protection	Disabled	-
		Enabled	RBRF1
		enabled w/ 3I0>	RBRF1

Table 2-4 SIPROTEC 7SD610 - Effects of Function parameters to the Logical Nodes (Cont.)

No.	Funktion	Setting	Logical Nodes
140	Trip Circuit Supervision	Disabled	-
		1 Trip Circuit	XCBR1.CirSpv - XCBR4.CirSpv
		2 Trip Circuits	XCBR1.CirSpv - XCBR4.CirSpv
		3 Trip Circuits	XCBR1.CirSpv - XCBR4.CirSpv
141	Restricted earth fault protection	Disabled	-
		Enabled	PDIF3
142	Thermal overload protection	Disabled	-
		Enabled	PTTR1
143	Transformer inside protection zone		No effect
144	Voltage transformers		No effect
148	GPS synchronization		No effect
-	Protection Interface (Port D)		MMXU2, MMXU3

2.2.6 Function parameters SIPROTEC 7VK61

The following table shows which Logical Nodes are available when setting the corresponding function parameter.

The setting (-) implies that no corresponding LN is available.

Table 2-5 SIPROTEC 7VK61 - Effects of Function parameters to the Logical Nodes

No.	Funktion	Setting	Logical Nodes
103	Setting Group Change Option		No effect
	Disturbance Recorder	-	RDRE1
106	Voltage transformer connection	3phase	-
		1phase	-
		No	LN RSYN1, PTUV1 - PTUV6, PTOV1 - PTOV10 not available
107	Current transformer connection	Yes	
		No	LN PTOC1 - PTOC4 not available
110	Trip mode	3pole only	XCBR1
		1-/3pole	XCBR2, XCBR3, XCBR4
126	Backup overcurrent	Disabled	-
		TOC IEC	PTOC1 – PTOC3
		TOC IEC /w 3ST	PTOC1 - PTOC4
		TOC ANSI	PTOC1 - PTOC4

Table 2-5 SIPROTEC 7VK61 - Effects of Function parameters to the Logical Nodes (Cont.)

No.	Funktion	Setting	Logical Nodes
133	Auto-Reclose Function	Disabled	-
		1 AR-cycle	RREC1
		2 AR-cycles	RREC1
		3 AR-cycles	RREC1
		4 AR-cycles	RREC1
		5 AR-cycles	RREC1
		6 AR-cycles	RREC1
		7 AR-cycles	RREC1
		8 AR-cycles	RREC1
		ADT	RREC1
134	Auto-Reclose control mode		No effect
135	Synchronism and Voltage Check	Disabled	-
		Enabled	RSYN1
137	Under / Overvoltage Protection	Disabled	-
		Enabled	PTUV1 – PTUV6, PTOV1 – PTOV10
139	Breaker Failure Protection	Disabled	-
		Enabled	RBRF1
		enabled w/ 3I0>	RBRF1
140	Trip Circuit Supervision	Disabled	-
		1 Trip Circuit	XCBR1.CirSpv - XCBR4.CirSpv
		2 Trip Circuits	XCBR1.CirSpv - XCBR4.CirSpv
		3 Trip Circuits	XCBR1.CirSpv - XCBR4.CirSpv

2.3 Allocation of Logical Nodes to Logical Devices

All Logical Nodes (LN) are allocated to Logical Devices (LD). The following tables show this allocation and the DOIs available for each LN.

LD PROT

The Logical Device PROT (protection) contains the following LNs:

Table 2-6 LD PROT - Logical Nodes

LN	Function	DOI
LLN0	General	Mod, Beh, Health, NamPlt
PTRC1	General device pickup Total OFF	Mod, Beh, Health, NamPlt, Str,Tr,FinTr
PDIF1 PDIF2	Differential protection	Mod, Beh, Health, NamPlt, Str, Op
PTRC3	Differential protection General messages	Mod, Beh, Health, NamPlt, Str, Op StrA, StrAG, StrB, StrBG, StrC, StrCG, StrAB, StrBC, StrCA, StrABC, StrABG, StrBCG, StrCAG, StrABCG
PDIF3	Earth fault overcurrent	Mod, Beh, Health, NamPlt, Str, Op, DifAClc, RstA
PDIS1 PDIS10	Distance protection zone 1, zone 1B	Mod, Beh, Health, NamPlt, Str, Op StrAG, StrBG, StrCG, StrAB, StrBC, StrCA
PDIS2 PDIS3 PDIS4 PDIS5	Distance protection zone 2, zone3, zone 4, zone 5	Mod, Beh, Health, NamPlt, Str, Op
PTRC2	Distance protection General messages	Mod, Beh, Health, NamPlt, Str, Op
PSCH1	Distance protection Teleprotection	Mod, Beh, Health, NamPlt, Str, Op, CarRx, ProRx, LosOfGrd, Echo, WeiOp, RvABlk, GrdRx, ProTx
RPSB1 RPSB2 RPSB3 RPSB4 RPSB5 RPSB1	Power Swing detection zone1, zone 2, zone3, zone 4, zone 5, zone 1B	Mod, Beh, Health, NamPlt, Str, BlkZn
RPSB6	Power Swing detection Power Swing trip	Mod, Beh, Health, NamPlt, Op

Table 2-6 LD PROT - Logical Nodes (Cont.)

LN	Function	DOI
PTOC5 PTOC6 PTOC7 PTOC8	Earth fault overcurrent	Mod, Beh, Health, NamPlt, Str, Op
PTOC1 PTOC2 PTOC3 PTOC4	Backup overcurrent	Mod, Beh, Health, NamPlt, Str, Op
PTOC9 PTOC10	Backup overcurrent directional	Mod, Beh, Health, NamPlt, Str, Op
RSYN1	Synchronism and Voltage Check	Mod, Beh, Health, NamPlt, Rel, VInd, AngInd, HzInd, SynPrg, DifVClc, DifHzClc, DifAngClc
PTUV1 PTUV2 PTUV3 PTUV4 PTUV5 PTUV6	Undervoltage Protection	Mod, Beh, Health, NamPlt, Str, Op
PTOV1 PTOV2 PTOV3 PTOV4 PTOV5 PTOV6 PTOV7 PTOV8 PTOV9 PTOV10	Overvoltage Protection	Mod, Beh, Health, NamPlt, Str, Op
PTUF1 PTUF2 PTUF3 PTUF4	Underfrequency Protection	Mod, Beh, Health, NamPlt, Str, Op
PTOF1 PTOF2 PTOF3 PTOF4	Overfrequency Protection	Mod, Beh, Health, NamPlt, Str, Op
RFLO1	Fault Locator	Mod, Beh, Health, NamPlt, FltZ, FltDiskm
RBRF1	Breaker Failure Protection	Mod, Beh, Health, NamPlt, Str, OpEx, OpIn
PTTR1	Thermal overload protection	Mod, Beh, Health, NamPlt, Str, Op, AlmThm

Table 2-6 LD PROT - Logical Nodes (Cont.)

LN	Function	DOI
XCBR1	Three-pole tripping	Mod, Beh, Health, NamPlt, Loc, OpCnt, Pos BlkOpn, BlkCls, CBOpCap SumSwARs1, SumSwARs2, SumSwARs3
XCBR2 XCBR3 XCBR4	Single-pole / Three-pole tripping	Mod, Beh, Health, NamPlt, Loc, OpCnt, Pos BlkOpn, BlkCls, CBOpCap, SumSwARs
LPHD1	Device	PhyNam, PhyHealth, Proxy
only SIPROTEC 7VK61		
RREC1	Auto-Reclose Function	Mod, Beh, Health, NamPlt, Op, AutoRecSt

LD MEAS

The Logical Device MEAS (measurement) contains the following LNs:

Table 2-7 LD MEAS - Logical Nodes

LN	Function	DOIs
LLN0	General	Mod, Beh, Health, NamPlt
MMXU1	Operational measured values	Mod, Beh, Health, NamPlt, TotW, TotVAr, TotVA, TotPF, Hz, PPV, PhV, A
MMXU2	Measure relay 1	Mod, Beh, Health, NamPlt, RelId, A, PhV,
MMXU3	Measure relay 2	Mod, Beh, Health, NamPlt, RelId, A, PhV,
MMXU4	Measure relay 3	Mod, Beh, Health, NamPlt, RelId, A, PhV,
MMXU5	Measure relay 4	Mod, Beh, Health, NamPlt, RelId, A, PhV,
MMXU6	Measure relay 5	Mod, Beh, Health, NamPlt, RelId, A, PhV,
MMXU7	Measure relay 6	Mod, Beh, Health, NamPlt, RelId, A, PhV,
MMTR1	Energy	Mod, Beh, Health, NamPlt, SupWh, SupVArh, DmdWh, DmdVArh
MSQI1	Measured values, symmetrical components	Mod, Beh, Health, NamPlt, SeqA, SeqV
LPHD1	Device	PhyNam, PhyHealth Proxy, CtrlNum, DevStr

LD DR

The Logical Device DR (Disturbance Recorder) contains the following LNs:

Table 2-8 LD DR - Logical Nodes

LN	Function	DOIs
LLN0	General	Mod, Beh, Health, NamPlt
RDRE1	Fault Record	Mod, Beh, Health, NamPlt, RcdMade, FltNum, GriFltNum, RcdStr
LPHD1	Device	PhyNam, PhyHealth, Proxy

LD CTRL

The Logical Device CTRL (Control) contains the following LNs:

Table 2-9 LD CTRL - Logical Nodes

LN	Function	DOIs
LLN0	General	Mod, Beh, Health, NamPlt, LEDRs, Loc
RREC1*	Auto-Reclose Function	Mod, Beh, Health, NamPlt, Op, AutoRecSt
CALH1	Alarms, warning messages and group alarms	Mod, Beh, Health, NamPlt, GrAlm, GrWrn, ErrBoard1, ErrBoard2, ErrBoard3, ErrBoard4, ErrBoard5, ErrBoard6, ErrBoard7
LPHD1	Device	PhyNam, PhyHealth, Proxy

* **SIPROTEC 7VK61**: RREC1 Part of Logical Device Protection (see Table 2-6)

The Logical Nodes of the switching (and userdefined) objects will be created by DIGSI during the parameterization of your SIPROTEC device.

MICS, Model Implementation Conformance Statement, shows the assignment of the DOIs; you can use DIGSI to print the MICS.

LD EXT

The Logical Device EXT (Extended) contains the following LNs:

Table 2-10 LD EXT - Logical Nodes

LN	Function	DOIs
LLN0	General	Mod, Beh, Health, NamPlt
LPHD1	Device	PhyNam, PhyHealth, Proxy

2.4 Logical Node LLN0

2.4.1 Logical Device PROT

LLN0.Mod

No.	Information						
52	At Least 1 Protection Funct. is Active (ProtActive)	0	0	1	1	1	1
	Test mode (Test mode)	0	x	0	1	0	1
	Stop data transmission (DataStop)	0	x	1	0	0	1
LLN0.Mod.stVal		5	5	2	3	1	4

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
 0 - OFF / FALSE 2 - BLOCKED
 x - irrelevant 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

LLN0.Beh

No.	Information						
52	At Least 1 Protection Funct. is Active (ProtActive)	0	1	1	1	1	1
	Test mode (Test mode)	x	0	0	1	1	1
	Stop data transmission (DataStop)	x	0	1	0	1	1
LLN0.Beh.stVal		5	1	2	3	4	4

device annunciation / setting: 1 - ON / TRUE IEC Status Beh.stVal: 1 - ON
 0 - OFF / FALSE 2 - BLOCKED
 x - irrelevant 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

2.5 The DOI Behavior

2.5.1 Logical Device PROT

For the Logical Nodes of the PROT Logical Device, **LNx.Beh.stVal** is formed from **LNx.Mod.stVal** of the Logical Node and the status of the following device messages:

- Test mode (Test mode),
- Stop data transmission and
- At Least 1 Protection Funct. is Active.

No.	Information								
52	At Least 1 Protection Funct. is Active (ProtActive)	x	1	1	1	1	1	1	0
	Test mode (Test mode)	x	0	1	0	1	0	1	x
	Stop data transmission (DataStop)	x	0	0	1	1	x	x	x
	LNx .Mod.stVal	5	1	1	1	1	2	2	x
LNx.Beh.stVal		5	1	3	2	4	2	4	5

device annunciation / setting: 1 - ON / TRUE
 0 - OFF / FALSE
 x - irrelevant

IEC Status stVal:

1 - ON
 2 - BLOCKED
 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

2.5.2 Logical Devices MEAS, CTRL, DR and EXT

For the Logical Nodes of the MEAS, CTRL, DR and EXT Logical Devices, **LNx.Beh.stVal** is formed from **LNx.Mod.stVal** of the Logical Node and the status of the following device messages:

- Test mode (Test mode),
- Stop data transmission.

No.	Information								
	Test mode (Test mode)	x	0	1	0	1	0	1	
	Stop data transmission (DataStop)	x	0	0	1	1	x	x	
	LNx .Mod.stVal	5	1	1	1	1	2	2	
LNx.Beh.stVal		5	1	3	2	4	2	4	

device annunciation / setting: 1 - ON / TRUE
 0 - OFF / FALSE
 x - irrelevant

IEC Status stVal:

1 - ON
 2 - BLOCKED
 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

Mapping

Contents

This chapter shows the mapping of the information relevant to the device on the Logical Node of protocol IEC61850. It is structured according to function. In Chapter 2 you can find the available functions of the different devices and what consequences non-configured functions have on the Logical Nodes. You find also general information about IEC 61850 mapping of information.

3.1	Differential Protection (PDIFx, PTRCx)	64
3.2	Distance Protection (PDISx, PTRC2)	74
3.3	Power swing detection (RPSBx)	103
3.4	Teleprotection for distance protection (PSCH1)	116
3.5	Earth fault overcurrent protection in earthed systems (PTOCx)	123
3.6	Earth fault detection in non-earthed systems (PSDE1)	131
3.7	Restricted earth fault protection (PDIF3)	135
3.8	Overcurrent protection (PTOCx)	137
3.9	Automatic reclosure function (RREC1)	147
3.10	Synchronism and voltage check (RSYN1)	149
3.11	Under and overvoltage protection (PTUVx, PTOVx)	152
3.12	Frequency protection (PTUFx, PTOFx)	176
3.13	Fault locator (RFLO1)	192
3.14	Circuit breaker failure protection (RBRF1)	194
3.15	Thermal overload protection (PTTR1)	196
3.16	Single-pole / threepole tripping Circuit Breaker (XCBRx)	198
3.17	Tripping Logic of the Entire Device (PTRC1)	208
3.18	Device (LPHD1, CALH1)	212
3.19	Measurements (MMXUx, MSQI1, MMTR1)	216
3.20	Oscillographic Fault Records (RDRE1)	242

3.1 Differential Protection (PDIFx, PTRCx)

3.1.1 I-DIFF> (PDIF1)

PDIF1.Mod

No.	Information							
3120	Diff: Active (Diff active)	x	0	0	1	1	1	1
3148	Diff: Differential protection is blocked (Diff block)	x	1	0	0	0	0	0
3149	Diff: Diff. protection is switched off (Diff OFF)	1	0	0	0	0	0	0
3190	Diff: Set Teststate of Diff. protection (Test Diff.)	x	x	x	0	1	0	1
3191	Diff: Set Commissioning state of Diff. (Comm. Diff)	x	x	x	0	0	1	1
PDIF1.Mod.stVal		5	2	5	1	3	4	4

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
 0 - OFF / FALSE 2 - BLOCKED
 x - irrelevant 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

PDIF1.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PDIF1.Health.stVal		3	1

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
 0 - OFF 2 - WARNING
 3 - ALARM

PDIF1.Str

No.	Information		
3139	Diff: Fault detection of I-Diff> (I-Diff> Flt.)	0	1
PDIF1.Str.general		0	1

device annunciation: 1 - ON IEC Status Str.general: 0 - FALSE
 0 - OFF 1 - TRUE

PDIF1.Op

No.	Information		
	OFF-command IDiff>	0	1
PDIF1.Op.general		0	1

device annunciation: 1 - ON IEC Status Op.general: 0 - FALSE
 0 - OFF 1 - TRUE

3.1.2 I-DIFF>> (PDIF2)

PDIF2.Mod

No.	Information							
3120	Diff: Active (Diff active)	x	0	0	1	1	1	1
3148	Diff: Differential protection is blocked (Diff block)	x	1	0	0	0	0	0
3149	Diff: Diff. protection is switched off (Diff OFF)	1	0	0	0	0	0	0
3190	Diff: Set Teststate of Diff. protection (Test Diff.)	x	x	x	0	1	0	1
3191	Diff: Set Commissioning state of Diff. (Comm. Diff)	x	x	x	0	0	1	1
PDIF2.Mod.stVal		5	2	5	1	3	4	4

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
 0 - OFF / FALSE 2 - BLOCKED
 x - irrelevant 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

PDIF2.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PDIF2.Health.stVal		3	1

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
 0 - OFF 2 - WARNING
 3 - ALARM

3.1 Differential Protection (PDIFx, PTRCx)

PDIF2.Str

No.	Information		
3137	Diff: Fault detection of I-Diff>> (I-Diff>> Flt.)	0	1
PDIF2.Str.general		0	1

device annunciation: 1 - ON IEC Status Str.general: 0 - FALSE
 0 - OFF 1 - TRUE

PDIF2.Op

No.	Information		
	OFF-command I-Diff>>	0	1
PDIF2.Op.general		0	1

device annunciation: 1 - ON IEC Status Op.general: 0 - FALSE
 0 - OFF 1 - TRUE

3.1.3 Differential Protection General Information

PTRC3.Mod

No.	Information							
3120	Diff: Active (Diff active)	x	0	0	1	1	1	1
3148	Diff: Differential protection is blocked (Diff block)	x	1	0	0	0	0	0
3149	Diff: Diff. protection is switched off (Diff OFF)	1	0	0	0	0	0	0
3190	Diff: Set Teststate of Diff. protection (Test Diff.)	x	0	0	0	1	0	1
3191	Diff: Set Commissioning state of Diff. (Comm. Diff)	x	0	0	0	0	1	1
PTRC3.Mod.stVal		5	2	5	1	3	4	4

device annunciation / setting: 1 - ON / TRUE
0 - OFF / FALSE
x - irrelevant

IEC Status Mod.stVal: 1 - ON
2 - BLOCKED
3 - TEST
4 - TEST/BLOCKED
5 - OFF

PTRC3.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTRC3.Health.stVal		3	1

device annunciation: 1 - ON
0 - OFF

IEC Status Health.stVal: 1 - OK
2 - WARNING
3 - ALARM

PTRC3.Str

No.	Information		
3132	Diff: Fault detection (Diff. Gen. Flt.)	0	1
PTRC3.Str.general		0	1

device annunciation: 1 - ON
0 - OFF

IEC Status Str.general: 0 - FALSE
1 - TRUE

PTRC3.Str.dirGeneral

No.	Information	
PTRC3.Str.dirGeneral		1

device annunciation: 1 - ON IEC Status Str.dirGeneral: 0 - UNKNOWN
 0 - OFF 1 - FORWARD
 x - irrelevant 2 - BACKWARD
 3 - BOTH

PTRC3.Str.phsA

No.	Information		
3133	Diff: Fault detection in phase L1 (Diff. Flt. L1)	0	1
PTRC3.Str.phsA		0	1

device annunciation: 1 - ON IEC Status Str.phsA: 0 - FALSE
 0 - OFF 1 - TRUE

PTRC3.Str.dirPhsA

No.	Information	
PTRC3.Str.dirPhsA		1

device annunciation: 1 - ON IEC Status Str.dirPhsA: 0 - UNKNOWN
 0 - OFF 1 - FORWARD
 x - irrelevant 2 - BACKWARD
 3 - BOTH

PTRC3.Str.phsB

No.	Information		
3134	Diff: Fault detection in phase L2 (Diff. Flt. L2)	0	1
PTRC3.Str.phsB		0	1

device annunciation: 1 - ON IEC Status Str.phsB: 0 - FALSE
 0 - OFF 1 - TRUE

PTRC3.Str.dirPhsB

No.	Information	
PTRC3.Str.dirPhsB		1

device annunciation: 1 - ON IEC Status Str.dirPhsB: 0 - UNKNOWN
 0 - OFF 1 - FORWARD
 x - irrelevant 2 - BACKWARD
 3 - BOTH

PTRC3.Str.phsC

No.	Information		
3135	Diff: Fault detection in phase L3 (Diff. Flt. L3)	0	1
PTRC3.Str.phsC		0	1

device annunciation: 1 - ON IEC Status Str.phsC: 0 - FALSE
0 - OFF 1 - TRUE

PTRC3.Str.dirPhsC

No.	Information		
PTRC3.Str.dirPhsC		1	

device annunciation: 1 - ON IEC Status Str.dirPhsC: 0 - UNKNOWN
0 - OFF 1 - FORWARD
x - irrelevant 2 - BACKWARD
3 - BOTH

PTRC3.Str.neut

No.	Information		
3136	Diff: Earth fault detection (Diff. Flt. E)	0	1
PTRC3.Str.neut		0	1

device annunciation: 1 - ON IEC Status Str.neut: 0 - FALSE
0 - OFF 1 - TRUE

PTRC3.Str.dirNeut

No.	Information		
PTRC3.Str.dirNeut		1	

device annunciation: 1 - ON IEC Status Str.dirNeut: 0 - UNKNOWN
0 - OFF 1 - FORWARD
x - irrelevant 2 - BACKWARD
3 - BOTH

PTRC3.Op

No.	Information		
3141	Diff: General TRIP (Diff. Gen. TRIP)	0	1
PTRC3.Op.general		0	1

device annunciation: 1 - ON IEC Status Op.general: 0 - FALSE
0 - OFF 1 - TRUE

PTRC3.Op.phsA

No.	Information			
3142	Diff: TRIP - Only L1 (Diff TRIP 1p L1)	1	0	0
3145	Diff: TRIP L123 (Diff TRIP L123)	0	1	0
PTRC3.Op.phsA		1	1	0

device annunciation: 1 - ON IEC Status Op.phsA: 0 - FALSE
0 - OFF 1 - TRUE

PTRC3.Op.phsB

No.	Information			
3143	Diff: TRIP - Only L2 (Diff TRIP 1p L2)	1	0	0
3145	Diff: TRIP L123 (Diff TRIP L123)	0	1	0
PTRC3.Op.phsB		1	1	0

device annunciation: 1 - ON IEC Status Op.phsB: 0 - FALSE
0 - OFF 1 - TRUE

PTRC3.Op.phsC

No.	Information			
3144	Diff: TRIP - Only L3 (Diff TRIP 1p L3)	1	0	0
3145	Diff: TRIP L123 (Diff TRIP L123)	0	1	0
PTRC3.Op.phsC		1	1	0

device annunciation: 1 - ON IEC Status Op.phsC: 0 - FALSE
0 - OFF 1 - TRUE

PTRC3.StrA

No.	Information		
3176	Diff: Fault detection L1 (only) (Diff Flt. 1p.L1)	1	0
PTRC3.StrA.stVal		1	0

device annunciation: 1 - ON IEC Status StrA.stVal: 0 - FALSE
0 - OFF 1 - TRUE

PTRC3.StrAG

No.	Information		
3177	Diff: Fault detection L1E (Diff Flt. L1E)	1	0
PTRC3.StrAG.stVal		1	0

device annunciation: 1 - ON IEC Status StrAG.stVal: 0 - FALSE
0 - OFF 1 - TRUE

PTRC3.StrB

No.	Information		
3178	Diff: Fault detection L2 (only) (Diff Flt. 1p.L2)	1	0
PTRC3.StrB.stVal		1	0

device annunciation: 1 - ON IEC Status StrB.stVal: 0 - FALSE
0 - OFF 1 - TRUE

PTRC3.StrBG

No.	Information		
3179	Diff: Fault detection L2E (Diff Flt. L2E)	1	0
PTRC3.StrBG.stVal		1	0

device annunciation: 1 - ON IEC Status StrBG.stVal: 0 - FALSE
0 - OFF 1 - TRUE

PTRC3.StrC

No.	Information		
3182	Diff: Fault detection L3 (only) (Diff Flt. 1p.L3)	1	0
PTRC3.StrC.stVal		1	0

device annunciation: 1 - ON IEC Status StrC.stVal: 0 - FALSE
0 - OFF 1 - TRUE

PTRC3.StrCG

No.	Information		
3183	Diff: Fault detection L3E (Diff Flt. L3E)	1	0
PTRC3.StrCG.stVal		1	0

device annunciation: 1 - ON IEC Status StrCG.stVal: 0 - FALSE
0 - OFF 1 - TRUE

3.1 Differential Protection (PDIFx, PTRCx)

PTRC3.StrAB

No.	Information		
3180	Diff: Fault detection L12 (Diff Fit. L12)	1	0
PTRC3.StrAB.stVal		1	0

device annunciation: 1 - ON IEC Status StrAB.stVal: 0 - FALSE
 0 - OFF 1 - TRUE

PTRC3.StrBC

No.	Information		
3186	Diff: Fault detection L23 (Diff Fit. L23)	1	0
PTRC3.StrBC.stVal		1	0

device annunciation: 1 - ON IEC Status StrBC.stVal: 0 - FALSE
 0 - OFF 1 - TRUE

PTRC3.StrCA

No.	Information		
3184	Diff: Fault detection L31 (Diff Fit. L31)	1	0
PTRC3.StrCA.stVal		1	0

device annunciation: 1 - ON IEC Status StrCA.stVal: 0 - FALSE
 0 - OFF 1 - TRUE

PTRC3.StrABC

No.	Information		
3188	Diff: Fault detection L123 (Diff Fit. L123)	1	0
PTRC3.StrABC.stVal		1	0

device annunciation: 1 - ON IEC Status StrABC.stVal: 0 - FALSE
 0 - OFF 1 - TRUE

PTRC3.StrABG

No.	Information		
3181	Diff: Fault detection L12E (Diff Flt. L12E)	1	0
PTRC3.StrABG.stVal		1	0

device annunciation: 1 - ON IEC Status StrABG.stVal: 0 - FALSE
 0 - OFF 1 - TRUE

PTRC3.StrBCG

No.	Information		
3187	Diff: Fault detection L23E (Diff Flt. L23E)	1	0
PTRC3.StrBCG.stVal		1	0

device annunciation: 1 - ON IEC Status StrBCG.stVal: 0 - FALSE
 0 - OFF 1 - TRUE

PTRC3.StrCAG

No.	Information		
3185	Diff: Fault detection L31E (Diff Flt. L31E)	1	0
PTRC3.StrCAG.stVal		1	0

device annunciation: 1 - ON IEC Status StrCAG.stVal: 0 - FALSE
 0 - OFF 1 - TRUE

PTRC3.StrABCG

No.	Information		
3189	Diff: Fault detection L123E (Diff Flt. L123E)	1	0
PTRC3.StrABCG.stVal		1	0

device annunciation: 1 - ON IEC Status StrABCG.stVal: 0 - FALSE
 0 - OFF 1 - TRUE

3.2 Distance Protection (PDISx, PTRC2)

3.2.1 Distance protection zone 1 (PDIS1)

PDIS1.Mod

No.	Information								
3653	Distance is ACTIVE (Dist. ACTIVE)	0	x	x	x	1	1	1	1
3652	Distance is BLOCKED (Dist. BLOCK)	x	x	x	0	0	1	1	
3603	>BLOCK 21 Distance (>BLOCK 21 Dist.)	x	x	x	0	1	0	1	
3651	Distance is switched off (Dist. OFF)	x	1	x	0	0	0	0	
	Op. mode Z1 (P1301) = Inactive	x	x	1	0	0	0	0	
PDIS1.Mod.stVal		5	5	5	1	2	2	2	

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
 0 - OFF / FALSE 2 - BLOCKED
 x - irrelevant 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

PDIS1.Health

No.	Information				
51	Device is Operational and Protecting (Device OK)	1	1	0	0
3654	Setting error K0(Z1) or Angle K0(Z1) (Dis.ErrorK0(Z1))	1	0	1	0
PDIS1.Health.stVal		2	1	3	3

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
 0 - OFF 2 - WARNING
 3 - ALARM

PDIS1.Str

No.	Information							
3741	Distance Pickup Z1, Loop L1E (Dis. Z1 L1E)	0	1	x	x	x	x	x
3742	Distance Pickup Z1, Loop L2E (Dis. Z1 L2E)	0	x	1	x	x	x	x
3743	Distance Pickup Z1, Loop L3E (Dis. Z1 L3E)	0	x	x	1	x	x	x
3744	Distance Pickup Z1, Loop L12 (Dis. Z1 L12)	0	x	x	x	1	x	x
3745	Distance Pickup Z1, Loop L23 (Dis. Z1 L23)	0	x	x	x	x	1	x
3746	Distance Pickup Z1, Loop L31 (Dis. Z1 L31)	0	x	x	x	x	x	1
PDIS1.Str.general		0	1	1	1	1	1	1

device annunciation:

1 - ON

0 - OFF

x - irrelevant

IEC Status Str.general:

0 - FALSE

1 - TRUE

PDIS1.Str.dirGeneral

No.	Information														
3719	Distance Pickup FORWARD (Dis. forward)	0	0	0	0	0	0	0	0	0	0	0	0	0	
3720	Distance Pickup REVERSE (Dis. reverse)	0	0	0	0	0	0	0	1	1	1	1	1	1	
3741	Distance Pickup Z1, Loop L1E (Dis. Z1 L1E)	0	1	x	x	x	x	x	0	1	x	x	x	x	
3742	Distance Pickup Z1, Loop L2E (Dis. Z1 L2E)	0	x	1	x	x	x	x	0	x	1	x	x	x	
3743	Distance Pickup Z1, Loop L3E (Dis. Z1 L3E)	0	x	x	1	x	x	x	0	x	x	1	x	x	
3744	Distance Pickup Z1, Loop L12 (Dis. Z1 L12)	0	x	x	x	1	x	x	0	x	x	x	1	x	
3745	Distance Pickup Z1, Loop L23 (Dis. Z1 L23)	0	x	x	x	x	1	x	0	x	x	x	x	1	
3746	Distance Pickup Z1, Loop L31 (Dis. Z1 L31)	0	x	x	x	x	x	1	0	x	x	x	x	1	
PDIS1.Str.dirGeneral		0	0	0	0	0	0	0	0	2	2	2	2	2	

No.	Information														
3719	Distance Pickup FORWARD (Dis. forward)	1	1	1	1	1	1	1	1	1	1	1	1	1	
3720	Distance Pickup REVERSE (Dis. reverse)	0	0	0	0	0	0	0	1	1	1	1	1	1	
3741	Distance Pickup Z1, Loop L1E (Dis. Z1 L1E)	0	1	x	x	x	x	x	0	1	x	x	x	x	
3742	Distance Pickup Z1, Loop L2E (Dis. Z1 L2E)	0	x	1	x	x	x	x	0	x	1	x	x	x	
3743	Distance Pickup Z1, Loop L3E (Dis. Z1 L3E)	0	x	x	1	x	x	x	0	x	x	1	x	x	
3744	Distance Pickup Z1, Loop L12 (Dis. Z1 L12)	0	x	x	x	1	x	x	0	x	x	x	1	x	
3745	Distance Pickup Z1, Loop L23 (Dis. Z1 L23)	0	x	x	x	x	1	x	0	x	x	x	x	1	
3746	Distance Pickup Z1, Loop L31 (Dis. Z1 L31)	0	x	x	x	x	x	1	0	x	x	x	x	1	
PDIS1.Str.dirGeneral		0	1	1	1	1	1	1	0	3	3	3	3	3	

device annunciation:
1 - ON
0 - OFF
x - irrelevant

IEC Status Str.dirGeneral:
0 - UNKNOWN
1 - FORWARD
2 - BACKWARD
3 - BOTH

PDIS1.Op

No.	Information				
3811	Distance TRIP single-phase Z1 (Dis.TripZ1/1p)	0	1	x	x
3823	DisTRIP 3phase in Z1 with single-ph Flt. (DisTRIP3p. Z1sf)	0	x	1	x
3824	DisTRIP 3phase in Z1 with multi-ph Flt. (DisTRIP3p. Z1mf)	0	x	x	1
PDIS1.Op.general		0	1	1	1

device annunciation: 1 - ON IEC Status Op.general: 0 - FALSE
0 - OFF 1 - TRUE
x - irrelevant

PDIS1.Op.phsA

No.	Information					
3811	Distance TRIP single-phase Z1 (Dis.TripZ1/1p)	x	0	1	0	0
3823	DisTRIP 3phase in Z1 with single-ph Flt. (DisTRIP3p. Z1sf)	x	0	0	1	0
3824	DisTRIP 3phase in Z1 with multi-ph Flt. (DisTRIP3p. Z1mf)	x	0	0	0	1
3802	Distance TRIP command - Only Phase L1 (Dis.Trip 1pL1)	0	x	1	0	0
3805	Distance TRIP command Phases L123 (Dis.Trip 3p)	0	x	0	1	1
PDIS1.Op.phsA		0	0	1	1	1

device annunciation: 1 - ON IEC Status Op.phsA: 0 - FALSE
0 - OFF 1 - TRUE
x - irrelevant

PDIS1.Op.phsB

No.	Information					
3811	Distance TRIP single-phase Z1 (Dis.TripZ1/1p)	x	0	1	0	0
3823	DisTRIP 3phase in Z1 with single-ph Flt. (DisTRIP3p. Z1sf)	x	0	0	1	0
3824	DisTRIP 3phase in Z1 with multi-ph Flt. (DisTRIP3p. Z1mf)	x	0	0	0	1
3803	Distance TRIP command - Only Phase L2 (Dis.Trip 1pL2)	0	x	1	0	0
3805	Distance TRIP command Phases L123 (Dis.Trip 3p)	0	x	0	1	1
PDIS1.Op.phsB		0	0	1	1	1

device annunciation: 1 - ON IEC Status Op.phsB: 0 - FALSE
0 - OFF 1 - TRUE
x - irrelevant

PDIS1.Op.phsC

No.	Information					
3811	Distance TRIP single-phase Z1 (Dis.TripZ1/1p)	x	0	1	0	0
3823	DisTRIP 3phase in Z1 with single-ph Flt. (DisTRIP3p. Z1sf)	x	0	0	1	0
3824	DisTRIP 3phase in Z1 with multi-ph Flt. (DisTRIP3p. Z1mf)	x	0	0	0	1
3804	Distance TRIP command - Only Phase L3 (Dis.Trip 1pL3)	0	x	1	0	0
3805	Distance TRIP command Phases L123 (Dis.Trip 3p)	0	x	0	1	1
PDIS1.Op.phsC		0	0	1	1	1

device annunciation: 1 - ON IEC Status Op.phsC: 0 - FALSE
0 - OFF 1 - TRUE
x - irrelevant

PDIS1.StrAG

No.	Information		
3741	Distance Pickup Z1, Loop L1E (Dis. Z1 L1E)	0	1
PDIS1.StrAG.stVal		0	1

device annunciation: 1 - ON IEC Status StrAG.stVal: 0 - FALSE
0 - OFF 1 - TRUE

PDIS1.StrBG

No.	Information		
3742	Distance Pickup Z1, Loop L2E (Dis. Z1 L2E)	0	1
PDIS1.StrBG.stVal		0	1

device annunciation: 1 - ON IEC Status StrBG.stVal: 0 - FALSE
0 - OFF 1 - TRUE

PDIS1.StrCG

No.	Information		
3743	Distance Pickup Z1, Loop L3E (Dis. Z1 L3E)	0	1
PDIS1.StrCG.stVal		0	1

device annunciation: 1 - ON IEC Status StrCG.stVal: 0 - FALSE
0 - OFF 1 - TRUE

PDIS1.StrAB

No.	Information		
3744	Distance Pickup Z1, Loop L12 (Dis. Z1 L12)	0	1
PDIS1.StrAB.stVal		0	1

device annunciation: 1 - ON IEC Status StrAB.stVal: 0 - FALSE
 0 - OFF 1 - TRUE

PDIS1.StrBC

No.	Information		
3745	Distance Pickup Z1, Loop L23 (Dis. Z1 L23)	0	1
PDIS1.StrBC.stVal		0	1

device annunciation: 1 - ON IEC Status StrBC.stVal: 0 - FALSE
 0 - OFF 1 - TRUE

PDIS1.StrCA

No.	Information		
3746	Distance Pickup Z1, Loop L31 (Dis. Z1 L31)	0	1
PDIS1.StrCA.stVal		0	1

device annunciation: 1 - ON IEC Status StrCA.stVal: 0 - FALSE
 0 - OFF 1 - TRUE

3.2.2 Distance protection zone 1B (PDIS10)

PDIS10.Mod

No.	Information							
3653	Distance is ACTIVE (Dist. ACTIVE)	0	x	x	1	1	1	1
3652	Distance is BLOCKED (Dist. BLOCK)	x	x	x	0	0	1	1
3603	>BLOCK 21 Distance (>BLOCK 21 Dist.)	x	x	x	0	1	0	1
3651	Distance is switched off (Dist. OFF)	x	1	x	0	0	0	0
	Op. mode Z1B (P1351) = Inactive	x	x	1	0	0	0	0
PDIS10.Mod.stVal		5	5	5	1	2	2	2

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
 0 - OFF / FALSE 2 - BLOCKED
 x - irrelevant 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

PDIS10.Health

No.	Information				
51	Device is Operational and Protecting (Device OK)	1	1	0	0
3655	Setting error K0(>Z1) or Angle K0(>Z1) (DisErrorK0(>Z1))	1	0	1	0
PDIS10.Health.stVal		2	1	3	3

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
 0 - OFF 2 - WARNING
 3 - ALARM

PDIS10.Str

No.	Information							
3747	Distance Pickup Z1B, Loop L1E (Dis. Z1B L1E)	0	1	x	x	x	x	x
3748	Distance Pickup Z1B, Loop L2E (Dis. Z1B L2E)	0	x	1	x	x	x	x
3749	Distance Pickup Z1B, Loop L3E (Dis. Z1B L3E)	0	x	x	1	x	x	x
3750	Distance Pickup Z1B, Loop L12 (Dis. Z1B L12)	0	x	x	x	1	x	x
3751	Distance Pickup Z1B, Loop L23 (Dis. Z1B L23)	0	x	x	x	x	1	x
3752	Distance Pickup Z1B, Loop L31 (Dis. Z1B L31)	0	x	x	x	x	x	1
PDIS10.Str.general		0	1	1	1	1	1	1

device annunciation:

1 - ON

0 - OFF

x - irrelevant

IEC Status Str.general:

0 - FALSE

1 - TRUE

PDIS10.Str.dirGeneral

No.	Information														
3719	Distance Pickup FORWARD (Dis. forward)	0	0	0	0	0	0	0	0	0	0	0	0	0	0
3720	Distance Pickup REVERSE (Dis. reverse)	0	0	0	0	0	0	0	1	1	1	1	1	1	1
3747	Distance Pickup Z1B, Loop L1E (Dis. Z1B L1E)	0	1	x	x	x	x	x	0	1	x	x	x	x	x
3748	Distance Pickup Z1B, Loop L2E (Dis. Z1B L2E)	0	x	1	x	x	x	x	0	x	1	x	x	x	x
3749	Distance Pickup Z1B, Loop L3E (Dis. Z1B L3E)	0	x	x	1	x	x	x	0	x	x	1	x	x	x
3750	Distance Pickup Z1B, Loop L12 (Dis. Z1B L12)	0	x	x	x	1	x	x	0	x	x	x	1	x	x
3751	Distance Pickup Z1B, Loop L23 (Dis. Z1B L23)	0	x	x	x	x	1	x	0	x	x	x	x	1	x
3752	Distance Pickup Z1B, Loop L31 (Dis. Z1B L31)	0	x	x	x	x	x	1	0	x	x	x	x	x	1
PDIS10.Str.dirGeneral		0	0	0	0	0	0	0	0	2	2	2	2	2	2

No.	Information														
3719	Distance Pickup FORWARD (Dis. forward)	1	1	1	1	1	1	1	1	1	1	1	1	1	1
3720	Distance Pickup REVERSE (Dis. reverse)	0	0	0	0	0	0	0	1	1	1	1	1	1	1
3747	Distance Pickup Z1B, Loop L1E (Dis. Z1B L1E)	0	1	x	x	x	x	x	0	1	x	x	x	x	x
3748	Distance Pickup Z1B, Loop L2E (Dis. Z1B L2E)	0	x	1	x	x	x	x	0	x	1	x	x	x	x
3749	Distance Pickup Z1B, Loop L3E (Dis. Z1B L3E)	0	x	x	1	x	x	x	0	x	x	1	x	x	x
3750	Distance Pickup Z1B, Loop L12 (Dis. Z1B L12)	0	x	x	x	1	x	x	0	x	x	x	1	x	x
3751	Distance Pickup Z1B, Loop L23 (Dis. Z1B L23)	0	x	x	x	x	1	x	0	x	x	x	x	1	x
3752	Distance Pickup Z1B, Loop L31 (Dis. Z1B L31)	0	x	x	x	x	x	1	0	x	x	x	x	x	1
PDIS10.Str.dirGeneral		0	1	1	1	1	1	1	0	3	3	3	3	3	3

device annunciation:
 1 - ON
 0 - OFF
 x - irrelevant

IEC Status Str.dirGeneral:
 0 - UNKNOWN
 1 - FORWARD
 2 - BACKWARD
 3 - BOTH

PDIS10.Op

No.	Information				
3813	Distance TRIP single-phase Z1B (Dis.TripZ1B1p)	0	1	x	x
3825	DisTRIP 3phase in Z1B with single-ph Flt (DisTRIP3p.Z1Bsf)	0	x	1	x
3826	DisTRIP 3phase in Z1B with multi-ph Flt. (DisTRIP3p Z1Bmf)	0	x	x	1
PDIS10.Op.general		0	1	1	1

device annunciation: 1 - ON IEC Status Op.general: 0 - FALSE
0 - OFF 1 - TRUE
x - irrelevant

PDIS10.Op.phsA

No.	Information					
3813	Distance TRIP single-phase Z1B (Dis.TripZ1B1p)	x	0	1	0	0
3825	DisTRIP 3phase in Z1B with single-ph Flt (DisTRIP3p.Z1Bsf)	x	0	0	1	0
3826	DisTRIP 3phase in Z1B with multi-ph Flt. (DisTRIP3p Z1Bmf)	x	0	0	0	1
3802	Distance TRIP command - Only Phase L1 (Dis.Trip 1pL1)	0	x	1	0	0
3805	Distance TRIP command Phases L123 (Dis.Trip 3p)	0	x	0	1	1
PDIS10.Op.phsA		0	0	1	1	1

device annunciation: 1 - ON IEC Status Op.phsA: 0 - FALSE
0 - OFF 1 - TRUE
x - irrelevant

PDIS10.Op.phsB

No.	Information					
3813	Distance TRIP single-phase Z1B (Dis.TripZ1B1p)	x	0	1	0	0
3825	DisTRIP 3phase in Z1B with single-ph Flt (DisTRIP3p.Z1Bsf)	x	0	0	1	0
3826	DisTRIP 3phase in Z1B with multi-ph Flt. (DisTRIP3p Z1Bmf)	x	0	0	0	1
3803	Distance TRIP command - Only Phase L2 (Dis.Trip 1pL2)	0	x	1	0	0
3805	Distance TRIP command Phases L123 (Dis.Trip 3p)	0	x	0	1	1
PDIS10.Op.phsB		0	0	1	1	1

device annunciation: 1 - ON IEC Status Op.phsB: 0 - FALSE
0 - OFF 1 - TRUE
x - irrelevant

PDIS10.Op.phsC

No.	Information					
3813	Distance TRIP single-phase Z1B (Dis.TripZ1B1p)	x	0	1	0	0
3825	DisTRIP 3phase in Z1B with single-ph Flt (DisTRIP3p.Z1Bsf)	x	0	0	1	0
3826	DisTRIP 3phase in Z1B with multi-ph Flt. (DisTRIP3p Z1Bmf)	x	0	0	0	1
3804	Distance TRIP command - Only Phase L3 (Dis.Trip 1pL3)	0	x	1	0	0
3805	Distance TRIP command Phases L123 (Dis.Trip 3p)	0	x	0	1	1
PDIS10.Op.phsC		0	0	1	1	1

device annunciation: 1 - ON IEC Status Op,phsC: 0 - FALSE
 0 - OFF 1 - TRUE
 x - irrelevant

PDIS10.StrAG

No.	Information		
3741	Distance Pickup Z1, Loop L1E (Dis. Z1 L1E)	0	1
PDIS10.StrAG.stVal		0	1

device annunciation: 1 - ON IEC Status StrAG.stVal: 0 - FALSE
 0 - OFF 1 - TRUE

PDIS10.StrBG

No.	Information		
3742	Distance Pickup Z1, Loop L2E (Dis. Z1 L2E)	0	1
PDIS10.StrBG.stVal		0	1

device annunciation: 1 - ON IEC Status StrBG.stVal: 0 - FALSE
 0 - OFF 1 - TRUE

PDIS10.StrCG

No.	Information		
3743	Distance Pickup Z1, Loop L3E (Dis. Z1 L3E)	0	1
PDIS10.StrCG.stVal		0	1

device annunciation: 1 - ON IEC Status StrCG.stVal: 0 - FALSE
 0 - OFF 1 - TRUE

3.2.3 Distance protection zone 2 (PDIS2)

PDIS2.Mod

No.	Information								
3653	Distance is ACTIVE (Dist. ACTIVE)	0	x	x	1	1	1	1	1
3652	Distance is BLOCKED (Dist. BLOCK)	x	x	x	0	0	1	1	
3603	>BLOCK 21 Distance (>BLOCK 21 Dist.)	x	x	x	0	1	0	1	
3651	Distance is switched off (Dist. OFF)	x	1	x	0	0	0	0	
	Op. mode Z2 (P1311) = Inactive	x	x	1	0	0	0	0	
PDIS2.Mod.stVal		5	5	5	1	2	2	2	

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
 0 - OFF / FALSE 2 - BLOCKED
 x - irrelevant 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

PDIS2.Health

No.	Information				
51	Device is Operational and Protecting (Device OK)	1	1	0	0
3655	Setting error K0(>Z1) or Angle K0(>Z1) (DisErrorK0(>Z1))	1	0	1	0
PDIS2.Health.stVal		2	1	3	3

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
 0 - OFF 2 - WARNING
 3 - ALARM

PDIS2.Str

No.	Information		
3755	Distance Pickup Z2 (Dis. Pickup Z2)	0	1
PDIS2.Str.general		0	1

device annunciation: 1 - ON IEC Status Str.general: 0 - FALSE
 0 - OFF 1 - TRUE

PDIS2.Str.dirGeneral

No.	Information					
3719	Distance Pickup FORWARD (Dis. forward)	x	0	0	1	1
3720	Distance Pickup REVERSE (Dis. reverse)	x	0	1	0	1
3755	Distance Pickup Z2 (Dis. Pickup Z2)	0	1	1	1	1
PDIS2.Str.dirGeneral		0	0	2	1	3

device annunciation: 1 - ON IEC Status Str.dirGeneral: 0 - UNKNOWN
0 - OFF 1 - FORWARD
2 - BACKWARD
3 - BOTH

PDIS2.Op

No.	Information				
3816	Distance TRIP single-phase Z2 (Dis.TripZ2/1p)	0	0	1	1
3817	Distance TRIP 3phase in Z2 (Dis.TripZ2/3p)	0	1	0	1
PDIS2.Op.general		0	1	1	1

device annunciation: 1 - ON IEC Status Op.general: 0 - FALSE
0 - OFF 1 - TRUE

PDIS2.Op.phsA

No.	Information				
3816	Distance TRIP single-phase Z2 (Dis.TripZ2/1p)	0	x	1	0
3817	Distance TRIP 3phase in Z2 (Dis.TripZ2/3p)	0	x	0	1
3802	Distance TRIP command - Only Phase L1 (Dis.Trip 1pL1)	x	0	1	0
3805	Distance TRIP command Phases L123 (Dis.Trip 3p)	x	0	0	1
PDIS2.Op.phsA		0	0	1	1

device annunciation: 1 - ON IEC Status Op.phsA: 0 - FALSE
0 - OFF 1 - TRUE
x - irrelevant

PDIS2.Op.phsB

No.	Information				
3816	Distance TRIP single-phase Z2 (Dis.TripZ2/1p)	0	x	1	0
3817	Distance TRIP 3phase in Z2 (Dis.TripZ2/3p)	0	x	0	1
3803	Distance TRIP command - Only Phase L2 (Dis.Trip 1pL2)	x	0	1	0
3805	Distance TRIP command Phases L123 (Dis. Trip 3p)	x	0	0	1
PDIS2.Op.phsB		0	0	1	1

device annunciation: 1 - ON IEC Status Op.phsB: 0 - FALSE
 0 - OFF 1 - TRUE
 x - irrelevant

PDIS2.Op.phsC

No.	Information				
3816	Distance TRIP single-phase Z2 (Dis.TripZ2/1p)	0	x	1	0
3817	Distance TRIP 3phase in Z2 (Dis.TripZ2/3p)	0	x	0	1
3804	Distance TRIP command - Only Phase L3 (Dis.Trip 1pL3)	x	0	1	0
3805	Distance TRIP command Phases L123 (Dis. Trip 3p)	x	0	0	1
PDIS2.Op.phsC		0	0	1	1

device annunciation: 1 - ON IEC Status Op.phsC: 0 - FALSE
 0 - OFF 1 - TRUE
 x - irrelevant

3.2.4 Distance protection zone 3 (PDIS3)

PDIS3.Mod

No.	Information								
3653	Distance is ACTIVE (Dist. ACTIVE)	0	x	x	1	1	1	1	
3652	Distance is BLOCKED (Dist. BLOCK)	x	x	x	0	0	1	1	
3603	>BLOCK Z1 Distance (>BLOCK Z1 Dist.)	x	x	x	0	1	0	1	
3651	Distance is switched off (Dist. OFF)	x	1	x	0	0	0	0	
	Op. mode Z3 (P1321) = Inactive	x	x	1	0	0	0	0	
PDIS3.Mod.stVal		5	5	5	1	2	2	2	

device annunciation / setting: 1 - ON / TRUE
0 - OFF / FALSE
x - irrelevant

IEC Status Mod.stVal:

1 - ON
2 - BLOCKED
3 - TEST
4 - TEST/BLOCKED
5 - OFF

PDIS3.Health

No.	Information				
51	Device is Operational and Protecting (Device OK)	1	1	0	0
3655	Setting error K0(>Z1) or Angle K0(>Z1) (DisErrorK0(>Z1))	1	0	1	0
PDIS3.Health.stVal		2	1	3	3

device annunciation: 1 - ON
0 - OFF

IEC Status Health.stVal:

1 - OK
2 - WARNING
3 - ALARM

PDIS3.Str

No.	Information		
3758	Distance Pickup Z3 (Dis. Pickup Z3)	0	1
PDIS3.Str.general		0	1

device annunciation: 1 - ON IEC Status Str.general: 0 - FALSE
0 - OFF 1 - TRUE

PDIS3.Str.dirGeneral

No.	Information					
3719	Distance Pickup FORWARD (Dis. forward)	x	0	0	1	1
3720	Distance Pickup REVERSE (Dis. reverse)	x	0	1	0	1
3758	Distance Pickup Z3 (Dis. Pickup Z3)	0	1	1	1	1
PDIS3.Str.dirGeneral		0	0	2	1	3

device annunciation: 1 - ON IEC Status Str.dirGeneral: 0 - UNKNOWN
0 - OFF 1 - FORWARD
2 - BACKWARD
3 - BOTH

PDIS3.Op

No.	Information		
3818	Distance TRIP 3phase in Z3 (Dis.TripZ3/T3)	0	1
PDIS3.Op.general		0	1

device annunciation: 1 - ON IEC Status Op.general: 0 - FALSE
0 - OFF 1 - TRUE
x - irrelevant

PDIS3.Op.phsA

No.	Information				
3818	Distance TRIP 3phase in Z3 (Dis.TripZ3/T3)	0	1	1	1
3802	Distance TRIP command - Only Phase L1 (Dis.Trip 1pL1)	x	0	1	0
3805	Distance TRIP command Phases L123 (Dis.Trip 3p)	x	0	0	1
PDIS3.Op.phsA		0	0	1	1

device annunciation: 1 - ON IEC Status Op.phsA: 0 - FALSE
 0 - OFF 1 - TRUE
 x - irrelevant

PDIS3.Op.phsB

No.	Information				
3818	Distance TRIP 3phase in Z3 (Dis.TripZ3/T3)	0	1	1	1
3803	Distance TRIP command - Only Phase L2 (Dis.Trip 1pL2)	x	0	1	0
3805	Distance TRIP command Phases L123 (Dis.Trip 3p)	x	0	0	1
PDIS3.Op.phsB		0	0	1	1

device annunciation: 1 - ON IEC Status Op.phsB: 0 - FALSE
 0 - OFF 1 - TRUE
 x - irrelevant

PDIS3.Op.phsC

No.	Information				
3818	Distance TRIP 3phase in Z3 (Dis.TripZ3/T3)	0	1	1	1
3804	Distance TRIP command - Only Phase L3 (Dis.Trip 1pL3)	x	0	1	0
3805	Distance TRIP command Phases L123 (Dis.Trip 3p)	x	0	0	1
PDIS3.Op.phsC		0	0	1	1

device annunciation: 1 - ON IEC Status Op.phsC: 0 - FALSE
 0 - OFF 1 - TRUE
 x - irrelevant

3.2.5 Distance protection zone 4 (PDIS4)

PDIS4.Mod

No.	Information							
3653	Distance is ACTIVE (Dist. ACTIVE)	0	x	x	1	1	1	1
3652	Distance is BLOCKED (Dist. BLOCK)	x	x	x	0	0	1	1
3603	>BLOCK 21 Distance (>BLOCK 21 Dist.)	x	x	x	0	1	0	1
3651	Distance is switched off (Dist. OFF)	x	1	x	0	0	0	0
	Op. mode Z4 (P1331) = Inactive	x	x	1	0	0	0	0
PDIS4.Mod.stVal		5	5	5	1	2	2	2

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
 0 - OFF / FALSE 2 - BLOCKED
 x - irrelevant 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

PDIS4.Health

No.	Information				
51	Device is Operational and Protecting (Device OK)	1	1	0	0
3655	Setting error K0(>Z1) or Angle K0(>Z1) (DisErrorK0(>Z1))	1	0	1	0
PDIS4.Health.stVal		2	1	3	3

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
 0 - OFF 2 - WARNING
 3 - ALARM

PDIS4.Str

No.	Information		
3759	Distance Pickup Z4 (Dis. Pickup Z4)	0	1
PDIS4.Str.general		0	1

device annunciation: 1 - ON IEC Status Str.general: 0 - FALSE
 0 - OFF 1 - TRUE

PDIS4.Str.dirGeneral

No.	Information					
3719	Distance Pickup FORWARD (Dis. forward)	x	0	0	1	1
3720	Distance Pickup REVERSE (Dis. reverse)	x	0	1	0	1
3759	Distance Pickup Z4 (Dis. Pickup Z4)	0	1	1	1	1
PDIS4.Str.dirGeneral		0	0	2	1	3

device annunciation:

1 - ON
0 - OFF

IEC Status Str.dirGeneral:

0 - UNKNOWN
1 - FORWARD
2 - BACKWARD
3 - BOTH**PDIS4.Op**

No.	Information		
3821	Distance TRIP 3phase in Z4 (Dis.TRIP 3p. Z4)	0	1
PDIS4.Op.general		0	1

device annunciation:

1 - ON
0 - OFF

IEC Status Op.general:

0 - FALSE
1 - TRUE

PDIS4.Op.phsA

No.	Information				
3821	Distance TRIP 3phase in Z4 (Dis.TRIP 3p. Z4)	0	1	1	1
3802	Distance TRIP command - Only Phase L1 (Dis.Trip 1pL1)	x	0	1	0
3805	Distance TRIP command Phases L123 (Dis.Trip 3p)	x	0	0	1
PDIS4.Op.phsA		0	0	1	1

device annunciation: 1 - ON IEC Status Op.phsA: 0 - FALSE
 0 - OFF 1 - TRUE
 x - irrelevant

PDIS4.Op.phsB

No.	Information				
3821	Distance TRIP 3phase in Z4 (Dis.TRIP 3p. Z4)	0	1	1	1
3803	Distance TRIP command - Only Phase L2 (Dis.Trip 1pL2)	x	0	1	0
3805	Distance TRIP command Phases L123 (Dis.Trip 3p)	x	0	0	1
PDIS4.Op.phsB		0	0	1	1

device annunciation: 1 - ON IEC Status Op.phsB: 0 - FALSE
 0 - OFF 1 - TRUE
 x - irrelevant

PDIS4.Op.phsC

No.	Information				
3821	Distance TRIP 3phase in Z4 (Dis.TRIP 3p. Z4)	0	1	1	1
3804	Distance TRIP command - Only Phase L3 (Dis.Trip 1pL3)	x	0	1	0
3805	Distance TRIP command Phases L123 (Dis.Trip 3p)	x	0	0	1
PDIS4.Op.phsC		0	0	1	1

device annunciation: 1 - ON IEC Status Op.phsC: 0 - FALSE
 0 - OFF 1 - TRUE
 x - irrelevant

3.2.6 Distance protection zone 5 (PDIS5)

PDIS5.Mod

No.	Information								
3653	Distance is ACTIVE (Dist. ACTIVE)	0	x	x	1	1	1	1	
3652	Distance is BLOCKED (Dist. BLOCK)	x	x	x	0	0	1	1	
3603	>BLOCK Z1 Distance (>BLOCK Z1 Dist.)	x	x	x	0	1	0	1	
3651	Distance is switched off (Dist. OFF)	x	1	x	0	0	0	0	
	Op. mode Z5 (P1341) = Inactive	x	x	1	0	0	0	0	
PDIS5.Mod.stVal		5	5	5	1	2	2	2	

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
 0 - OFF / FALSE 2 - BLOCKED
 x - irrelevant 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

PDIS5.Health

No.	Information				
51	Device is Operational and Protecting (Device OK)	1	1	0	0
3655	Setting error K0(>Z1) or Angle K0(>Z1) (DisErrorK0(>Z1))	1	0	1	0
PDIS5.Health.stVal		2	1	3	3

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
 0 - OFF 2 - WARNING
 3 - ALARM

PDIS5.Str

No.	Information		
3760	Distance Pickup Z5 (Dis. Pickup Z5)	0	1
PDIS5.Str.general		0	1

device annunciation: 1 - ON IEC Status Str.general: 0 - FALSE
 0 - OFF 1 - TRUE

PDIS5.Str.dirGeneral

No.	Information					
3719	Distance Pickup FORWARD (Dis. forward)	x	0	0	1	1
3720	Distance Pickup REVERSE (Dis. reverse)	x	0	1	0	1
3760	Distance Pickup Z5 (Dis. Pickup Z5)	0	1	1	1	1
PDIS5.Str.dirGeneral		0	0	2	1	3

device annunciation: 1 - ON
0 - OFF

IEC Status Str.dirGeneral: 0 - UNKNOWN
1 - FORWARD
2 - BACKWARD
3 - BOTH

PDIS5.Op

No.	Information		
3822	Distance TRIP 3phase in Z5 (Dis.TRIP 3p. Z5)	0	1
PDIS5.Op.general		0	1

device annunciation: 1 - ON
0 - OFF

IEC Status Op.general: 0 - FALSE
1 - TRUE

PDIS5.Op.phsA

No.	Information				
3822	Distance TRIP 3phase in Z5 (Dis.TRIP 3p. Z5)	0	1	1	1
3802	Distance TRIP command - Only Phase L1 (Dis.Trip 1pL1)	x	0	1	0
3805	Distance TRIP command Phases L123 (Dis.Trip 3p)	x	0	0	1
PDIS5.Op.phsA		0	0	1	1

device annunciation: 1 - ON IEC Status Op.phsA: 0 - FALSE
 0 - OFF 1 - TRUE
 x - irrelevant

PDIS5.Op.phsB

No.	Information				
3822	Distance TRIP 3phase in Z5 (Dis.TRIP 3p. Z5)	0	1	1	1
3803	Distance TRIP command - Only Phase L2 (Dis.Trip 1pL2)	x	0	1	0
3805	Distance TRIP command Phases L123 (Dis.Trip 3p)	x	0	0	1
PDIS5.Op.phsB		0	0	1	1

device annunciation: 1 - ON IEC Status Op.phsB: 0 - FALSE
 0 - OFF 1 - TRUE
 x - irrelevant

PDIS5.Op.phsC

No.	Information				
3822	Distance TRIP 3phase in Z5 (Dis.TRIP 3p. Z5)	0	1	1	1
3804	Distance TRIP command - Only Phase L3 (Dis.Trip 1pL3)	x	0	1	0
3805	Distance TRIP command Phases L123 (Dis.Trip 3p)	x	0	0	1
PDIS5.Op.phsC		0	0	1	1

device annunciation: 1 - ON IEC Status Op.phsC: 0 - FALSE
 0 - OFF 1 - TRUE
 x - irrelevant

3.2.7 Distance protection general information (PTRC2)

PTRC2.Mod

No.	Information					
3653	Distance is ACTIVE (Dist. ACTIVE)	0	1	0	0	0
3652	Distance is BLOCKED (Dist. BLOCK)	x	0	1	0	1
3603	>BLOCK 21 Distance (>BLOCK 21 Dist.)	x	0	0	1	1
3651	Distance is switched off (Dist. OFF)	1	0	0	0	0
PTRC2.Mod.stVal		5	1	2	2	2

device annunciation:
 1 - ON
 0 - OFF
 x - irrelevant

IEC Status Mod.stVal:
 1 - ON
 2 - BLOCKED
 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

PTRC2.Health

No.	Information					
3654	Setting error K0(Z1) or Angle K0(Z1) (Dis.ErrorK0(Z1))	x	0	1	0	1
3655	Setting error K0(>Z1) or Angle K0(>Z1) (DisErrorK0(>Z1))	x	0	0	1	1
51	Device is Operational and Protecting (Device OK)	0	1	1	1	1
PTRC2.Health.stVal		3	1	2	2	2

device annunciation:
 1 - ON
 0 - OFF

IEC Status Health.stVal:
 1 - OK
 2 - WARNING
 3 - ALARM

PTRC2.Str

No.	Information		
3671	Distance PICKED UP (Dis. PICKUP)	0	1
PTRC2.Str.general		0	1

device annunciation:
 1 - ON
 0 - OFF

IEC Status Str.general:
 0 - FALSE
 1 - TRUE

PTRC2.Str.dirGeneral

No.	Information				
3720	Distance Pickup REVERSE (Dis. reverse)	1	1	0	0
3719	Distance Pickup FORWARD (Dis. forward)	1	0	1	0
PTRC2.Str.dirGeneral		3	2	1	0

device annunciation: 1 - ON IEC Status Str.dirGeneral: 0 - UNKNOWN
 0 - OFF 1 - FORWARD
 2 - BACKWARD
 3 - BOTH

PTRC2.Str.phsA

No.	Information		
3672	Distance PICKUP L1 (Dis.Pickup L1)	0	1
PTRC2.Str.phsA		0	1

device annunciation: 1 - ON IEC Status Str.phsA: 0 - FALSE
 0 - OFF 1 - TRUE

PTRC2.Str.dirPhsA

No.	Information														
3701	Distance Loop L1E selected forward (Dis.Loop L1-E f)	1	x	x	0	0	0	1	1	x	x	x	x	0	
3704	Distance Loop L12 selected forward (Dis.Loop L1-2 f)	x	1	x	0	0	0	x	x	1	1	x	x	0	
3706	Distance Loop L31 selected forward (Dis.Loop L3-1 f)	x	x	1	0	0	0	x	x	x	x	1	1	0	
3707	Distance Loop L1E selected reverse (Dis.Loop L1-E r)	0	0	0	1	x	x	0	0	1	x	1	x	0	
3710	Distance Loop L12 selected reverse (Dis.Loop L1-2 r)	0	0	0	x	1	x	1	x	0	0	x	1	0	
3712	Distance Loop L31 selected reverse (Dis.Loop L3-1 r)	0	0	0	x	x	1	x	1	x	1	0	0	0	
PTRC2.Str.dirPhsA		1	1	1	2	2	2	3	3	3	3	3	3	0	

device annunciation: 1 - ON IEC Status Str.dirPhsA: 0 - UNKNOWN
 0 - OFF 1 - FORWARD
 x - irrelevant 2 - BACKWARD

3.2 Distance Protection (PDISx, PTRC2)

PTRC2.Str.phsB

No.	Information		
3673	Distance PICKUP L2 (Dis.Pickup L2)	0	1
PTRC2.Str.phsB		0	1

device annunciation: 1 - ON IEC Status Str.phsB: 0 - FALSE
 0 - OFF 1 - TRUE

PTRC2.Str.dirPhsB

No.	Information														
3702	Distance Loop L2E selected forward (Dis.Loop L2-E f)	1	x	x	0	0	0	1	1	x	x	x	x	0	
3704	Distance Loop L12 selected forward (Dis.Loop L1-2 f)	x	1	x	0	0	0	x	x	1	1	x	x	0	
3705	Distance Loop L23 selected forward (Dis.Loop L2-3 f)	x	x	1	0	0	0	x	x	x	x	1	1	0	
3708	Distance Loop L2E selected reverse (Dis.Loop L2-E r)	0	0	0	1	x	x	0	0	1	x	1	x	0	
3710	Distance Loop L12 selected reverse (Dis.Loop L1-2 r)	0	0	0	x	1	x	1	x	0	0	x	1	0	
3711	Distance Loop L23 selected reverse (Dis.Loop L2-3 r)	0	0	0	x	x	1	x	1	x	1	0	0	0	
PTRC2.Str.dirPhsB		1	1	1	2	2	3	3	3	3	3	3	3	0	

device annunciation: 1 - ON IEC Status Str.dirPhsB: 0 - UNKNOWN
 0 - OFF 1 - FORWARD
 x - irrelevant 2 - BACKWARD

PTRC2.Str.phsC

No.	Information		
3674	Distance PICKUP L3 (Dis.Pickup L3)	0	1
PTRC2.Str.phsC		0	1

device annunciation: 1 - ON IEC Status Str.phsC: 0 - FALSE
0 - OFF 1 - TRUE

PTRC2.Str.dirPhsC

No.	Information														
3703	Distance Loop L3E selected forward (Dis.Loop L3-E f)	1	x	x	0	0	0	1	1	x	x	x	x	0	
3705	Distance Loop L23 selected forward (Dis.Loop L2-3 f)	x	1	x	0	0	0	x	x	1	1	x	x	0	
3706	Distance Loop L31 selected forward (Dis.Loop L3-1 f)	x	x	1	0	0	0	x	x	x	x	1	1	0	
3709	Distance Loop L3E selected reverse (Dis.Loop L3-E r)	0	0	0	1	x	x	0	0	1	x	1	x	0	
3711	Distance Loop L23 selected reverse (Dis.Loop L2-3 r)	0	0	0	x	1	x	1	x	0	0	x	1	0	
3712	Distance Loop L31 selected reverse (Dis.Loop L3-1 r)	0	0	0	x	x	1	x	1	x	1	0	0	0	
PTRC2.Str.dirPhsC		1	1	1	2	2	2	3	3	3	3	3	3	0	

device annunciation: 1 - ON IEC Status Str.dirPhsC: 0 - UNKNOWN
0 - OFF 1 - FORWARD
x - irrelevant 2 - BACKWARD

PTRC2.Str.neut

No.	Information		
3675	Distance PICKUP Earth (Dis.Pickup E)	0	1
PTRC2.Str.neut		0	1

device annunciation: 1 - ON IEC Status Str.neut: 0 - FALSE
0 - OFF 1 - TRUE

PTRC2.Op

No.	Information		
3801	Distance protection: General trip (Dis.Gen. Trip)	0	1
PTRC2.Op.general		0	1

device annunciation: 1 - ON IEC Status Op.general: 0 - FALSE
0 - OFF 1 - TRUE

PTRC2.Op.phsA

No.	Information			
3802	Distance TRIP command - Only Phase L1 (Dis.Trip 1pL1)	1	0	0
3805	Distance TRIP command Phases L123 (Dis.Trip 3p)	0	1	0
PTRC2.Op.phsA		1	1	0

device annunciation: 1 - ON IEC Status Op.phsA: 0 - FALSE
0 - OFF 1 - TRUE

PTRC2.Op.phsB

No.	Information			
3803	Distance TRIP command - Only Phase L2 (Dis.Trip 1pL2)	1	0	0
3805	Distance TRIP command Phases L123 (Dis.Trip 3p)	0	1	0
PTRC2.Op.phsB		1	1	0

device annunciation: 1 - ON IEC Status Op.phsB: 0 - FALSE
0 - OFF 1 - TRUE

PTRC2.Op.phsC

No.	Information			
3804	Distance TRIP command - Only Phase L3 (Dis.Trip 1pL3)	1	0	0
3805	Distance TRIP command Phases L123 (Dis.Trip 3p)	0	1	0
PTRC2.Op.phsC		1	1	0

device annunciation: 1 - ON IEC Status Op.phsC: 0 - FALSE
0 - OFF 1 - TRUE

3.3 Power swing detection (RPSBx)

3.3.1 Power swing detection zone 1 (RPSB1)

RPSB1.Mod

No.	Information					
3651	Distance is switched off (Dist. OFF)	x	x	1	0	0
4160	>BLOCK Power Swing detection (>Pow. Swing BLK)	x	x	x	0	1
	Power Swing (P 120) = Enabled and Dis. PICKUP (P 114) = Z< (quadrilat.)	0	1	1	1	1
	P/S Op. mode (P2002) = All zones block or Z1/Z1B block or Z1,Z1B,Z2 block	x	1	x	0	0
RPSB1.Mod.stVal		5	5	5	1	2

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
0 - OFF / FALSE 2 - BLOCKED
3 - TEST
4 - TEST/BLOCKED
5 - OFF

RPSB1.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
RPSB1.Health.stVal		3	1

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
0 - OFF 2 - WARNING
3 - ALARM

RPSB1.Str

No.	Information			
4164	Power Swing detected (Power Swing)	0	1	x
	P/S Op. mode (P2002) = All zones block or Z1/Z1B block or Z1,Z1B,Z2 block	0	0	1
RPSB1.Str.general		0	1	0

device annunciation / setting: 1 - ON / TRUE IEC Status Str.general: 0 - FALSE
0 - OFF / FALSE 1 - TRUE
x - irrelevant

RPSB2.Str.phsA

No.	Information			
4167	Power Swing detected in L1 (Pow. Swing L1)	0	1	x
	P/S Op. mode (P2002) = All zones block or Z1,Z1B,Z2 block or Z2 to Z5 block	0	0	1
RPSB2.Str.phsA		0	1	0

device annunciation / setting: 1 - ON / TRUE IEC Status Str.phsA: 0 - FALSE
0 - OFF / FALSE 1 - TRUE

RPSB2.Str.phsB

No.	Information			
4168	Power Swing detected in L2 (Pow. Swing L2)	0	1	x
	P/S Op. mode (P2002) = All zones block or Z1,Z1B,Z2 block or Z2 to Z5 block	0	0	1
RPSB2.Str.phsB		0	1	0

device annunciation / setting: 1 - ON / TRUE IEC Status Str.phsB: 0 - FALSE
0 - OFF / FALSE 1 - TRUE

RPSB2.Str.phsC

No.	Information			
4169	Power Swing detected in L3 (Pow. Swing L3)	0	1	x
	P/S Op. mode (P2002) = All zones block or Z1,Z1B,Z2 block or Z2 to Z5 block	0	0	1
RPSB2.Str.phsC		0	1	0

device annunciation / setting: 1 - ON / TRUE IEC Status Str.phsC: 0 - FALSE
0 - OFF / FALSE 1 - TRUE

RPSB2.BlkZn

No.	Information				
4164	Power Swing detected (Power Swing)	0	1	1	x
4166	Power Swing TRIP command (Pow. Swing TRIP)	0	0	1	x
	P/S Op. mode (P2002) = All zones block or Z1,Z1B,Z2 block or Z2 to Z5 block	0	0	0	1
RPSB2.BlkZn.stVal		0	1	0	0

device annunciation / setting: 1 - ON / TRUE IEC Status BlkZn.stVal: 0 - NOT BLOCKED
0 - OFF / FALSE 1 - BLOCKED

3.3.4 Power swing detection zone 3 (RPSB3)

RPSB3.Mod

No.	Information				
4160	>BLOCK Power Swing detection (>Pow. Swing BLK)	x	0	1	x
	Power Swing (P 120) = Enabled and Dis. PICKUP (P 114) = Z< (quadrilat.)	0	1	1	1
	P/S Op. mode (P2002) = All zones block or Z2 to Z5 block	x	0	0	1
RPSB3.Mod.stVal		5	1	2	5

device annunciation / setting: 1 - ON / TRUE
0 - OFF / FALSE

IEC Status Mod.stVal:

1 - ON
2 - BLOCKED
3 - TEST
4 - TEST/BLOCKED
5 - OFF

RPSB3.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
RPSB3.Health.stVal		3	1

device annunciation:
1 - ON
0 - OFF

IEC Status Health.stVal:

1 - OK
2 - WARNING
3 - ALARM

RPSB3.Str

No.	Information			
4164	Power Swing detected (Power Swing)	0	1	x
	P/S Op. mode (P2002) = All zones block or Z2 to Z5 block	0	0	1
RPSB1.Str.general		0	1	0

device annunciation / setting: 1 - ON / TRUE
0 - OFF / FALSE
x - irrelevant

IEC Status Str.general:

0 - FALSE
1 - TRUE

RPSB3.Str.phsA

No.	Information			
4167	Power Swing detected in L1 (Pow. Swing L1)	0	1	x
	P/S Op. mode (P2002) = All zones block or Z2 to Z5 block	0	0	1
RPSB3.Str.phsA		0	1	0

device annunciation / setting: 1 - ON / TRUE IEC Status Str.phsA: 0 - FALSE
0 - OFF / FALSE 1 - TRUE

RPSB3.Str.phsB

No.	Information			
4168	Power Swing detected in L2 (Pow. Swing L2)	0	1	x
	P/S Op. mode (P2002) = All zones block or Z2 to Z5 block	0	0	1
RPSB3.Str.phsB		0	1	0

device annunciation / setting: 1 - ON / TRUE IEC Status Str.phsB: 0 - FALSE
0 - OFF / FALSE 1 - TRUE

RPSB3.Str.phsC

No.	Information			
4169	Power Swing detected in L3 (Pow. Swing L3)	0	1	x
	P/S Op. mode (P2002) = All zones block or Z2 to Z5 block	0	0	1
RPSB3.Str.phsC		0	1	0

device annunciation / setting: 1 - ON / TRUE IEC Status Str.phsC: 0 - FALSE
0 - OFF / FALSE 1 - TRUE

RPSB3.BlkZn

No.	Information				
4164	Power Swing detected (Power Swing)	0	1	1	x
4166	Power Swing TRIP command (Pow. Swing TRIP)	0	0	1	x
	P/S Op. mode (P2002) = All zones block or Z2 to Z5 block	0	0	0	1
RPSB3.BlkZn.stVal		0	1	0	0

device annunciation / setting: 1 - ON / TRUE IEC Status BlkZn.stVal: 0 - NOT BLOCKED
0 - OFF / FALSE 1 - BLOCKED

RPSB5.Str.phsA

No.	Information			
4167	Power Swing detected in L1 (Pow. Swing L1)	0	1	x
	P/S Op. mode (P2002) = All zones block or Z2 to Z5 block	0	0	1
RPSB5.Str.phsA		0	1	0

device annunciation / setting: 1 - ON / TRUE IEC Status Str.phsA: 0 - FALSE
0 - OFF / FALSE 1 - TRUE

RPSB5.Str.phsB

No.	Information			
4168	Power Swing detected in L2 (Pow. Swing L2)	0	1	x
	P/S Op. mode (P2002) = All zones block or Z2 to Z5 block	0	0	1
RPSB5.Str.phsB		0	1	0

device annunciation / setting: 1 - ON / TRUE IEC Status Str.phsB: 0 - FALSE
0 - OFF / FALSE 1 - TRUE

RPSB5.Str.phsC

No.	Information			
4169	Power Swing detected in L3 (Pow. Swing L3)	0	1	x
	P/S Op. mode (P2002) = All zones block or Z2 to Z5 block	0	0	1
RPSB5.Str.phsC		0	1	0

device annunciation / setting: 1 - ON / TRUE IEC Status Str.phsC: 0 - FALSE
0 - OFF / FALSE 1 - TRUE

RPSB5.BlkZn

No.	Information				
4164	Power Swing detected (Power Swing)	0	1	1	x
4166	Power Swing TRIP command (Pow. Swing TRIP)	0	0	1	x
	P/S Op. mode (P2002) = All zones block or Z2 to Z5 block	0	0	0	1
RPSB5.BlkZn.stVal		0	1	0	0

device annunciation / setting: 1 - ON / TRUE IEC Status BlkZn.stVal: 0 - NOT BLOCKED
0 - OFF / FALSE 1 - BLOCKED

3.4 Teleprotection for distance protection (PSCH1)

PSCH1.Mod

No.	Information				
4003	>Distance Teleprotection BLOCK (>Dis.Telep. Blk)	1	1	0	0
4052	Dis. Teleprotection is switched OFF (Dis.Telep. OFF)	1	0	1	0
PSCH1.Mod.stVal		5	2	5	1

device annunciation: 1 - ON
0 - OFF

IEC Status Mod.stVal: 1 - ON
2 - BLOCKED
3 - TEST
4 - TEST/BLOCKED
5 - OFF

PSCH1.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PSCH1.Health.stVal		3	1

device annunciation: 1 - ON
0 - OFF

IEC Status Health.stVal: 1 - OK
2 - WARNING
3 - ALARM

PSCH1.ProTx

No.	Information						
4057	Dis. Telep. Carrier SEND signal, L1 (Dis.T.SEND L1)	1	1	x	x	x	0
4058	Dis. Telep. Carrier SEND signal, L2 (Dis.T.SEND L2)	1	x	1	x	x	0
4059	Dis. Telep. Carrier SEND signal, L3 (Dis.T.SEND L3)	1	x	x	1	x	0
4056	Dis. Telep. Carrier SEND signal (Dis.T.SEND)	1	x	x	x	1	0
PSCH1.ProTx.stVal		1	1	1	1	1	0

device annunciation: 1 - ON
0 - OFF
x - irrelevant

IEC Status ProTx.stVal: 0 - FALSE
1 - TRUE

PSCH1.ProRx

No.	Information		
4054	Dis. Telep. Carrier signal received (Dis.T.Carr.rec.)	0	1
PSCH1.ProRx.stVal		0	1

device annunciation: 1 - ON IEC Status ProRx.stVal: 0 - FALSE
0 - OFF 1 - TRUE

PSCH1.Str

No.	Information						
4057	Dis. Telep. Carrier SEND signal, L1 (Dis.T.SEND L1)	1	1	x	x	x	0
4058	Dis. Telep. Carrier SEND signal, L2 (Dis.T.SEND L2)	1	x	1	x	x	0
4059	Dis. Telep. Carrier SEND signal, L3 (Dis.T.SEND L3)	1	x	x	1	x	0
4056	Dis. Telep. Carrier SEND signal (Dis.T.SEND)	1	x	x	x	1	0
PSCH1.Str.general		1	1	1	1	1	0

device annunciation: 1 - ON IEC Status Str.general: 0 - FALSE
0 - OFF 1 - TRUE
x - irrelevant

PSCH1.Str.phsA

No.	Information		
4057	Dis. Telep. Carrier SEND signal, L1 (Dis.T.SEND L1)	0	1
PSCH1.Str.phsA		0	1

device annunciation: 1 - ON IEC Status Str.phsA: 0 - FALSE
0 - OFF 1 - TRUE

PSCH1.Str.phsB

No.	Information		
4058	Dis. Telep. Carrier SEND signal, L2 (Dis.T.SEND L2)	0	1
PSCH1.Str.phsB		0	1

device annunciation: 1 - ON IEC Status Str.phsB: 0 - FALSE
0 - OFF 1 - TRUE

3.4 Teleprotection for distance protection (PSCH1)

PSCH1.Str.phsC

No.	Information		
4059	Dis. telep. Carrier SEND signal, L3 (Dis.T.SEND L3)	0	1
PSCH1.Str.phsC		0	1

device annunciation: 1 - ON IEC Status Str.phsC: 0 - FALSE
 0 - OFF 1 - TRUE

PSCH1.Op

No.	Information		
3850	DisTRIP Z1B with Teleprotection scheme (DisTRIP Z1B Tel)	0	1
PSCH1.Op.general		0	1

device annunciation: 1 - ON IEC Status Op.general: 0 - FALSE
 0 - OFF 1 - TRUE

PSCH1.CarRx

No.	Information							
4030	>Dis.Tele. Unblocking: UNBLOCK Channel 1 (>Dis.T.UB ub 1)	1	1	x	x	x	x	0
4035	>Dis.Tele. Unblocking: UNBLOCK Channel 2 (>Dis.T.UB ub 2)	1	x	1	x	x	x	0
4032	>Dis.Tele. Unblocking: UNBLOCK Ch. 1, L1 (>Dis.T.UB ub1L1)	1	x	x	1	x	x	0
4033	>Dis.Tele. Unblocking: UNBLOCK Ch. 1, L2 (>Dis.T.UB ub1L2)	1	x	x	x	1	x	0
4034	>Dis.Tele. Unblocking: UNBLOCK Ch. 1, L3 (>Dis.T.UB ub1L3)	1	x	x	x	x	1	0
PSCH1.CarRx.general		1	1	1	1	1	1	0

device annunciation: 1 - ON IEC Status CarRx.general: 0 - FALSE
0 - OFF 1 - TRUE
x - irrelevant

PSCH1.LosOfGrd

No.	Information				
4055	Dis. Telep. Carrier CHANNEL FAILURE (Dis.T.Carr.Fail)	1	x	x	0
4080	Dis. Tele.Unblocking: FAILURE Channel 1 (Dis.T.UB Fail1)	1	1	x	0
4081	Dis. Tele.Unblocking: FAILURE Channel 2 (Dis.T.UB Fail2)	1	x	1	0
PSCH1.LosOfGrd.stVal		1	1	1	0

device annunciation: 1 - ON IEC Status LosOfGrd.stVal: 0 - FALSE
0 - OFF 1 - TRUE
x - irrelevant

PSCH1.Echo

No.	Information		
4246	ECHO Send SIGNAL (ECHO SIGNAL)	0	1
PSCH1.Echo.stVal		0	1

device annunciation: 1 - ON IEC Status Echo.stVal: 0 - FALSE
0 - OFF 1 - TRUE

PSCH1.Weio.general

No.	Information		
4241	Weak Infeed General TRIP command (WeakInfeed TRIP)	0	1
PSCH1.Weio.general		0	1

device annunciation: 1 - ON IEC Status Weio.general: 0 - FALSE
 0 - OFF 1 - TRUE

PSCH1.Weio.phsA

No.	Information				
4242	Weak Infeed TRIP command - Only L1 (Weak TRIP 1p.L1)	1	1	x	0
4245	Weak Infeed TRIP command L123 (Weak TRIP L123)	1	x	1	0
PSCH1.Weio.phsA		1	1	1	0

device annunciation: 1 - ON IEC Status Weio.phsA: 0 - FALSE
 0 - OFF 1 - TRUE
 x - irrelevant

PSCH1.Weio.phsB

No.	Information				
4243	Weak Infeed TRIP command - Only L2 (Weak TRIP 1p.L2)	1	1	x	0
4245	Weak Infeed TRIP command L123 (Weak TRIP L123)	1	x	1	0
PSCH1.Weio.phsB		1	1	1	0

device annunciation: 1 - ON IEC Status Weio.phsB: 0 - FALSE
 0 - OFF 1 - TRUE
 x - irrelevant

PSCH1.Weio.phsC

No.	Information				
4244	Weak Infeed TRIP command - Only L3 (Weak TRIP 1p.L3)	1	1	x	0
4245	Weak Infeed TRIP command L123 (Weak TRIP L123)	1	x	1	0
PSCH1.Weio.phsC		1	1	1	0

device annunciation: 1 - ON IEC Status Weio.phsC: 0 - FALSE
 0 - OFF 1 - TRUE
 x - irrelevant

PSCH1.RvABIk

No.	Information		
4068	Dis. Telep. Transient Blocking (Dis.T.Trans.Blk)	0	1
PSCH1.RvABIk.stVal		0	1

device annunciation: 1 - ON IEC Status RvABIk.stVal: 0 - FALSE
 0 - OFF 1 - TRUE
 x - irrelevant

PSCH1.GrdRx

No.	Information			
4031	>Dis.Tele. Unblocking: BLOCK Channel 1 (>Dis.T.UB bl 1)	1	x	0
4036	>Dis.Tele. Unblocking: BLOCK Channel 2 (>Dis.T.UB bl 2)	x	1	0
PSCH1.GrdRx.stVal		1	1	0

device annunciation: 1 - ON IEC Status GrdRx.stVal: 0 - FALSE
 0 - OFF 1 - TRUE
 x - irrelevant

3.5 Earth fault overcurrent protection in earthed systems (PTOCx)

3.5.1 Earth fault 3I0 > (PTOC5)

PTOC5.Mod

No.	Information							
1333	Earth fault protection is ACTIVE (E/F ACTIVE)	x	x	0	1	1	1	1
1332	Earth fault protection is BLOCKED (E/F BLOCK)	x	x	x	0	1	1	0
1308	>Earth Fault O/C Block 3I0> (>EF BLOCK 3I0>)	x	x	x	1	0	1	0
1331	Earth fault protection is switched OFF (E/F Prot. OFF)	1	x	x	0	0	0	0
	Op. mode 3I0> (P3130) = Inactive	x	1	x	0	0	0	0
PTOC5.Mod.stVal		5	5	5	2	2	2	1

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
0 - OFF / FALSE 2 - BLOCKED
x - irrelevant 3 - TEST
4 - TEST/BLOCKED
5 - OFF

PTOC5.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTOC5.Health.stVal		3	1

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
0 - OFF 2 - WARNING
3 - ALARM

PTOC5.Str

No.	Information		
1356	E/F 3I0> PICKED UP (EF 3I0> Pickup)	0	1
PTOC5.Str.general		0	1

device annunciation: 1 - ON IEC Status Str.general: 0 - FALSE
0 - OFF 1 - TRUE

PTOC5.Str.dirGeneral

No.	Information					
1358	E/F picked up FORWARD (EF forward)	x	1	1	0	0
1359	E/F picked up REVERSE (EF reverse)	x	1	0	1	0
1356	E/F 3I0> PICKED UP (EF 3I0> Pickup)	0	1	1	1	1
PTOC5.Str.dirGeneral		0	3	1	2	0

device annunciation: 1 - ON
0 - OFF

IEC Status Str.dirGeneral: 0 - UNKNOWN
1 - FORWARD
2 - BACKWARD
3 - BOTH

PTOC5.Op

No.	Information		
1368	E/F 3I0> TRIP (EF 3I0> TRIP)	0	1
PTOC5.Op.general		0	1

device annunciation: 1 - ON
0 - OFF

IEC Status Op.general: 0 - FALSE
1 - TRUE

PTOC6.Str.dirGeneral

No.	Information					
1358	E/F picked up FORWARD (EF forward)	x	1	1	0	0
1359	E/F picked up REVERSE (EF reverse)	x	1	0	1	0
1355	E/F 3I0>> PICKED UP (EF 3I0>> Pickup)	0	1	1	1	1
PTOC6.Str.dirGeneral		0	3	1	2	0

device annunciation: 1 - ON
0 - OFF

IEC Status Str.dirGeneral: 0 - UNKNOWN
1 - FORWARD
2 - BACKWARD
3 - BOTH

PTOC6.Op

No.	Information		
1367	E/F 3I0>> TRIP (EF 3I0>> TRIP)	0	1
PTOC6.Op.general		0	1

device annunciation: 1 - ON
0 - OFF

IEC Status Op.general: 0 - FALSE
1 - TRUE

3.5.3 Earth fault 3I0 >>> (PTOC7)

PTOC7.Mod

No.	Information							
1333	Earth fault protection is ACTIVE (E/F ACTIVE)	x	x	0	1	1	1	1
1332	Earth fault protection is BLOCKED (E/F BLOCK)	x	x	x	0	1	1	0
1305	>Earth Fault O/C Block 3I0>>> (>EF BLK 3I0>>>)	x	x	x	1	0	1	0
1331	Earth fault protection is switched OFF (E/F Prot. OFF)	1	x	x	0	0	0	0
	Op. mode 3I0>>> (P3110) = Inactive	x	1	x	0	0	0	0
PTOC7.Mod.stVal		5	5	5	2	2	2	1

device annunciation / setting: 1 - ON / TRUE
0 - OFF / FALSE
x - irrelevant

IEC Status Mod.stVal:

1 - ON
2 - BLOCKED
3 - TEST
4 - TEST/BLOCKED
5 - OFF

PTOC7.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTOC7.Health.stVal		3	1

device annunciation: 1 - ON
0 - OFF

IEC Status Health.stVal:

1 - OK
2 - WARNING
3 - ALARM

PTOC7.Str

No.	Information		
1354	E/F 3I0>>> PICKED UP (EF 3I0>>>Pickup)	0	1
PTOC7.Str.general		0	1

device annunciation: 1 - ON
0 - OFF

IEC Status Str.general:

0 - FALSE
1 - TRUE

PTOC7.Str.dirGeneral

No.	Information					
1358	E/F picked up FORWARD (EF forward)	x	1	1	0	0
1359	E/F picked up REVERSE (EF reverse)	x	1	0	1	0
1354	E/F 3I0>>> PICKED UP (EF 3I0>>>Pickup)	0	1	1	1	1
PTOC7.Str.dirGeneral		0	3	1	2	0

device annunciation: 1 - ON
0 - OFF

IEC Status Str.dirGeneral: 0 - UNKNOWN
1 - FORWARD
2 - BACKWARD
3 - BOTH

PTOC7.Op

No.	Information		
1366	E/F 3I0>>> TRIP (EF 3I0>>> TRIP)	0	1
PTOC7.Op.general		0	1

device annunciation: 1 - ON
0 - OFF

IEC Status Op.general: 0 - FALSE
1 - TRUE

3.5.4 Earth fault 3I0p (PTOC8)

PTOC8.Mod

No.	Information						
1332	Earth fault protection is BLOCKED (E/F BLOCK)	x	x	1	1	0	0
1309	>Earth Fault O/C Block 3I0p (>EF BLOCK 3I0p)	x	x	1	0	1	0
1331	Earth fault protection is switched OFF (E/F Prot. OFF)	1	x	0	0	0	0
	Op. mode 3I0p (P3140) = Inactive	x	1	0	0	0	0
PTOC8.Mod.stVal		5	5	2	2	2	1

device annunciation / setting: 1 - ON / TRUE
0 - OFF / FALSE

IEC Status Mod.stVal:

1 - ON
2 - BLOCKED
3 - TEST
4 - TEST/BLOCKED
5 - OFF

PTOC8.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTOC8.Health.stVal		3	1

device annunciation: 1 - ON
0 - OFF

IEC Status Health.stVal:

1 - OK
2 - WARNING
3 - ALARM

PTOC8.Str

No.	Information		
1357	E/F 3I0p PICKED UP (EF 3I0p Pickup)	0	1
PTOC8.Str.general		0	1

device annunciation: 1 - ON
0 - OFF

IEC Status Str.general:

0 - FALSE
1 - TRUE

PTOC8.Str.dirGeneral

No.	Information					
1358	E/F picked up FORWARD (EF forward)	x	0	1	1	0
1359	E/F picked up REVERSE (EF reverse)	x	0	0	1	1
1357	E/F 3I0p PICKED UP (EF 3I0p Pickup)	0	1	1	1	1
PTOC8.Str.dirGeneral		0	0	1	3	2

device annunciation: 1 - ON
0 - OFF

IEC Status Str.dirGeneral: 0 - UNKNOWN
1 - FORWARD
2 - BACKWARD
3 - BOTH

PTOC8.Op

No.	Information		
1369	E/F 3I0p TRIP (EF 3I0p TRIP)	0	1
PTOC8.Op.general		0	1

device annunciation: 1 - ON
0 - OFF

IEC Status Op.general: 0 - FALSE
1 - TRUE

3.6 Earth fault detection in non-earthed systems (PSDE1)

PSDE1.Str.dirGeneral

No.	Information								
1276	Sensitive E/F detection Forward (SenseEF Forward)	1	1	1	1	0	0	0	0
1277	Sensitive E/F detection Reverse (SenseEF Reverse)	1	1	0	0	1	1	0	0
1278	Sensitive E/F detection Undef. Direction (SenseEF undefDir)	1	0	1	0	1	0	1	0
PSDE1.Mod.dirGeneral		0	3	0	1	0	2	0	0

device annunciation: 1 - ON
0 - OFF

IEC Status Str.dirGeneral: 0 - UNKNOWN
1 - FORWARD
2 - BACKWARD
3 - BOTH

PSDE1.Str.phsA

No.	Information		
1272	Sensitive E/F detection Phase L1 (SenseEF Phase L1)	0	1
PSDE1.Str.phsA		0	1

device annunciation: 1 - ON
0 - OFF

IEC Status Str.phsA: 0 - FALSE
1 - TRUE

PSDE1.Str.dirPhsA

No.	Information																
1276	Sensitive E/F detection Forward (SenseEF Forward)	1	1	1	1	1	1	1	1	0	0	0	0	0	0	0	
1277	Sensitive E/F detection Reverse (SenseEF Reverse)	1	1	1	1	0	0	0	0	1	1	1	1	0	0	0	
1278	Sensitive E/F detection Undef. Direction (SenseEF undefDir)	1	1	0	0	1	1	0	0	1	1	0	0	1	1	0	
1272	Sensitive E/F detection Phase L1 (SenseEF Phase L1)	1	0	1	0	1	0	1	0	1	0	1	0	1	0	1	
PSDE1.Str.dirPhsA		0	0	0	0	0	0	1	0	0	0	2	0	0	0	0	

device annunciation: 1 - ON
0 - OFF

IEC Status Str.dirPhsA: 0 - UNKNOWN
1 - FORWARD
2 - BACKWARD

PSDE1.Str.dirPhsC

No.	Information																
1276	Sensitive E/F detection Forward (SenseF Forward)	1	1	1	1	1	1	1	1	0	0	0	0	0	0	0	0
1277	Sensitive E/F detection Reverse (SenseF Reverse)	1	1	1	1	0	0	0	0	1	1	1	1	0	0	0	0
1278	Sensitive E/F detection Undef. Direction (SenseF undefDir)	1	1	0	0	1	1	0	0	1	1	0	0	1	1	0	0
1274	Sensitive E/F detection Phase L3 (SenseF Phase L3)	1	0	1	0	1	0	1	0	1	0	1	0	1	0	1	0
PSDE1.Str.dirPhsC		0	0	0	0	0	0	1	0	0	0	2	0	0	0	0	

device annunciation:
1 - ON
0 - OFF
t

IEC Status Str.dirPhsC:
0 - UNKNOWN
1 - FORWARD
2 - BACKWARD

PSDE1.Op

No.	Information		
1281	Sensitive E/F detection TRIP command (SenseF TRIP)	0	1
PSDE1.Op.general		0	1

device annunciation:
1 - ON
0 - OFF

IEC Status Op.general:
0 - FALSE
1 - TRUE

3.7 Restricted earth fault protection (PDIF3)

PDIF3.Mod

No.	Information							
5813	Restricted earth fault is ACTIVE (REF ACTIVE)	x	0	1	1	1	1	1
5812	Restricted earth fault is BLOCKED (REF BLOCKED)	x	x	0	1	x	x	x
5811	Restricted earth fault is switched OFF (REF OFF)	1	0	0	0	0	0	0
290	Alarm: Broken current-wire detected L1 (Broken Iwire L1)	x	x	0	0	1	x	x
291	Alarm: Broken current-wire detected L2 (Broken Iwire L2)	x	x	0	0	x	1	x
292	Alarm: Broken current-wire detected L3 (Broken Iwire L3)	x	x	0	0	x	x	1
PDIF3.Mod.stVal		5	5	1	2	2	2	2

device annunciation / setting: 1 - ON / TRUE
0 - OFF / FALSE
x - irrelevant

IEC Status Mod.stVal:

1 - ON
2 - BLOCKED
3 - TEST
4 - TEST/BLOCKED
5 - OFF

PDIF3.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PDIF3.Health.stVal		3	1

device annunciation:

1 - ON
0 - OFF

IEC Status Health.stVal:

1 - OK
2 - WARNING
3 - ALARM

3.7 Restricted earth fault protection (PDIF3)

PDIF3.Str

No.	Information		
5817	Restr. earth flt.: picked up (REF picked up)	0	1
PDIF3.Str.general		0	1

device annunciation: 1 - ON IEC Status Str.general: 0 - FALSE
0 - OFF 1 - TRUE

PDIF3.Str.dirGeneral

No.	Information	
PDIF3.Str.dirGeneral		1

device annunciation: 1 - ON IEC Status Str.dirGeneral: 0 - UNKNOWN
0 - OFF 1 - FORWARD
x - irrelevant 2 - BACKWARD
3 - BOTH

PDIF3.Op

No.	Information		
5821	Restr. earth flt.: TRIP (REF TRIP)	0	1
PDIF3.Op.general		0	1

device annunciation: 1 - ON IEC Status Op.general: 0 - FALSE
0 - OFF 1 - TRUE

PDIF3.DifAClc

No.	Information	Value		
30654	ldiff REF(% Operational nominal current) (ldiffREF=)	PDIF3.DifAClc.cVal.mag.f	Measured value	Absolute value
		PDIF3.DifAClc.units.SIUnit		
		PDIF3.DifAClc.units.multiplier		

PDIF3.RstA

No.	Information	Value		
30655	Irest REF(% Operational nominal current) (IrestREF=)	PDIF3.RstA.cVal.mag.f	Measured value	Absolute value
		PDIF3.RstA.units.SIUnit		
		PDIF3.RstA.units.multiplier		

3.8 Overcurrent protection (PTOCx)

PTOC1.Op

No.	Information		
7223	Backup O/C TRIP Ip (O/C TRIP Ip)	0	1
PTOC1.Op.general		0	1

device annunciation: 1 - ON
0 - OFF

IEC Status Op.general: 0 - FALSE
1 - TRUE

3.8.2 O/C I> (PTOC2)

PTOC2.Mod

No.	Information										
7153	Backup O/C is ACTIVE (O/C ACTIVE)	x	x	0	0	0	1	1	1	1	
7152	Backup O/C is BLOCKED (O/C BLOCK)	x	x	0	1	1	0	0	1	1	
7105	>BLOCK Backup OverCurrent I> (>BLOCK O/C I>)	x	x	1	0	1	0	1	0	1	
7151	Backup O/C is switched OFF (O/C OFF)	1	x	0	0	0	0	0	0	0	
	Operating Mode (P2601) = OFF or Iph> (P2620) and 3I0> (P2622) = ∞	x	1	0	0	0	0	0	0	0	
PTOC2.Mod.stVal		5	5	2	2	2	1	2	2	2	

device annunciation / setting: 1 - ON / TRUE
0 - OFF / FALSE
x - irrelevant

IEC Status Mod.stVal: 1 - ON
2 - BLOCKED
3 - TEST
4 - TEST/BLOCKED
5 - OFF

PTOC2.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTOC2.Health.stVal		3	1

device annunciation: 1 - ON
0 - OFF

IEC Status Health.stVal: 1 - OK
2 - WARNING
3 - ALARM

3.8.4 O/C I>>> (PTOC4)

PTOC4.Mod

No.	Information																	
7153	Backup O/C is ACTIVE (O/C ACTIVE)	x	x	0	0	0	0	0	0	0	0	1	1	1	1	1	1	1
7152	Backup O/C is BLOCKED (O/C BLOCK)	x	x	0	0	1	1	1	1	0	0	0	0	1	1	1	1	1
7130	>BLOCK I-STUB (>BLOCK I-STUB)	x	x	1	1	0	0	1	1	0	0	1	1	0	0	1	1	
7131	>Enable I-STUB-Bus function (>I-STUB ENABLE)	x	x	0	1	0	1	0	1	0	1	0	1	0	1	0	1	
7151	Backup O/C is switched OFF (O/C OFF)	1	x	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	Operating Mode (P2601) = OFF or Iph>>> (P2630) and 3I0>>> PICKUP (P2632) = ∞	x	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
PTOC4.Mod.stVal		5	5	2	2	2	2	2	2	2	2	1	2	2	2	2	2	

device annunciation / setting: 1 - ON / TRUE
0 - OFF / FALSE
x - irrelevant

IEC Status Mod.stVal:

1 - ON
2 - BLOCKED
3 - TEST
4 - TEST/BLOCKED
5 - OFF

PTOC4.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTOC4.Health.stVal		3	1

device annunciation: 1 - ON
0 - OFF

IEC Status Health.stVal:

1 - OK
2 - WARNING
3 - ALARM

3.8 Overcurrent protection (PTOCx)

PTOC10.Str

No.	Information		
7202	Backup O/C Pickup I> directional (O/C PICK. I>Dir)	0	1
PTOC10.Str.general		0	1

device annunciation: 1 - ON IEC Status Str.general: 0 - FALSE
0 - OFF 1 - TRUE

PTOC10.Str.dirGeneral

No.	Information					
7202	Backup O/C Pickup I> directional (O/C PICK. I>Dir)	0	1	1	1	1
7248	Backup O/C forward direction (O/C Dir.forward)	x	0	0	1	1
7249	Backup O/C reverse direction (O/C Dir.reverse)	x	0	1	0	1
PTOC10.Str.dirGeneral		0	0	2	1	3

device annunciation: 1 - ON IEC Status Str.dirGeneral: 0 - UNKNOWN
0 - OFF 1 - FORWARD
x - irrelevant 2 - BACKWARD
3 - BOTH

PTOC10.Op

No.	Information		
7236	Backup O/C TRIP I> directional (O/C TRIP I>Dir.)	0	1
PTOC10.Op.general		0	1

device annunciation: 1 - ON IEC Status Op.general: 0 - FALSE
0 - OFF 1 - TRUE

RSYN1.DifVClc

No.	Information		Value	
636	U-diff (line-bus) (Udiff =)	RSYN1.DifVClc.mag.f	Measured value	Absolute value
		RSYN1.DifVClc.units.SIUnit	29	V (Volt)
		RSYN1.DifVClc.units.multiplier	3	Kilo

RSYN1.DifHzClc

No.	Information		Value	
647	Frequency (difference line-bus) (F-diff=)	RSYN1.DifHzClc.mag.f	Measured value	Absolute value
		RSYN1.DifHzClc.units.SIUnit	33	Hz
		RSYN1.DifHzClc.units.multiplier	0	1

RSYN1.DifAngClc

No.	Information		Value	
648	Angle (difference line-bus) (φ -diff=)	RSYN1.DifAngClc.mag.f	Measured value	Absolute value
		RSYN1.DifAngClc.units.SIUnit	9	° (Degree)
		RSYN1.DifAngClc.units.multiplier	0	1

PTUV1.Str.phsA

No.	Information		
10318	Uph-e< Pickup L1 (Uph-e< PU L1)	0	1
PTUV1.Str.phsA		0	1

device annunciation: 1 - ON IEC Status Str.phsA: 0 - FALSE
0 - OFF 1 - TRUE

PTUV1.Str.phsB

No.	Information		
10319	Uph-e< Pickup L2 (Uph-e< PU L2)	0	1
PTUV1.Str.phsB		0	1

device annunciation: 1 - ON IEC Status Str.phsB: 0 - FALSE
0 - OFF 1 - TRUE

PTUV1.Str.phsC

No.	Information		
10320	Uph-e< Pickup L3 (Uph-e< PU L3)	0	1
PTUV1.Str.phsC		0	1

device annunciation: 1 - ON IEC Status Str.phsC: 0 - FALSE
0 - OFF 1 - TRUE

PTUV1.Op

No.	Information				
10317	Uph-e<(<) TRIP command (Uph-e<(<) TRIP)	0	0	1	1
10315	Uph-e< TimeOut (Uph-e< TimeOut)	0	1	0	1
PTUV1.Op.general		0	0	0	1

device annunciation: 1 - ON IEC Status Op.general: 0 - FALSE
0 - OFF 1 - TRUE

PTUV2.Str.phsA

No.	Information		
10321	Uph-e<< Pickup L1 (Uph-e<< PU L1)	0	1
PTUV2.Str.phsA		0	1

device annunciation: 1 - ON IEC Status Str.phsA: 0 - FALSE
0 - OFF 1 - TRUE

PTUV2.Str.phsB

No.	Information		
10322	Uph-e<< Pickup L2 (Uph-e<< PU L2)	0	1
PTUV2.Str.phsB		0	1

device annunciation: 1 - ON IEC Status Str.phsB: 0 - FALSE
0 - OFF 1 - TRUE

PTUV2.Str.phsC

No.	Information		
10323	Uph-e<< Pickup L3 (Uph-e<< PU L3)	0	1
PTUV2.Str.phsC		0	1

device annunciation: 1 - ON IEC Status Str.phsC: 0 - FALSE
0 - OFF 1 - TRUE

PTUV2.Op

No.	Information				
10317	Uph-e<(<) TRIP command (Uph-e<(<) TRIP)	0	0	1	1
10316	Uph-e<< TimeOut (Uph-e<< TimeOut)	0	1	0	1
PTUV2.Op.general		0	0	0	1

device annunciation: 1 - ON IEC Status Op.general: 0 - FALSE
0 - OFF 1 - TRUE

PTUV3.Str.phsA

No.	Information				
10327	Uphph<(<) Pickup L1-L2 (Uphph<(<)PU L12)	0	0	1	1
10329	Uphph<(<) Pickup L3-L1 (Uphph<(<)PU L31)	0	1	0	1
PTUV3.Str.phsA		0	1	1	1

device annunciation: 1 - ON IEC Status Str.phsA: 0 - FALSE
0 - OFF 1 - TRUE

PTUV3.Str.phsB

No.	Information				
10327	Uphph<(<) Pickup L1-L2 (Uphph<(<)PU L12)	0	0	1	1
10328	Uphph<(<) Pickup L2-L3 (Uphph<(<)PU L23)	0	1	0	1
PTUV3.Str.phsB		0	1	1	1

device annunciation: 1 - ON IEC Status Str.phsB: 0 - FALSE
0 - OFF 1 - TRUE

PTUV3.Str.phsC

No.	Information				
10328	Uphph<(<) Pickup L2-L3 (Uphph<(<)PU L23)	0	0	1	1
10329	Uphph<(<) Pickup L3-L1 (Uphph<(<)PU L31)	0	1	0	1
PTUV3.Str.phsC		0	1	1	1

device annunciation: 1 - ON IEC Status Str.phsC: 0 - FALSE
0 - OFF 1 - TRUE

PTUV3.Op

No.	Information				
10332	Uphph<(<) TRIP command (Uphph<(<) TRIP)	0	0	1	1
10330	Uphph< TimeOut (Uphph< TimeOut)	0	1	0	1
PTUV3.Op.general		0	0	0	1

device annunciation: 1 - ON IEC Status Op.general: 0 - FALSE
0 - OFF 1 - TRUE

3.11.4 Undervoltage protection Uphph<< (PTUV4)

PTUV4.Mod

No.	Information			
10228	Uphph<(<) Undervolt. is BLOCKED (Uph-ph<(<) BLK)	0	0	1
	Uph-ph<(<) (P3761) = OFF or Uph-ph<< (P3764) = 0	0	1	0
PTUV4.Mod.stVal		1	5	2

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
 0 - OFF / FALSE 2 - BLOCKED
 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

PTUV4.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTUV4.Health.stVal		3	1

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
 0 - OFF 2 - WARNING
 3 - ALARM

PTUV4.Str

No.	Information					
10326	Uph-ph<< Pickup (Uph-ph<< Pickup)	0	1	1	1	1
10327	Uphph<(<) Pickup L1-L2 (Uphph<(<)PU L12)	0	x	1	x	x
10328	Uphph<(<) Pickup L2-L3 (Uphph<(<)PU L23)	0	x	x	1	x
10329	Uphph<(<) Pickup L3-L1 (Uphph<(<)PU L31)	0	x	x	x	1
PTUV4.Str.general		0	1	1	1	1

device annunciation: 1 - ON IEC Status Str.general: 0 - FALSE
 0 - OFF 1 - TRUE
 x - irrelevant

PTUV4.Str.phsA

No.	Information				
10327	Uphph(<) Pickup L1-L2 (Uphph(<)PU L12)	0	0	1	1
10329	Uphph(<) Pickup L3-L1 (Uphph(<)PU L31)	0	1	0	1
PTUV4.Str.phsA		0	1	1	1

device annunciation: 1 - ON IEC Status Str.phsA: 0 - FALSE
 0 - OFF 1 - TRUE

PTUV4.Str.phsB

No.	Information				
10327	Uphph(<) Pickup L1-L2 (Uphph(<)PU L12)	0	0	1	1
10328	Uphph(<) Pickup L2-L3 (Uphph(<)PU L23)	0	1	0	1
PTUV4.Str.phsB		0	1	1	1

device annunciation: 1 - ON IEC Status Str.phsB: 0 - FALSE
 0 - OFF 1 - TRUE

PTUV4.Str.phsC

No.	Information				
10328	Uphph(<) Pickup L2-L3 (Uphph(<)PU L23)	0	0	1	1
10329	Uphph(<) Pickup L3-L1 (Uphph(<)PU L31)	0	1	0	1
PTUV4.Str.phsC		0	1	1	1

device annunciation: 1 - ON IEC Status Str.phsC: 0 - FALSE
 0 - OFF 1 - TRUE

PTUV4.Op

No.	Information				
10332	Uphph(<) TRIP command (Uphph(<) TRIP)	0	0	1	1
10331	Uphph<< TimeOut (Uphph<< TimeOut)	0	1	0	1
PTUV4.Op.general		0	0	0	1

device annunciation: 1 - ON IEC Status Op.general: 0 - FALSE
 0 - OFF 1 - TRUE

3.11.5 Undervoltage protection U1< (PTUV5)

PTUV5.Mod

No.	Information			
10230	U1<(<) Undervolt. is BLOCKED (U1<(<) BLK)	0	0	1
	U1<(<) (P3771) = OFF or U1< (P3772) = 0	0	1	0
PTUV5.Mod.stVal		1	5	2

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
0 - OFF / FALSE 2 - BLOCKED
3 - TEST
4 - TEST/BLOCKED
5 - OFF

PTUV5.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTUV5.Health.stVal		3	1

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
0 - OFF 2 - WARNING
3 - ALARM

PTUV5.Str

No.	Information		
10300	U1< Pickup (U1< Pickup)	0	1
PTUV5.Str.general		0	1

device annunciation: 1 - ON IEC Status Str.general: 0 - FALSE
0 - OFF 1 - TRUE

PTUV5.Op

No.	Information				
10304	U1<(<) TRIP command (U1<(<) TRIP)	0	0	1	1
10302	U1< TimeOut (U1< TimeOut)	0	1	0	1
PTUV5.Op.general		0	0	0	1

device annunciation: 1 - ON IEC Status Op.general: 0 - FALSE
0 - OFF 1 - TRUE

3.11.6 Undervoltage protection U1<< (PTUV6)

PTUV6.Mod

No.	Information			
10230	U1<(<) Undervolt. is BLOCKED (U1<(<) BLK)	0	0	1
	U1<(<) (P3771) = OFF or U1<< (P3774) = 0	0	1	0
PTUV6.Mod.stVal		1	5	2

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
 0 - OFF / FALSE 2 - BLOCKED
 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

PTUV6.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTUV6.Health.stVal		3	1

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
 0 - OFF 2 - WARNING
 3 - ALARM

PTUV6.Str

No.	Information		
10301	U1<< Pickup (U1<< Pickup)	0	1
PTUV6.Str.general		0	1

device annunciation: 1 - ON IEC Status Str.general: 0 - FALSE
 0 - OFF 1 - TRUE

PTUV6.Op

No.	Information				
10304	U1<(<) TRIP command (U1<(<) TRIP)	0	0	1	1
10303	U1<< TimeOut (U1<< TimeOut)	0	1	0	1
PTUV6.Op.general		0	0	0	1

device annunciation: 1 - ON IEC Status Op.general: 0 - FALSE
 0 - OFF 1 - TRUE

3.11.7 Overvoltage protection Uph> (PTOV1)

PTOV1.Mod

No.	Information			
10216	Uph-e>(>) Overvolt. is BLOCKED (Uph-e>(>) BLK)	0	0	1
	Uph-e>(>) (P3701) = OFF or Uph-e> (P3702) = ∞	0	1	0
PTOV1.Mod.stVal		1	5	2

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
 0 - OFF / FALSE 2 - BLOCKED
 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

PTOV1.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTOV1.Health.stVal		3	1

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
 0 - OFF 2 - WARNING
 3 - ALARM

PTOV1.Str

No.	Information					
10240	Uph-e> Pickup (Uph-e> Pickup)	0	1	1	1	1
10248	Uph-e> Pickup L1 (Uph-e> PU L1)	0	x	1	x	x
10249	Uph-e> Pickup L2 (Uph-e> PU L2)	0	x	x	1	x
10250	Uph-e> Pickup L3 (Uph-e> PU L3)	0	x	x	x	1
PTOV1.Str.general		0	1	1	1	1

device annunciation: 1 - ON IEC Status Str.general: 0 - FALSE
 0 - OFF 1 - TRUE
 x - irrelevant

3.11.8 Overvoltage protection Uph-e>> (PTOV2)

PTOV2.Mod

No.	Information			
10216	Uph-e>(>) Overvolt. is BLOCKED (Uph-e>(>) BLK)	0	0	1
	Uph-e>(>) (P3701) = OFF or Uph-e>> (P3704) = ∞	0	1	0
PTOV2.Mod.stVal		1	5	2

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
 0 - OFF / FALSE 2 - BLOCKED
 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

PTOV2.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTOV2.Health.stVal		3	1

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
 0 - OFF 2 - WARNING
 3 - ALARM

PTOV2.Str

No.	Information					
10241	Uph-e>> Pickup (Uph-e>> Pickup)	0	1	1	1	1
10242	Uph-e>(>) Pickup L1 (Uph-e>(>) PU L1)	0	x	1	x	x
10243	Uph-e>(>) Pickup L2 (Uph-e>(>) PU L2)	0	x	x	1	x
10244	Uph-e>(>) Pickup L3 (Uph-e>(>) PU L3)	0	x	x	x	1
PTOV2.Str.general		0	1	1	1	1

device annunciation: 1 - ON IEC Status Str.general: 0 - FALSE
 0 - OFF 1 - TRUE
 x - irrelevant

PTOV2.Str.phsA

No.	Information		
10242	Uph-e>(>) Pickup L1 (Uph-e>(>) PU L1)	0	1
PTOV2.Str.phsA		0	1

device annunciation: 1 - ON IEC Status Str.phsA: 0 - FALSE
 0 - OFF 1 - TRUE

PTOV2.Str.phsB

No.	Information		
10243	Uph-e>(>) Pickup L2 (Uph-e>(>) PU L2)	0	1
PTOV2.Str.phsB		0	1

device annunciation: 1 - ON IEC Status Str.phsB: 0 - FALSE
 0 - OFF 1 - TRUE

PTOV2.Str.phsC

No.	Information		
10244	Uph-e>(>) Pickup L3 (Uph-e>(>) PU L3)	0	1
PTOV2.Str.phsC		0	1

device annunciation: 1 - ON IEC Status Str.phsC: 0 - FALSE
 0 - OFF 1 - TRUE

PTOV2.Op

No.	Information				
10247	Uph-e>(>) TRIP command (Uph-e>(>) TRIP)	0	0	1	1
10246	Uph-e>> TimeOut (Uph-e>> TimeOut)	0	1	0	1
PTOV2.Op.general		0	0	0	1

device annunciation: 1 - ON IEC Status Op.general: 0 - FALSE
 0 - OFF 1 - TRUE

PTOV3.Str.phsA

No.	Information				
10257	Uph-ph>(>) Pickup L1-L2 (Uphph>(>)PU L12)	0	0	1	1
10259	Uph-ph>(>) Pickup L3-L1 (Uphph>(>)PU L31)	0	1	0	1
PTOV3.Str.phsA		0	1	1	1

device annunciation: 1 - ON IEC Status Str.phsA: 0 - FALSE
0 - OFF 1 - TRUE

PTOV3.Str.phsB

No.	Information				
10257	Uph-ph>(>) Pickup L1-L2 (Uphph>(>)PU L12)	0	0	1	1
10258	Uph-ph>(>) Pickup L2-L3 (Uphph>(>)PU L23)	0	1	0	1
PTOV3.Str.phsB		0	1	1	1

device annunciation: 1 - ON IEC Status Str.phsB: 0 - FALSE
0 - OFF 1 - TRUE

PTOV3.Str.phsC

No.	Information				
10258	Uph-ph>(>) Pickup L2-L3 (Uphph>(>)PU L23)	0	0	1	1
10259	Uph-ph>(>) Pickup L3-L1 (Uphph>(>)PU L31)	0	1	0	1
PTOV3.Str.phsC		0	1	1	1

device annunciation: 1 - ON IEC Status Str.phsC: 0 - FALSE
0 - OFF 1 - TRUE

PTOV3.Op

No.	Information				
10262	Uph-ph>(>) TRIP command (Uphph>(>) TRIP)	0	0	1	1
10260	Uph-ph> TimeOut (Uphph> TimeOut)	0	1	0	1
PTOV3.Op.general		0	0	0	1

device annunciation: 1 - ON IEC Status Op.general: 0 - FALSE
0 - OFF 1 - TRUE

3.11.10 Overvoltage protection Uphph>> (PTOV4)

PTOV4.Mod

No.	Information			
10218	Uph-ph>(>) Overvolt. is BLOCKED (Uph-ph>(>) BLK)	0	0	1
	Uph-ph>(>) (P3711) = OFF or Uph-ph>> (P3714) = ∞	0	1	0
PTOV4.Mod.stVal		1	5	2

device annunciation / setting:

1 - ON / TRUE
0 - OFF / FALSE

IEC Status Mod.stVal:

1 - ON
2 - BLOCKED
3 - TEST
4 - TEST/BLOCKED
5 - OFF

PTOV4.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTOV4.Health.stVal		3	1

device annunciation:

1 - ON
0 - OFF

IEC Status Health.stVal:

1 - OK
2 - WARNING
3 - ALARM

PTOV4.Str

No.	Information					
10256	Uph-ph>> Pickup (Uphph>> Pickup)	0	1	1	1	1
10266	Uph-ph>> Pickup L1-L2 (Uphph>> PU L12)	0	x	1	x	x
10267	Uph-ph>> Pickup L2-L3 (Uphph>> PU L23)	0	x	x	1	x
10268	Uph-ph>> Pickup L3-L1 (Uphph>> PU L31)	0	x	x	x	1
PTOV4.Str.general		0	1	1	1	1

device annunciation:

1 - ON
0 - OFF
x - irrelevant

IEC Status Str.general:

0 - FALSE
1 - TRUE

PTOV4.Str.phsA

No.	Information				
10266	Uph-ph>> Pickup L1-L2 (Uphph>> PU L12)	0	0	1	1
10268	Uph-ph>> Pickup L3-L1 (Uphph>> PU L31)	0	1	0	1
PTOV4.Str.phsA		0	1	1	1

device annunciation: 1 - ON IEC Status Str.phsA: 0 - FALSE
0 - OFF 1 - TRUE

PTOV4.Str.phsB

No.	Information				
10266	Uph-ph>> Pickup L1-L2 (Uphph>> PU L12)	0	0	1	1
10267	Uph-ph>> Pickup L2-L3 (Uphph>> PU L23)	0	1	0	1
PTOV4.Str.phsB		0	1	1	1

device annunciation: 1 - ON IEC Status Str.phsB: 0 - FALSE
0 - OFF 1 - TRUE

PTOV4.Str.phsC

No.	Information				
10267	Uph-ph>> Pickup L2-L3 (Uphph>> PU L23)	0	0	1	1
10268	Uph-ph>> Pickup L3-L1 (Uphph>> PU L31)	0	1	0	1
PTOV4.Str.phsC		0	1	1	1

device annunciation: 1 - ON IEC Status Str.phsC: 0 - FALSE
0 - OFF 1 - TRUE

PTOV4.Op

No.	Information				
10262	Uph-ph>(>) TRIP command (Uphph>(>) TRIP)	0	0	1	1
10261	Uph-ph>> TimeOut (Uphph>> TimeOut)	0	1	0	1
PTOV4.Op.general		0	0	0	1

device annunciation: 1 - ON IEC Status Op.general: 0 - FALSE
0 - OFF 1 - TRUE

3.11.12 Overvoltage protection 3U0>> (PTOV6)

PTOV6.Mod

No.	Information			
10220	3U0>(>) Overvolt. is BLOCKED (3U0>(>) BLK)	0	0	1
	3U0>(>) (or Ux) (P3721) = OFF or 3U0>> (P3724) = ∞	0	1	0
PTOV6.Mod.stVal		1	5	2

device annunciation / setting: 1 - ON / TRUE
0 - OFF / FALSE

IEC Status Mod.stVal:

1 - ON
2 - BLOCKED
3 - TEST
4 - TEST/BLOCKED
5 - OFF

PTOV6.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTOV6.Health.stVal		3	1

device annunciation: 1 - ON
0 - OFF

IEC Status Health.stVal:

1 - OK
2 - WARNING
3 - ALARM

PTOV6.Str

No.	Information		
10271	3U0>> Pickup (3U0>> Pickup)	0	1
PTOV6.Str.general		0	1

device annunciation: 1 - ON
0 - OFF

IEC Status Str.general:

0 - FALSE
1 - TRUE

PTOV6.Op

No.	Information				
10274	3U0>(>) TRIP command (3U0>(>) TRIP)	0	0	1	1
10273	3U0>> TimeOut (3U0>> TimeOut)	0	1	0	1
PTOV6.Op.general		0	0	0	1

device annunciation: 1 - ON
0 - OFF

IEC Status Op.general:

0 - FALSE
1 - TRUE

3.11.15 Overvoltage protection U2> (PTOV9)

PTOV9.Mod

No.	Information			
10224	U2>(>) Overvolt. is BLOCKED (U2>(>) BLK)	0	0	1
	U2>(>) (P3741) = OFF or U2> (P3742) = ∞	0	1	0
PTOV9.Mod.stVal		1	5	2

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
0 - OFF / FALSE 2 - BLOCKED
3 - TEST
4 - TEST/BLOCKED
5 - OFF

PTOV9.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTOV9.Health.stVal		3	1

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
0 - OFF 2 - WARNING
3 - ALARM

PTOV9.Str

No.	Information		
10290	U2> Pickup (U2> Pickup)	0	1
PTOV9.Str.general		0	1

device annunciation: 1 - ON IEC Status Str.general: 0 - FALSE
0 - OFF 1 - TRUE

PTOV9.Op

No.	Information				
10294	U2>(>) TRIP command (U2>(>) TRIP)	0	0	1	1
10292	U2> TimeOut (U2> TimeOut)	0	1	0	1
PTOV9.Op.general		0	0	0	1

device annunciation: 1 - ON IEC Status Op.general: 0 - FALSE
0 - OFF 1 - TRUE

3.12 Frequency protection (PTUFx, PTOFx)

3.12.1 Underfrequency protection FQS stage f1 (PTUF1)

PTUF1.Mod

No.	Information						
5212	Frequency protection is BLOCKED (Freq. BLOCKED)	x	x	0	1	x	x
5206	>BLOCK frequency protection stage f1 (>BLOCK f1)	x	x	0	x	1	x
5215	Frequency protection undervoltage Blk (Freq UnderV Blk)	x	x	0	x	x	1
	O/U FREQ. f1 (P3601) = ON and f1 PICKUP (P3602/3603) < Rated Frequency (P230)	x	0	1	1	1	1
	O/U FREQ. f1 (P3601) =OFF or f1 PICKUP (P3602/3603) = Rated Frequency (P230)	1	0	0	0	0	0
PTUF1.Mod.stVal		5	5	1	2	2	2

device annunciation / setting: 1 - ON / TRUE
 0 - OFF / FALSE
 x - irrelevant

IEC Status Mod.stVal: 1 - ON
 2 - BLOCKED
 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

PTUF1.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTUF1.Health.stVal		3	1

device annunciation: 1 - ON
 0 - OFF

IEC Status Health.stVal: 1 - OK
 2 - WARNING
 3 - ALARM

PTUF1.Str

No.	Information				
5232	Frequency protection: f1 picked up (f1 picked up)	0	0	1	1
	O/U FREQ. f1 P3601) = ON and f1 PICKUP (P3602/3603) < Rated Frequency (P230)	0	1	0	1
PTUF1.Str.general		0	0	0	1

device annunciation / setting: 1 - ON / TRUE IEC Status Str.general: 0 - FALSE
0 - OFF / FALSE 1 - TRUE

PTUF1.Op

No.	Information				
5236	Frequency protection: f1 TRIP (f1 TRIP)	0	0	1	1
	O/U FREQ. f1 P3601) = ON and f1 PICKUP (P3602/3603) < Rated Frequency (P230)	0	1	0	1
PTUF1.Op.general		0	0	0	1

device annunciation / setting: 1 - ON / TRUE IEC Status Op.general: 0 - FALSE
0 - OFF / FALSE 1 - TRUE

3.12.2 Underfrequency protection FQS stage f2 (PTUF2)

PTUF2.Mod

No.	Information						
5212	Frequency protection is BLOCKED (Freq. BLOCKED)	x	x	0	1	x	x
5207	>BLOCK frequency protection stage f2 (>BLOCK f2)	x	x	0	x	1	x
5215	Frequency protection undervoltage Blk (Freq UnderV Blk)	x	x	0	x	x	1
	O/U FREQ. f2 (P3611) = ON and f2 PICKUP (P3612/3613) < Rated Frequency (P230)	x	0	1	1	1	1
	O/U FREQ. f2 (P3611) = OFF or f2 PICKUP (P3612/3613) = Rated Frequency (P230)	1	0	0	0	0	0
PTUF2.Mod.stVal		5	5	1	2	2	2

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
 0 - OFF / FALSE 2 - BLOCKED
 x - irrelevant 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

PTUF2.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTUF2.Health.stVal		3	1

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
 0 - OFF 2 - WARNING
 3 - ALARM

PTUF2.Str

No.	Information				
5233	Frequency protection: f2 picked up (f2 picked up)	0	0	1	1
	O/U FREQ. f2 (P3611) = ON and f2 PICKUP (P3612/3613) < Rated Frequency (P230)	0	1	0	1
PTUF2.Str.general		0	0	0	1

device annunciation / setting: 1 - ON / TRUE IEC Status Str.general: 0 - FALSE
 0 - OFF / FALSE 1 - TRUE

PTUF2.Op

No.	Information				
5237	Frequency protection: f2 TRIP (f2 TRIP)	0	0	1	1
	O/U FREQ. f2 (P3611)= ON and f2 PICKUP (P3612/3613) < Rated Frequency (P230)	0	1	0	1
PTUF2.Op.general		0	0	0	1

device annunciation / setting: 1 - ON / TRUE IEC Status Op.general: 0 - FALSE
 0 - OFF / FALSE 1 - TRUE

3.12.3 Underfrequency protection FQS stage f3 (PTUF3)

PTUF3.Mod

No.	Information						
5212	Frequency protection is BLOCKED (Freq. BLOCKED)	x	x	0	1	x	x
5208	>BLOCK frequency protection stage f3 (>BLOCK f3)	x	x	0	x	1	x
5215	Frequency protection undervoltage Blk (Freq UnderV Blk)	x	x	0	x	x	1
	O/U FREQ. f3 (P3621) = ON and f3 PICKUP (P3622/3623) < Rated Frequency (P230)	x	0	1	1	1	1
	O/U FREQ. f3 (P3621) = OFF or f3PICKUP (P3622/3623) = Rated Frequency (P230)	1	0	0	0	0	0
PTUF3.Mod.stVal		5	5	1	2	2	2

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
0 - OFF / FALSE 2 - BLOCKED
x - irrelevant 3 - TEST
4 - TEST/BLOCKED
5 - OFF

PTUF3.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTUF3.Health.stVal		3	1

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
0 - OFF 2 - WARNING
3 - ALARM

PTUF3.Str

No.	Information				
5234	Frequency protection: f3 picked up (f3 picked up)	0	0	1	1
	O/U FREQ. f3 (P3621) = ON and f3 PICKUP (P3622/3623) < Rated Frequency (P230)	0	1	0	1
PTUF3.Str.general		0	0	0	1

device annunciation / setting: 1 - ON / TRUE IEC Status Str.general: 0 - FALSE
0 - OFF / FALSE 1 - TRUE

PTUF3.Op

No.	Information				
5238	Frequency protection: f3 TRIP (f3 TRIP)	0	0	1	1
	O/U FREQ. f3 (P3621) = ON and f3 PICKUP (P3622/3623) < Rated Frequency (P230)	0	1	0	1
PTUF3.Op.general		0	0	0	1

device annunciation / setting: 1 - ON / TRUE IEC Status Op.general: 0 - FALSE
0 - OFF / FALSE 1 - TRUE

3.12.4 Underfrequency protection FQS stage f4 (PTUF4)

PTUF4.Mod

No.	Information						
5212	Frequency protection is BLOCKED (Freq. BLOCKED)	x	x	0	1	x	x
5209	>BLOCK frequency protection stage f4 (>BLOCK f4)	x	x	0	x	1	x
5215	Frequency protection undervoltage Blk (Freq UnderV Blk)	x	x	0	x	x	1
	O/U FREQ. f4 ON (P3631) and f4 PICKUP (P3632/3633) < Rated Frequency (P230)	x	0	1	1	1	1
	O/U FREQ. f4 (P3631) = OFF or f4 PICKUP (P3632/3633) = Rated Frequency (P230)	1	0	0	0	0	0
PTUF4.Mod.stVal		5	5	1	2	2	2

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
0 - OFF / FALSE 2 - BLOCKED
x - irrelevant 3 - TEST
4 - TEST/BLOCKED
5 - OFF

PTUF4.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTUF4.Health.stVal		3	1

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
0 - OFF 2 - WARNING
3 - ALARM

PTUF4.Str

No.	Information				
5235	Frequency protection: f4 picked up (f4 picked up)	0	0	1	1
	O/U FREQ. f4 (P3631)= ON and f4 PICKUP (P3632/3633) < Rated Frequency (P230)	0	1	0	1
PTUF4.Str.general		0	0	0	1

device annunciation / setting: 1 - ON / TRUE IEC Status Str.general: 0 - FALSE
 0 - OFF / FALSE 1 - TRUE

PTUF4.Op

No.	Information				
5239	Frequency protection: f4 TRIP (f4 TRIP)	0	0	1	1
	O/U FREQ. f4 (P3631) = ON and f4 PICKUP (P3632/3633) < Rated Frequency (P230)	0	1	0	1
PTUF4.Op.general		0	0	0	1

device annunciation / setting: 1 - ON / TRUE IEC Status Op.general: 0 - FALSE
 0 - OFF / FALSE 1 - TRUE

3.12.5 Overfrequency protection FQS stage f1 (PTOF1)

PTOF1.Mod

No.	Information						
5212	Frequency protection is BLOCKED (Freq. BLOCKED)	x	x	0	1	x	x
5206	>BLOCK frequency protection stage f1 (>BLOCK f1)	x	x	0	x	1	x
5215	Frequency protection undervoltage Blk (Freq UnderV Blk)	x	x	0	x	x	1
	O/U FREQ. f1 (P3601) = ON and f1 PICKUP (P3602/3603) < Rated Frequency (P230)	x	1	0	0	0	0
	O/U FREQ. f1 (P3601) = OFF or f1 PICKUP (P3602/3603) = Rated Frequency (P230)	1	0	0	0	0	0
PTOF1.Mod.stVal		5	5	1	2	2	2

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
 0 - OFF / FALSE 2 - BLOCKED
 x - irrelevant 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

PTOF1.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTOF1.Health.stVal		3	1

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
 0 - OFF 2 - WARNING
 3 - ALARM

PTOF1.Str

No.	Information				
5232	Frequency protection: f1 picked up (f1 picked up)	0	0	1	1
	O/U FREQ. f1 (P3601) = ON and f1 PICKUP (P3602/3603) > Rated Frequency (P230)	1	0	1	0
PTOF1.Str.general		0	0	1	0

device annunciation / setting: 1 - ON / TRUE IEC Status Str.general: 0 - FALSE
0 - OFF / FALSE 1 - TRUE

PTOF1.Op

No.	Information				
5236	Frequency protection: f1 TRIP (f1 TRIP)	0	0	1	1
	O/U FREQ. f1 (P3601) = ON and f1 PICKUP (P3602/3603) > Rated Frequency (P230)q	1	0	1	0
PTOF1.Op.general		0	0	1	0

device annunciation / setting: 1 - ON / TRUE IEC Status Op.general: 0 - FALSE
0 - OFF / FALSE 1 - TRUE

3.12.6 Overfrequency protection FQS stage f2 (PTOF2)

PTOF2.Mod

No.	Information						
5212	Frequency protection is BLOCKED (Freq. BLOCKED)	x	x	0	1	x	x
5207	>BLOCK frequency protection stage f2 (>BLOCK f2)	x	x	0	x	1	x
5215	Frequency protection undervoltage Blk (Freq UnderV Blk)	x	x	0	x	x	1
	O/U FREQ. f2 (P3611) = ON and f2 PICKUP (P3612/3613) < Rated Frequency (P230)	x	1	0	0	0	0
	O/U FREQ. f2 (P3611) = OFF or f2 PICKUP (P3612/3613) = Rated Frequency (P230)	1	0	0	0	0	0
PTOF2.Mod.stVal		5	5	1	2	2	2

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
 0 - OFF / FALSE 2 - BLOCKED
 x - irrelevant 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

PTOF2.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTOF2.Health.stVal		3	1

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
 0 - OFF 2 - WARNING
 3 - ALARM

PTOF2.Str

No.	Information				
5233	Frequency protection: f2 picked up (f2 picked up)	0	0	1	1
	O/U FREQ. f2 (P3611)= ON and f2 PICKUP (P3612/3613) > Rated Frequency (P230)	1	0	1	0
PTOF2.Str.general		0	0	1	0

device annunciation / setting: 1 - ON / TRUE IEC Status Str.general: 0 - FALSE
 0 - OFF / FALSE 1 - TRUE

PTOF2.Op

No.	Information				
5237	Frequency protection: f2 TRIP (f2 TRIP)	0	0	1	1
	O/U FREQ. f2 (P3611) = ON and f2 PICKUP (P3612/3613) > Rated Frequency (P230)	1	0	1	0
PTOF2.Op.general		0	0	1	0

device annunciation / setting: 1 - ON / TRUE IEC Status Op.general: 0 - FALSE
 0 - OFF / FALSE 1 - TRUE

3.12.7 Overfrequency protection FQS stage f3 (PTOF3)

PTOF3.Mod

No.	Information						
5212	Frequency protection is BLOCKED (Freq. BLOCKED)	x	x	0	1	x	x
5208	>BLOCK frequency protection stage f3 (>BLOCK f3)	x	x	0	x	1	x
5215	Frequency protection undervoltage Blk (Freq UnderV Blk)	x	x	0	x	x	1
	O/U FREQ. f3 (P3621) = ON and f3 PICKUP (P3622/3623) < Rated Frequency (P230)	x	1	0	0	0	0
	O/U FREQ. f3 (P3621)= OFF or f3 PICKUP (P3622/3623) = Rated Frequency (P230)	1	0	0	0	0	0
PTOF3.Mod.stVal		5	5	1	2	2	2

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
 0 - OFF / FALSE 2 - BLOCKED
 x - irrelevant 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

PTOF3.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTOF3.Health.stVal		3	1

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
 0 - OFF 2 - WARNING
 3 - ALARM

PTOF3.Str

No.	Information				
5234	Frequency protection: f3 picked up (f3 picked up)	0	0	1	1
	O/U FREQ. f3 (P3621) = ON and f3 PICKUP (P3622/3623) > Rated Frequency (P230)	1	0	1	0
PTOF3.Str.general		0	0	1	0

device annunciation / setting: 1 - ON / TRUE IEC Status Str.general: 0 - FALSE
 0 - OFF / FALSE 1 - TRUE

PTOF3.Op

No.	Information				
5238	Frequency protection: f3 TRIP (f3 TRIP)	0	0	1	1
	O/U FREQ. f3 (P3621) = ON and f3 PICKUP (P3622/3623) > Rated Frequency (P230)	1	0	1	0
PTOF3.Op.general		0	0	1	0

device annunciation / setting: 1 - ON / TRUE IEC Status Op.general: 0 - FALSE
 0 - OFF / FALSE 1 - TRUE

3.12.8 Overfrequency protection FQS stage f4 (PTOF4)

PTOF4.Mod

No.	Information						
5212	Frequency protection is BLOCKED (Freq. BLOCKED)	x	x	0	1	x	x
5209	>BLOCK frequency protection stage f4 (>BLOCK f4)	x	x	0	x	1	x
5215	Frequency protection undervoltage Blk (Freq UnderV Blk)	x	x	0	x	x	1
	O/U FREQ. f4 (P3631) = ON and f4 PICKUP (P3632/3633) < Rated Frequency (P230)	x	1	0	0	0	0
	O/U FREQ. f4 (P3631) = OFF or f4 PICKUP (P3632/3633) = Rated Frequency (P230)	1	0	0	0	0	0
PTOF4.Mod.stVal		5	5	1	2	2	2

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
0 - OFF / FALSE 2 - BLOCKED
x - irrelevant 3 - TEST
4 - TEST/BLOCKED
5 - OFF

PTOF4.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTOF4.Health.stVal		3	1

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
0 - OFF 2 - WARNING
3 - ALARM

PTOF4.Str

No.	Information				
5235	Frequency protection: f4 picked up (f4 picked up)	0	0	1	1
	O/U FREQ. f4 (P3631) = ON and f4 PICKUP (P3632/3633) > Rated Frequency (P230)	1	0	1	0
PTOF4.Str.general		0	0	1	0

device annunciation / setting: 1 - ON / TRUE IEC Status Str.general: 0 - FALSE
 0 - OFF / FALSE 1 - TRUE

PTOF4.Op

No.	Information				
5239	Frequency protection: f4 TRIP (f4 TRIP)	0	0	1	1
	O/U FREQ. f4 (P3631) = ON and f4 PICKUP (P3632/3633) > Rated Frequency (P230)	1	0	1	0
PTOF4.Op.general		0	0	1	0

device annunciation / setting: 1 - ON / TRUE IEC Status Op.general: 0 - FALSE
 0 - OFF / FALSE 1 - TRUE

RFLO1.FItZ

No.	Information	Value		
	Absolute value of the fault impedance	RFLO1.FItZ.cVal.mag.f	Measured value	Absolute value
		RFLO1.FItZ.units.SIUnit	30	Ω (Ohm)
		RFLO1.FItZ.units.multiplier	0	1
	Angle of the fault impedance	RFLO1.FItZ.cVal.ang.f	Measured value	Angle in °

RFLO1.FItDiskm

No.	Information	Value		
1119 or 1122	Fit Locator: Distance to fault (dist =)	RFLO1.FItDiskm.mag.f	Measured value	Absolute value
		RFLO1.FItDiskm.units.SIUnit	2	Meter or miles
		RFLO1.FItDiskm.units.multiplier	3	Kilo

RFLO1.FItDisPrc

No.	Information	Value		
1120	Fit Locator: Distance [%] to fault (d[%] =)	RFLO1.FItDisPrc.mag.f	Measured value	Absolute value
		RFLO1.FItDisPrc.units.SIUnit	1	NONE
		RFLO1.FItDisPrc.multiplier	0	1

3.14 Circuit breaker failure protection (RBRF1)

RBRF1.Mod

No.	Information				
1452	Breaker failure is BLOCKED (BkrFail BLOCK)	0	0	1	1
1451	Breaker failure is switched OFF (BkrFail OFF)	0	1	0	1
RBRF1.Mod.stVal		1	5	2	5

device annunciation: 1 - ON
0 - OFF

IEC Status Mod.stVal: 1 - ON
2 - BLOCKED
3 - TEST
4 - TEST/BLOCKED
5 - OFF

RBRF1.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
RBRF1.Health.stVal		3	1

device annunciation: 1 - ON
0 - OFF

IEC Status Health.stVal: 1 - OK
2 - WARNING
3 - ALARM

RBRF1.Str

No.	Information		
1461	Breaker failure protection started (BF Start)	0	1
RBRF1.Str.general		0	1

device annunciation: 1 - ON
0 - OFF

IEC Status Str.general: 0 - FALSE
1 - TRUE

RBRF1.OpEx

No.	Information		
1494	BF Trip T2 (busbar trip) (BF T2-TRIP(bus))	0	1
RBRF1.OpEx.general		0	1

device annunciation: 1 - ON
0 - OFF

IEC Status OpEx.general: 0 - FALSE
1 - TRUE

RBRF1.Opln

No.	Information					
1472	BF Trip T1 (local trip) - only phase L1 (BF T1-TRIP 1pL1)	0	1	x	x	x
1473	BF Trip T1 (local trip) - only phase L2 (BF T1-TRIP 1pL2)	0	x	1	x	x
1474	BF Trip T1 (local trip) - only phase L3 (BF T1-TRIP 1pL3)	0	x	x	1	x
1476	BF Trip T1 (local trip) - 3pole (BF T1-TRIP L123)	0	x	x	x	1
RBRF1.Opln.general		0	1	1	1	1

device annunciation: 1 - ON IEC Status Opln.general: 0 - FALSE
 0 - OFF 1 - TRUE
 x - irrelevant

RBRF1.Opln.phsA

No.	Information		
1472	BF Trip T1 (local trip) - only phase L1 (BF T1-TRIP 1pL1)	0	1
RBRF1.Opln.phsA		0	1

device annunciation: 1 - ON IEC Status Opln.phsA: 0 - FALSE
 0 - OFF 1 - TRUE

RBRF1.Opln.phsB

No.	Information		
1473	BF Trip T1 (local trip) - only phase L2 (BF T1-TRIP 1pL2)	0	1
RBRF1.Opln.phsB		0	1

device annunciation: 1 - ON IEC Status Opln.phsB: 0 - FALSE
 0 - OFF 1 - TRUE

RBRF1.Opln.phsC

No.	Information		
1474	BF Trip T1 (local trip) - only phase L3 (BF T1-TRIP 1pL3)	0	1
RBRF1.Opln.phsC		0	1

device annunciation: 1 - ON IEC Status Opln.phsC: 0 - FALSE
 0 - OFF 1 - TRUE

3.15 Thermal overload protection (PTTR1)

PTTR1.Mod

No.	Information				
1513	Thermal Overload Protection ACTIVE (Th.O/L ACTIVE)	x	0	1	1
1512	Thermal Overload Protection BLOCKED (Th.Overload BLK)	x	x	0	1
1511	Thermal Overload Protection OFF (Th.Overload OFF)	1	0	0	0
PTTR1.Mod.stVal		5	5	1	2

device annunciation: 1 - ON
0 - OFF

IEC Status Mod.stVal: 1 - ON
2 - BLOCKED
3 - TEST
4 - TEST/BLOCKED
5 - OFF

PTTR1.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTTR1.Health.stVal		3	1

device annunciation: 1 - ON
0 - OFF

IEC Status Health.stVal: 1 - OK
2 - WARNING
3 - ALARM

PTTR1.Str

No.	Information		
1517	Th. Overload Pickup before trip (Th.O/L Pickup)	0	1
PTTR1.Str.general		0	1

device annunciation: 1 - ON
0 - OFF

IEC Status Str.general: 0 - FALSE
1 - TRUE

PTTR1.Op

No.	Information		
1521	Th. Overload TRIP command (Th.O/L TRIP)	0	1
PTTR1.Op.general		0	1

device annunciation: 1 - ON
0 - OFF

IEC Status Op.general: 0 - FALSE
1 - TRUE

PTTR1.AlmThm

No.	Information		
1516	Th. Overload Alarm: Near Thermal Trip (Th.O/L Ⓟ Alarm)	0	1
PTTR1.AlmThm.general		0	1

device annunciation:

1 - ON
0 - OFF

IEC Status AlmThm.general:

0 - FALSE
1 - TRUE

3.16 Single-pole / threepole tripping Circuit Breaker (XCBRx)

3.16.1 Threepole tripping (XCBR1)

XCBR1.Mod

No.	Information		
52	At Least 1 Protection Funct. is Active (ProtActive)	1	0
XCBR1.Mod.stVal		1	5

device annunciation: 1 - ON
0 - OFF

IEC Status Mod.stVal: 1 - ON
2 - BLOCKED
3 - TEST
4 - TEST/BLOCKED
5 - OFF

XCBR1.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
XCBR1.Health.stVal		3	1

device annunciation: 1 - ON
0 - OFF

IEC Status Health.stVal: 1 - OK
2 - WARNING
3 - ALARM

XCBR1.Loc

No.	Information		
55	Reset Device (Reset Device)	1	0
XCBR1.Loc.stVal		1	0

device annunciation: 1 - ON
0 - OFF

IEC Status Loc.stVal: 0 - FALSE
1 - TRUE

XCBR1.OpCnt

No.	Information	Value		
1000	Number of breaker TRIP commands (# TRIPs=)	XCBR1.OpCnt.stVal	Metered value	Absolute value

XCBR1.SumSwARs1

No.	Information	Value		
1027	Accumulation of interrupted current L1 ($\Sigma IL1 =$)	XCBR1.SumSwARs1.actVal	Metered value	Current value of accumulated interrupted current = actVal \times pulsQty
		XCBR1.SumSwARs1.units.SIUnit	5	A (Ampere)
		XCBR1.SumSwARs1.units.multiplier	3	Kilo
		XCBR1.SumSwARs1.pulsQty	1.000000e-002	A / Metered value

XCBR1.SumSwARs2

No.	Information	Value		
1028	Accumulation of interrupted current L2 ($\Sigma IL2 =$)	XCBR1.SumSwARs2.actVal	Metered value	Current value of accumulated interrupted current = actVal \times pulsQty
		XCBR1.SumSwARs2.units.SIUnit	5	A (Ampere)
		XCBR1.SumSwARs2.units.multiplier	3	Kilo
		XCBR1.SumSwARs2.pulsQty	1.000000e-002	A / Metered value

XCBR1.SumSwARs3

No.	Information	Value		
1029	Accumulation of interrupted current L3 ($\Sigma IL3 =$)	XCBR1.SumSwARs3.actVal	Metered value	Current value of accumulated interrupted current = actVal \times pulsQty
		XCBR1.SumSwARs3.units.SIUnit	5	A (Ampere)
		XCBR1.SumSwARs3.units.multiplier	3	Kilo
		XCBR1.SumSwARs3.pulsQty	1.000000e-002	A / Metered value

3.16 Single-pole / threepole tripping Circuit Breaker (XCBRx)

XCBR2.Pos

No.	Information		
351	>Circuit breaker aux. contact: Pole L1 (>CB Aux. L1)	0	1
XCBR2.Pos.stVal		01	10

device annunciation: 1 - ON IEC Status Pos.stVal: 00 - INTERMEDIATE STATE
 0 - OFF 01 - OFF
 10 - ON
 11 - BAD STATE

XCBR2.BlkOpn

No.	Information		
55	Reset Device (Reset Device)	1	0
XCBR2.BlkOpn.stVal		0	1

device annunciation: 1 - ON IEC Status BlkOpn.stVal: 0 - FALSE
 0 - OFF 1 - TRUE

XCBR2.BlkCls

No.	Information		
55	Reset Device (Reset Device)	1	0
XCBR2.BlkCls.stVal		0	1

device annunciation: 1 - ON IEC Status BlkCls.stVal: 0 - FALSE
 0 - OFF 1 - TRUE

XCBR2.CirSpv

No.	Information		
6865	Failure Trip Circuit (FAIL: Trip cir.)	0	1
XCBR2.CirSpv.stVal		0	1

device annunciation: 1 - ON IEC Status CirSpv.stVal: 0 - FALSE
 0 - OFF 1 - TRUE

XCBr2.SumSwARs

No.	Information	Value		
1027	Accumulation of interrupted current L1 ($\Sigma IL1 =$)	XCBr2.SumSwARs.actVal	Metered value	Current value of accumulated interrupted current = actVal \times pulsQty
		XCBr2.SumSwARs.units.SIUnit	5	A (Ampere)
		XCBr2.SumSwARs.units.multiplier	3	Kilo
		XCBr2.SumSwARs.pulsQty	1.000000e-002	A / Metered value

XCBr3.Mod

No.	Information		
52	At Least 1 Protection Funct. is Active (ProtActive)	1	0
XCBr3.Mod.stVal		1	5

device annunciation: 1 - ON
0 - OFF

IEC Status Mod.stVal: 1 - ON
2 - BLOCKED
3 - TEST
4 - TEST/BLOCKED
5 - OFF

XCBr3.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
XCBr3.Health.stVal		3	1

device annunciation: 1 - ON
0 - OFF

IEC Status Health.stVal: 1 - OK
2 - WARNING
3 - ALARM

XCBr3.Loc

No.	Information		
55	Reset Device (Reset Device)	1	0
XCBr3.Loc.stVal		1	0

device annunciation: 1 - ON
0 - OFF

IEC Status Loc.stVal: 0 - FALSE
1 - TRUE

3.16 Single-pole / threepole tripping Circuit Breaker (XCBRx)

XCBR3.OpCnt

No.	Information	Value		
1002	Number of breaker TRIP commands L2 (TripNo L2=)	XCBR3.OpCnt.stVal	Metered value	Absolute value

XCBR3.Pos

No.	Information		
352	>Circuit breaker aux. contact: Pole L2 (>CB Aux. L2)	0	1
XCBR3.Pos.stVal		01	10

device annunciation: 1 - ON IEC Status Pos.stVal: 00 - INTERMEDIATE STATE
0 - OFF 01 - OFF
10 - ON
11 - BAD STATE

XCBR3.BlkOpn

No.	Information		
55	Reset Device (Reset Device)	1	0
XCBR3.BlkOpn.stVal		0	1

device annunciation: 1 - ON IEC Status BlkOpn.stVal: 0 - FALSE
0 - OFF 1 - TRUE

XCBR3.BlkCls

No.	Information		
55	Reset Device (Reset Device)	1	0
XCBR3.BlkCls.stVal		0	1

device annunciation: 1 - ON IEC Status BlkCls.stVal: 0 - FALSE
0 - OFF 1 - TRUE

XCBR3.CirSpv

No.	Information		
6865	Failure Trip Circuit (FAIL: Trip cir.)	0	1
XCBR3.CirSpv.stVal		0	1

device annunciation: 1 - ON IEC Status CirSpv.stVal: 0 - FALSE
0 - OFF 1 - TRUE

XCBR3.SumSwARs

No.	Information	Value		
1028	Accumulation of interrupted current L2 ($\Sigma IL2 =$)	XCBR3.SumSwARs.actVal	Metered value	Current value of accumulated interrupted current = actVal \times pulsQty
		XCBR3.SumSwARs.units.SIUnit	5	A (Ampere)
		XCBR3.SumSwARs.units.multiplier	3	Kilo
		XCBR3.SumSwARs.pulsQty	1.000000e-002	A / Metered value

XCBR4.Mod

No.	Information		
52	At Least 1 Protection Funct. is Active (ProtActive)	1	0
XCBR4.Mod.stVal		1	5

device annunciation: 1 - ON
0 - OFF

IEC Status Mod.stVal: 1 - ON
2 - BLOCKED
3 - TEST
4 - TEST/BLOCKED
5 - OFF

XCBR4.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
XCBR4.Health.stVal		3	1

device annunciation: 1 - ON
0 - OFF

IEC Status Health.stVal: 1 - OK
2 - WARNING
3 - ALARM

XCBR4.Loc

No.	Information		
55	Reset Device (Reset Device)	1	0
XCBR4.Loc.stVal		1	0

device annunciation: 1 - ON
0 - OFF

IEC Status Loc.stVal: 0 - FALSE
1 - TRUE

XCBR4.OpCnt

No.	Information	Value		
1003	Number of breaker TRIP commands L3 (TripNo L3=)	XCBR4.OpCnt.stVal	Metered value	Absolute value

XCBR4.Pos

No.	Information		
353	>Circuit breaker aux. contact: Pole L3 (>CB Aux. L3)	0	1
XCBR4.Pos.stVal		01	10

device annunciation: 1 - ON IEC Status Pos.stVal: 00 - INTERMEDIATE STATE
0 - OFF 01 - OFF
10 - ON
11 - BAD STATE

XCBR4.BlkOpn

No.	Information		
55	Reset Device (Reset Device)	1	0
XCBR4.BlkOpn.stVal		0	1

device annunciation: 1 - ON IEC Status BlkOpn.stval: 0 - FALSE
0 - OFF 1 - TRUE

XCBR4.BlkCls

No.	Information		
55	Reset Device (Reset Device)	1	0
XCBR4.BlkCls.stVal		0	1

device annunciation: 1 - ON IEC Status BlkCls.stVal: 0 - FALSE
0 - OFF 1 - TRUE

XCBR4.CirSpv

No.	Information		
6865	Failure Trip Circuit (FAIL: Trip cir.)	0	1
XCBR4.CirSpv.stVal		0	1

device annunciation: 1 - ON IEC Status CirSpv.stVal: 0 - FALSE
0 - OFF 1 - TRUE

XCBR4.SumSwARs

No.	Information	Value		
1029	Accumulation of interrupted current L3 ($\Sigma I_{L3} =$)	XCBR4.SumSwARs.actVal	Metered value	Current value of accumulated interrupted current = actVal \times pulsQty
		XCBR4.SumSwARs.units.SIUnit	5	A (Ampere)
		XCBR4.SumSwARs.units.multiplier	3	Kilo
		XCBR4.SumSwARs.pulsQty	1.000000e-002	A / Metered value

3.17 Tripping Logic of the Entire Device (PTRC1)

PTRC1.Mod

No.	Information		
52	At Least 1 Protection Funct. is Active (ProtActive)	1	0
PTRC1.Mod.stVal		1	5

device annunciation: 1 - ON
0 - OFF

IEC Status Mod.stVal: 1 - ON
2 - BLOCKED
3 - TEST
4 - TEST/BLOCKED
5 - OFF

PTRC1.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTRC1.Health.stVal		3	1

device annunciation: 1 - ON
0 - OFF

IEC Status Health.stVal: 1 - OK
2 - WARNING
3 - ALARM

PTRC1.Str

No.	Information						
501	Relay PICKUP (Relay PICKUP)	0	1	x	x	x	x
503	Relay PICKUP Phase L1 (Relay PICKUP L1)	0	x	1	x	x	x
504	Relay PICKUP Phase L2 (Relay PICKUP L2)	0	x	x	1	x	x
505	Relay PICKUP Phase L3 (Relay PICKUP L3)	0	x	x	x	1	x
506	Relay PICKUP Earth (Relay PICKUP E)	0	x	x	x	x	1
PTRC1.Str.general		0	1	1	1	1	1

device annunciation: 1 - ON
0 - OFF
X - irrelevant

IEC Status Str.general: 0 - FALSE
1 - TRUE

PTRC1.Str.dirGeneral

No.	Information													
3719	Distance Pickup FORWARD (Dis. forward)	0	1	0	1	0	0	0	1	1	x	x		
1358	E/F picked up FORWARD (EF forward)	0	0	1	1	0	0	0	x	x	1	1		
3720	Distance Pickup REVERSE (Dis. reverse)	0	0	0	0	1	0	1	1	x	1	x		
1359	E/F picked up REVERSE (EF reverse)	0	0	0	0	0	1	1	x	1	x	1		
PTRC1.Str.dirGeneral		0	1	1	1	2	2	2	3	3	3	3		

device annunciation:

1 - ON

0 - OFF

x - irrelevant

IEC Status Str.dirGeneral:

0 - UNKNOWN

1 - FORWARD

2 - BACKWARD

3 - BOTH

PTRC1.Str.phsA

No.	Information		
503	Relay PICKUP Phase L1 (Relay PICKUP L1)	0	1
PTRC1.Str.phsA		0	1

device annunciation:

1 - ON

0 - OFF

IEC Status Str.phsA:

0 - FALSE

1 - TRUE

PTRC1.Str.phsB

No.	Information		
504	Relay PICKUP Phase L2 (Relay PICKUP L2)	0	1
PTRC1.Str.phsB		0	1

device annunciation:

1 - ON

0 - OFF

IEC Status Str.phsB:

0 - FALSE

1 - TRUE

PTRC1.Str.phsC

No.	Information		
505	Relay PICKUP Phase L3 (Relay PICKUP L3)	0	1
PTRC1.Str.phsC		0	1

device annunciation:

1 - ON

0 - OFF

IEC Status Str.phsC:

0 - FALSE

1 - TRUE

3.17 Tripping Logic of the Entire Device (PTRC1)

PTRC1.Str.neut

No.	Information		
506	Relay PICKUP Earth (Relay PICKUP E)	0	1
PTRC1.Str.neut		0	1

device annunciation: 1 - ON IEC Status Str.neut: 0 - FALSE
0 - OFF 1 - TRUE

PTRC1.Tr.dirGeneral

No.	Information					
501	Relay PICKUP (Relay PICKUP)	0	1	x	x	x
507	Relay TRIP command Phase L1 (Relay TRIP L1)	0	x	1	x	x
508	Relay TRIP command Phase L2 (Relay TRIP L2)	0	x	x	1	x
509	Relay TRIP command Phase L3 (Relay TRIP L3)	0	x	x	x	1
PTRC1.Tr.dirGeneral		0	1	1	1	1

device annunciation: 1 - ON IEC Status Tr.dirGeneral: 0 - UNKNOWN
0 - OFF 1 - FORWARD
x - irrelevant 2 - BACKWARD
3 - BOTH

PTRC1.Tr.phsA

No.	Information		
507	Relay TRIP command Phase L1 (Relay TRIP L1)	0	1
PTRC1.Tr.phsA		0	1

device annunciation: 1 - ON IEC Status Tr.phsA: 0 - FALSE
0 - OFF 1 - TRUE

PTRC1.Tr.phsB

No.	Information		
508	Relay TRIP command Phase L2 (Relay TRIP L2)	0	1
PTRC1.Tr.phsB		0	1

device annunciation: 1 - ON IEC Status Tr.phsB: 0 - FALSE
0 - OFF 1 - TRUE

PTRC1.Tr.phsC

No.	Information		
509	Relay TRIP command Phase L3 (Relay TRIP L3)	0	1
PTRC1.Tr.phsC		0	1

device annunciation: 1 - ON IEC Status Tr.phsC: 0 - FALSE
 0 - OFF 1 - TRUE

PTRC1.FinTr

No.	Information		
536	Relay Definitive TRIP (Definitive TRIP)	0	1
PTRC1.FinTr.stVal		0	1

device annunciation: 1 - ON IEC Status FinTr.stVal: 0 - FALSE
 0 - OFF 1 - TRUE

3.18 Device (LPHD1, CALH1)

LPHD1.DevStr

No.	Information				
56	Initial Start of Device (Initial Start)	0	0	1	1
67	Resume (Resume)	0	1	0	1
LPHD1.DevStr.stVal		T	2	1	T

device annunciation: 1 - ON IEC Status DevStr.stVal: 1 - Initial Start
 0 - OFF 2 - Resume
 x - irrelevant T - toggle between 1 and 2

LPHD1.PhyHealth

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
LPHD1.PhyHealth.stVal		3	1

device annunciation: 1 - ON IEC Status PhyHealth.stVal: 1 - OK
 0 - OFF 2 - WARNING
 3 - ALARM

LPHD1.Proxy

No.	Information		
55	Reset Device (Reset Device)	0	1
LPHD1.Proxy.stVal		1	0

device annunciation: 1 - ON IEC Status Proxy.stVal: 0 - DEVICE is not a PROXY
 0 - OFF 1 - DEVICE is a PROXY

3.18.1 Alarm-, Warn- and Group alarms (CALH1)

CALH1.Mod

No.	Information		
55	Reset Device (Reset Device)	1	0
CALH1.Mod.stVal		1	5

device annunciation: 1 - ON
 0 - OFF
 IEC Status Mod.stVal: 1 - ON
 2 - BLOCKED
 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

CALH1.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
CALH1.Health.stVal		3	1

device annunciation: 1 - ON
 0 - OFF
 IEC Status Health.stVal: 1 - OK
 2 - WARNING
 3 - ALARM

CALH1.GrAlm

No.	Information		
140	Error with a summary alarm (Error Sum Alarm)	1	0
CALH1.GrAlm.stVal		1	0

device annunciation: 1 - ON
 0 - OFF
 IEC Status GrAlm.stVal: 0 - FALSE
 1 - TRUE

CALH1.GrWrn

No.	Information		
160	Alarm Summary Event (Alarm Sum Event)	1	0
CALH1.GrWrn.stVal		1	0

device annunciation: 1 - ON
 0 - OFF
 IEC Status GrWrn.stVal: 0 - FALSE
 1 - TRUE

The LN CALH1.ErrBoard1 to CALH1.ErrBoard7 are available
 SIPROTEC 7SA with Firmware V04.65 and higher
 SIPROTEC 7SD with Firmware V04.61 and higher
 SIPROTEC 7VK with Firmware V04.60 and higher.

CALH1.ErrBoard1

No.	Information		
183	Error Board 1 (Error Board 1)	1	0
CALH1.ErrBoard1.stVal		1	0

device annunciation: 1 - ON IEC Status ErrBoard1.stVal: 0 - FALSE
 0 - OFF 1 - TRUE

CALH1.ErrBoard2

No.	Information		
184	Error Board 2 (Error Board 2)	1	0
CALH1.ErrBoard2.stVal		1	0

device annunciation: 1 - ON IEC Status ErrBoard2.stVal: 0 - FALSE
 0 - OFF 1 - TRUE

CALH1.ErrBoard3

No.	Information		
185	Error Board 3 (Error Board 3)	1	0
CALH1.ErrBoard3.stVal		1	0

device annunciation: 1 - ON IEC Status ErrBoard3.stVal: 0 - FALSE
 0 - OFF 1 - TRUE

CALH1.ErrBoard4

No.	Information		
186	Error Board 4 (Error Board 4)	1	0
CALH1.ErrBoard4.stVal		1	0

device annunciation: 1 - ON IEC Status ErrBoard4.stVal: 0 - FALSE
 0 - OFF 1 - TRUE

CALH1.ErrBoard5

No.	Information		
187	Error Board 5 (Error Board 5)	1	0
CALH1.ErrBoard5.stVal		1	0

device annunciation: 1 - ON IEC Status ErrBoard5.stVal: 0 - FALSE
 0 - OFF 1 - TRUE

CALH1.ErrBoard6

No.	Information		
188	Error Board 6 (Error Board 6)	1	0
CALH1.ErrBoard6.stVal		1	0

device annunciation: 1 - ON IEC Status ErrBoard6.stVal: 0 - FALSE
 0 - OFF 1 - TRUE

CALH1.ErrBoard7

No.	Information		
189	Error Board 7 (Error Board 7)	1	0
CALH1.ErrBoard7.stVal		1	0

device annunciation: 1 - ON IEC Status ErrBoard7.stVal: 0 - FALSE
 0 - OFF 1 - TRUE

3.19 Measurements (MMXUx, MSQI1, MMTR1)

3.19.1 Measured values of local device (MMXU1)

MMXU1.Mod

No.	Information		
51	Device is Operational and Protecting (Device OK)	1	0
MMXU1.Mod.stVal		1	5

device annunciation: 1 - ON IEC Status Mod.stVal: 1 - ON
 0 - OFF 2 - BLOCKED
 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

MMXU1.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
MMXU1.Health.stVal		3	1

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
 0 - OFF 2 - WARNING
 3 - ALARM

MMXU1.TotW

No.	Information	Value		
641	P (active power) ($P =$)	MMXU1.TotW.mag.f	Measured value	Absolute value
		MMXU1.TotW.units.SIUnit	62	W (Watt)
		MMXU1.TotW.units.multiplier	6	Mega

MMXU1.TotVAr

No.	Information	Value		
642	Q (reactive power) ($Q =$)	MMXU1.TotVAr.mag.f	Measured value	Absolute value
		MMXU1.TotVAr.units.SIUnit	63	VAr
		MMXU1.TotVAr.units.multiplier	6	Mega

MMXU1.TotVA

No.	Information	Value		
645	S (apparent power) ($S =$)	MMXU1.TotVA.mag.f	Measured value	Absolute value
		MMXU1.TotVA.units.SIUnit	61	VA
		MMXU1.TotVA.units.multiplier	6	Mega

MMXU1.TotPF

No.	Information	Value		
643	cos PHI (Power factor) ($\cos \phi =$)	MMXU1.TotPF.mag.f	Measured value	Absolute value
		MMXU1.TotPF.units.SIUnit	1	NONE
		MMXU1.TotPF.units.multiplier	0	1

MMXU1.Hz

No.	Information	Value		
644	Frequency (Freq=)	MMXU1.Hz.mag.f	Measured value	Absolute value
		MMXU1.Hz.units.SIUnit	33	Hz
		MMXU1.Hz.units.multiplier	0	1

MMXU1.A

No.	Information	Value		
601	I L1 (IL1 =)	MMXU1.A.phsA.cVal.mag.f	Measured value	Absolute value
		MMXU1.A.phsA.units.SIUnit	5	A (Ampere)
		MMXU1.A.phsA.units.multiplier	0	1

No.	Information	Value		
602	I L2 (IL2 =)	MMXU1.A.phsB.cVal.mag.f	Measured value	Absolute value
		MMXU1.A.phsB.units.SIUnit	5	A (Ampere)
		MMXU1.A.phsB.units.multiplier	0	1

No.	Information	Value		
603	I L3 (IL3 =)	MMXU1.A.phsC.cVal.mag.f	Measured value	Absolute value
		MMXU1.A.phsC.units.SIUnit	5	A (Ampere)
		MMXU1.A.phsC.units.multiplier	0	1

MMXU1.PPV

No.	Information	Value		
624	U L12 (UL12=)	MMXU1.PPV.phsAB.cVal.mag.f	Measured value	Absolute value
		MMXU1.PPV.phsAB.units.SIUnit	29	V (Volt)
		MMXU1.PPV.phsAB.units.multiplier	3	Kilo

No.	Information	Value		
625	U L23 (UL23=)	MMXU1.PPV.phsBC.cVal.mag.f	Measured value	Absolute value
		MMXU1.PPV.phsBC.units.SIUnit	29	V (Volt)
		MMXU1.PPV.phsBC.units.multiplier	3	Kilo

No.	Information	Value		
626	U L31 (UL31=)	MMXU1.PPV.phsCA.cVal.mag.f	Measured value	Absolute value
		MMXU1.PPV.phsCA.units.SIUnit	29	V (Volt)
		MMXU1.PPV.phsCA.units.multiplier	3	Kilo

MMXU1.PhV

No.	Information	Value		
621	U L1-E (UL1E=)	MMXU1.PhV.phsA.cVal.mag.f	Measured value	Absolute value
		MMXU1.PhV.phsA.units.SIUnit	29	V (Volt)
		MMXU1.PhV.phsA.units.multiplier	3	Kilo

No.	Information	Value		
622	U L2-E (UL2E=)	MMXU1.PhV.phsB.cVal.mag.f	Measured value	Absolute value
		MMXU1.PhV.phsB.units.SIUnit	29	V (Volt)
		MMXU1.PhV.phsB.units.multiplier	3	Kilo

No.	Information	Value		
623	U L3-E (UL3E=)	MMXU1.PhV.phsC.cVal.mag.f	Measured value	Absolute value
		MMXU1.PhV.phsC.units.SIUnit	29	V (Volt)
		MMXU1.PhV.phsC.units.multiplier	3	Kilo

No.	Information	Value		
627	Uen (Uen =)	MMXU1.PhV.neut.cVal.mag.f	Measured value	Absolute value
		MMXU1.PhV.neut.units.SIUnit	29	V (Volt)
		MMXU1.PhV.neut.units.multiplier	3	Kilo

MMXU2.A

No.	Information	Value		
7762	IL1(% of Operational nominal current) (IL1_opN=)	MMXU2.A.phsA.cVal.mag.f	Measured value	Absolute value
		MMXU2.A.phsA.units.SIUnit	1	NONE
		MMXU2.A.phsA.units.multiplier	0	1
7763	Angle IL1_rem <-> IL1_loc (ϕI L1=)	MMXU2.A.phsA.cVal.ang.f	Measured value	Phase angle in °

No.	Information	Value		
7764	IL2(% of Operational nominal current) (IL2_opN=)	MMXU2.A.phsB.cVal.mag.f	Measured value	Absolute value
		MMXU2.A.phsB.units.SIUnit	1	NONE
		MMXU2.A.phsB.units.multiplier	0	1
7765	Angle IL2_rem <-> IL2_loc (ϕI L2=)	MMXU2.A.phsB.cVal.ang.f	Measured value	Phase angle in °

No.	Information	Value		
7766	IL3(% of Operational nominal current) (IL3_opN=)	MMXU2.A.phsC.cVal.mag.f	Measured value	Absolute value
		MMXU2.A.phsC.units.SIUnit	1	NONE
		MMXU2.A.phsC.units.multiplier	0	1
7767	Angle IL3_rem <-> IL3_loc (ϕI L3=)	MMXU2.A.phsC.cVal.ang.f	Measured value	Phase angle in °

MMXU2.PhV

No.	Information	Value		
7769	UL1(% of Operational nominal voltage) (UL1_opN=)	MMXU2.PhV.phsA.cVal.mag.f	Measured value	Absolute value
		MMXU2. PhV.phsA.units.SIUnit	29	V (Volt)
		MMXU2. PhV.phsA.units.multiplier	3	Kilo
7770	Angle UL1_rem <-> UL1_loc (ΦU L1=)	MMXU2. PhV.phsA.cVal.ang.f	Measured value	Phase angle in °

No.	Information	Value		
7771	UL2(% of Operational nominal voltage) (UL2_opN=)	MMXU2.PhV.phsB.cVal.mag.f	Measured value	Absolute value
		MMXU2. PhV.phsB.units.SIUnit	29	V (Volt)
		MMXU2. PhV.phsB.units.multiplier	3	Kilo
7772	Angle UL2_rem <-> UL2_loc (ΦU L2=)	MMXU2. PhV.phsB.cVal.ang.f	Measured value	Phase angle in °

No.	Information	Value		
7773	UL3(% of Operational nominal voltage) (UL3_opN=)	MMXU2.PhV.phsC.cVal.mag.f	Measured value	Absolute value
		MMXU2. PhV.phsC.units.SIUnit	29	V (Volt)
		MMXU2. PhV.phsC.units.multiplier	3	Kilo
7774	Angle UL3_rem <-> UL3_loc (ΦU L3=)	MMXU2. PhV.phsC.cVal.ang.f	Measured value	Phase angle in °

MMXU3.A

No.	Information	Value		
7782	IL1(% of Operational nominal current) (IL1_opN=)	MMXU3.A.phsA.cVal.mag.f	Measured value	Absolute value
		MMXU3.A.phsA.units.SIUnit	1	NONE
		MMXU3.A.phsA.units.multiplier	0	1
7783	Angle IL1_rem <-> IL1_loc (Φ1 L1=)	MMXU3.A.phsA.cVal.ang.f	Measured value	Phase angle in °

No.	Information	Value		
7784	IL2(% of Operational nominal current) (IL2_opN=)	MMXU3.A.phsB.cVal.mag.f	Measured value	Absolute value
		MMXU3.A.phsB.units.SIUnit	1	NONE
		MMXU3.A.phsB.units.multiplier	0	1
7785	Angle IL2_rem <-> IL2_loc (Φ1 L2=)	MMXU3.A.phsB.cVal.ang.f	Measured value	Phase angle in °

No.	Information	Value		
7786	IL3(% of Operational nominal current) (IL3_opN=)	MMXU3.A.phsC.cVal.mag.f	Measured value	Absolute value
		MMXU3.A.phsC.units.SIUnit	1	NONE
		MMXU3.A.phsC.units.multiplier	0	1
7787	Angle IL3_rem <-> IL3_loc (Φ1 L3=)	MMXU3.A.phsC.cVal.ang.f	Measured value	Phase angle in °

MMXU3.PhV

No.	Information	Value		
7789	UL1(% of Operational nominal voltage) (UL1_opN=)	MMXU3.PhV.phsA.cVal.mag.f	Measured value	Absolute value
		MMXU3. PhV.phsA.units.SIUnit	29	V (Volt)
		MMXU3. PhV.phsA.units.multiplier	3	Kilo
7790	Angle UL1_rem <-> UL1_loc (φU L1=)	MMXU3. PhV.phsA.cVal.ang.f	Measured value	Phase angle in °

No.	Information	Value		
7791	UL2(% of Operational nominal voltage) (UL2_opN=)	MMXU3.PhV.phsB.cVal.mag.f	Measured value	Absolute value
		MMXU3. PhV.phsB.units.SIUnit	29	V (Volt)
		MMXU3. PhV.phsB.units.multiplier	3	Kilo
7792	Angle UL2_rem <-> UL2_loc (φU L2=)	MMXU3. PhV.phsB.cVal.ang.f	Measured value	Phase angle in °

No.	Information	Value		
7793	UL3(% of Operational nominal voltage) (UL3_opN=)	MMXU3.PhV.phsC.cVal.mag.f	Measured value	Absolute value
		MMXU3. PhV.phsC.units.SIUnit	29	V (Volt)
		MMXU3. PhV.phsC.units.multiplier	3	Kilo
7794	Angle UL3_rem <-> UL3_loc (φU L3=)	MMXU3. PhV.phsC.cVal.ang.f	Measured value	Phase angle in °

3.19.4 Remote measured values of relay 3 (MMXU4)

MMXU4.Mod

No.	Information		
3493	Relay 3 in Login state (Rel3 Login)	0	1
MMXU4.Mod.stVal		5	1

device annunciation:	1 - ON 0 - OFF	IEC Status Mod.stVal:	1 - ON 2 - BLOCKED 3 - TEST 4 - TEST/BLOCKED 5 - OFF
----------------------	-------------------	-----------------------	--

MMXU4.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
MMXU4.Health.stVal		3	1

device annunciation:	1 - ON 0 - OFF	IEC Status Health.stVal:	1 - OK 2 - WARNING 3 - ALARM
----------------------	-------------------	--------------------------	------------------------------------

MMXU4.RelId

No.	Information	Value		
7801	Relay ID of 3. relay (Relay ID)	MMXU4.RelId.stVal	Parameter 4703	Device address

MMXU4.A

No.	Information	Value		
7802	IL1(% of Operational nominal current) (IL1_opN=)	MMXU4.A.phsA.cVal.mag.f	Measured value	Absolute value
		MMXU4.A.phsA.units.SIUnit	1	NONE
		MMXU4.A.phsA.units.multiplier	0	1
7803	Angle IL1_rem <-> IL1_loc (ΦI L1=)	MMXU4.A.phsA.cVal.ang.f	Measured value	Phase angle in °

No.	Information	Value		
7804	IL2(% of Operational nominal current) (IL2_opN=)	MMXU4.A.phsB.cVal.mag.f	Measured value	Absolute value
		MMXU4.A.phsB.units.SIUnit	1	NONE
		MMXU4.A.phsB.units.multiplier	0	1
7805	Angle IL2_rem <-> IL2_loc (ΦI L2=)	MMXU4.A.phsB.cVal.ang.f	Measured value	Phase angle in °

No.	Information	Value		
7806	IL3(% of Operational nominal current) (IL3_opN=)	MMXU4.A.phsC.cVal.mag.f	Measured value	Absolute value
		MMXU4.A.phsC.units.SIUnit	1	NONE
		MMXU4.A.phsC.units.multiplier	0	1
7807	Angle IL3_rem <-> IL3_loc (ΦI L3=)	MMXU4.A.phsC.cVal.ang.f	Measured value	Phase angle in °

MMXU4.PhV

No.	Information	Value		
7809	UL1(% of Operational nominal voltage) (UL1_opN=)	MMXU4.PhV.phsA.cVal.mag.f	Measured value	Absolute value
		MMXU4.PhV.phsA.units.SIUnit	29	V (Volt)
		MMXU4.PhV.phsA.units.multiplier	3	Kilo
7810	Angle UL1_rem <-> UL1_loc (ΦU L1=)	MMXU4.PhV.phsA.cVal.ang.f	Measured value	Phase angle in °

No.	Information	Value		
7811	UL2(% of Operational nominal voltage) (UL2_opN=)	MMXU4.PhV.phsB.cVal.mag.f	Measured value	Absolute value
		MMXU4.PhV.phsB.units.SIUnit	29	V (Volt)
		MMXU4.PhV.phsB.units.multiplier	3	Kilo
7812	Angle UL2_rem <-> UL2_loc (ΦU L2=)	MMXU4.PhV.phsB.cVal.ang.f	Measured value	Phase angle in °

No.	Information	Value		
7813	UL3(% of Operational nominal voltage) (UL3_opN=)	MMXU4.PhV.phsC.cVal.mag.f	Measured value	Absolute value
		MMXU4.PhV.phsC.units.SIUnit	29	V (Volt)
		MMXU4. PhV.phsC.units.multiplier	3	Kilo
7814	Angle UL3_rem <-> UL3_loc (ΦU L3=)	MMXU4. PhV.phsC.cVal.ang.f	Measured value	Phase angle in °

MMXU5.A

No.	Information	Value		
7822	IL1(% of Operational nominal current) (IL1_opN=)	MMXU5A.phsA.cVal.mag.f	Measured value	Absolute value
		MMXU5A.phsA.units.SIUnit	1	NONE
		MMXU5A.phsA.units.multiplier	0	1
7823	Angle IL1_rem <-> IL1_loc (Φ1 L1=)	MMXU5A.phsA.cVal.ang.f	Measured value	Phase angle in °

No.	Information	Value		
7824	IL2(% of Operational nominal current) (IL2_opN=)	MMXU5A.phsB.cVal.mag.f	Measured value	Absolute value
		MMXU5A.phsB.units.SIUnit	1	NONE
		MMXU5A.phsB.units.multiplier	0	1
7825	Angle IL2_rem <-> IL2_loc (Φ1 L2=)	MMXU5A.phsB.cVal.ang.f	Measured value	Phase angle in °

No.	Information	Value		
7826	IL3(% of Operational nominal current) (IL3_opN=)	MMXU5A.phsC.cVal.mag.f	Measured value	Absolute value
		MMXU5A.phsC.units.SIUnit	1	NONE
		MMXU5A.phsC.units.multiplier	0	1
7827	Angle IL3_rem <-> IL3_loc (Φ1 L3=)	MMXU5A.phsC.cVal.ang.f	Measured value	Phase angle in °

MMXU5.PhV

No.	Information	Value		
7829	UL1(% of Operational nominal voltage) (UL1_opN=)	MMXU5.PhV.phsA.cVal.mag.f	Measured value	Absolute value
		MMXU5.PhV.phsA.units.SIUnit	29	V (Volt)
		MMXU5.PhV.phsA.units.multiplier	3	Kilo
7830	Angle UL1_rem <-> UL1_loc (φU L1=)	MMXU5.PhV.phsA.cVal.ang.f	Measured value	Phase angle in °

No.	Information	Value		
7831	UL2(% of Operational nominal voltage) (UL2_opN=)	MMXU5.PhV.phsB.cVal.mag.f	Measured value	Absolute value
		MMXU5.PhV.phsB.units.SIUnit	29	V (Volt)
		MMXU5.PhV.phsB.units.multiplier	3	Kilo
7832	Angle UL2_rem <-> UL2_loc (φU L2=)	MMXU5.PhV.phsB.cVal.ang.f	Measured value	Phase angle in °

No.	Information	Value		
7833	UL3(% of Operational nominal voltage) (UL3_opN=)	MMXU5.PhV.phsC.cVal.mag.f	Measured value	Absolute value
		MMXU5.PhV.phsC.units.SIUnit	29	V (Volt)
		MMXU5. PhV.phsC.units.multiplier	3	Kilo
7834	Angle UL3_rem <-> UL3_loc (φU L3=)	MMXU5. PhV.phsC.cVal.ang.f	Measured value	Phase angle in °

3.19.6 Remote measured values of relay 5 (MMXU6)

MMXU6.Mod

No.	Information		
3495	Relay 5 in Login state (Rel5 Login)	0	1
MMXU6.Mod.stVal		5	1

device annunciation: 1 - ON
0 - OFF

IEC Status Mod.stVal:

1 - ON
2 - BLOCKED
3 - TEST
4 - TEST/BLOCKED
5 - OFF

MMXU6.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
MMXU6.Health.stVal		3	1

device annunciation: 1 - ON
0 - OFF

IEC Status Health.stVal:

1 - OK
2 - WARNING
3 - ALARM

MMXU6.RelId

No.	Information	Value		
7841	Relay ID of 5. relay (Relay ID)	MMXU6.RelId.stVal	Parameter 4705	Device address

MMXU6.A

No.	Information	Value		
7842	IL1(% of Operational nominal current) (IL1_opN=)	MMXU6.A.phsA.cVal.mag.f	Measured value	Absolute value
		MMXU6.A.phsA.units.SIUnit	1	NONE
		MMXU6.A.phsA.units.multiplier	0	1
7843	Angle IL1_rem <-> IL1_loc (ΦI L1=)	MMXU6.A.phsA.cVal.ang.f	Measured value	Phase angle in °

No.	Information	Value		
7844	IL2(% of Operational nominal current) (IL2_opN=)	MMXU6.A.phsB.cVal.mag.f	Measured value	Absolute value
		MMXU6.A.phsB.units.SIUnit	1	NONE
		MMXU6.A.phsB.units.multiplier	0	1
7845	Angle IL2_rem <-> IL2_loc (ΦI L2=)	MMXU6.A.phsB.cVal.ang.f	Measured value	Phase angle in °

No.	Information	Value		
7846	IL3(% of Operational nominal current) (IL3_opN=)	MMXU6.A.phsC.cVal.mag.f	Measured value	Absolute value
		MMXU6.A.phsC.units.SIUnit	1	NONE
		MMXU6.A.phsC.units.multiplier	0	1
7847	Angle IL3_rem <-> IL3_loc (ΦI L3=)	MMXU6.A.phsC.cVal.ang.f	Measured value	Phase angle in °

MMXU6.PhV

No.	Information	Value		
7849	UL1(% of Operational nominal voltage) (UL1_opN=)	MMXU6.PhV.phsA.cVal.mag.f	Measured value	Absolute value
		MMXU6.PhV.phsA.units.SIUnit	29	V (Volt)
		MMXU6.PhV.phsA.units.multiplier	3	Kilo
7850	Angle UL1_rem <-> UL1_loc (ΦU L1=)	MMXU6.PhV.phsA.cVal.ang.f	Measured value	Phase angle in °

No.	Information	Value		
7851	UL2(% of Operational nominal voltage) (UL2_opN=)	MMXU6.PhV.phsB.cVal.mag.f	Measured value	Absolute value
		MMXU6.PhV.phsB.units.SIUnit	29	V (Volt)
		MMXU6.PhV.phsB.units.multiplier	3	Kilo
7852	Angle UL2_rem <-> UL2_loc (ΦU L2=)	MMXU6.PhV.phsB.cVal.ang.f	Measured value	Phase angle in °

No.	Information	Value		
7853	UL3(% of Operational nominal voltage) (UL3_opN=)	MMXU6.PhV.phsC.cVal.mag.f	Measured value	Absolute value
		MMXU6.PhV.phsC.units.SIUnit	29	V (Volt)
		MMXU6. PhV.phsC.units.multiplier	3	Kilo
7854	Angle UL3_rem <-> UL3_loc (ΦU L3=)	MMXU6. PhV.phsC.cVal.ang.f	Measured value	Phase angle in °

MMXU7.A

No.	Information	Value		
7862	IL1(% of Operational nominal current) (IL1_opN=)	MMXU7.A.phsA.cVal.mag.f	Measured value	Absolute value
		MMXU7.A.phsA.units.SIUnit	1	NONE
		MMXU7.A.phsA.units.multiplier	0	1
7863	Angle IL1_rem <-> IL1_loc (Φ1 L1=)	MMXU7.A.phsA.cVal.ang.f	Measured value	Phase angle in °

No.	Information	Value		
7864	IL2(% of Operational nominal current) (IL2_opN=)	MMXU7.A.phsB.cVal.mag.f	Measured value	Absolute value
		MMXU7.A.phsB.units.SIUnit	1	NONE
		MMXU7.A.phsB.units.multiplier	0	1
7865	Angle IL2_rem <-> IL2_loc (Φ1 L2=)	MMXU7.A.phsB.cVal.ang.f	Measured value	Phase angle in °

No.	Information	Value		
7866	IL3(% of Operational nominal current) (IL3_opN=)	MMXU7.A.phsC.cVal.mag.f	Measured value	Absolute value
		MMXU7.A.phsC.units.SIUnit	1	NONE
		MMXU7.A.phsC.units.multiplier	0	1
7867	Angle IL3_rem <-> IL3_loc (Φ1 L3=)	MMXU7.A.phsC.cVal.ang.f	Measured value	Phase angle in °

MMXU7.PhV

No.	Information	Value		
7869	UL1(% of Operational nominal voltage) (UL1_opN=)	MMXU7.PhV.phsA.cVal.mag.f	Measured value	Absolute value
		MMXU7.PhV.phsA.units.SIUnit	29	V (Volt)
		MMXU7.PhV.phsA.units.multiplier	3	Kilo
7870	Angle UL1_rem <-> UL1_loc (φU L1=)	MMXU7.PhV.phsA.cVal.ang.f	Measured value	Phase angle in °

No.	Information	Value		
7871	UL2(% of Operational nominal voltage) (UL2_opN=)	MMXU7.PhV.phsB.cVal.mag.f	Measured value	Absolute value
		MMXU7.PhV.phsB.units.SIUnit	29	V (Volt)
		MMXU7.PhV.phsB.units.multiplier	3	Kilo
7872	Angle UL2_rem <-> UL2_loc (φU L2=)	MMXU7.PhV.phsB.cVal.ang.f	Measured value	Phase angle in °

No.	Information	Value		
7873	UL3(% of Operational nominal voltage) (UL3_opN=)	MMXU7.PhV.phsC.cVal.mag.f	Measured value	Absolute value
		MMXU7.PhV.phsC.units.SIUnit	29	V (Volt)
		MMXU7. PhV.phsC.units.multiplier	3	Kilo
7874	Angle UL3_rem <-> UL3_loc (φU L3=)	MMXU7. PhV.phsC.cVal.ang.f	Measured value	Phase angle in °

3.19.8 Measured values, symmetrical components (MSQI1)

MSQI1.Mod

No.	Information		
51	Device is Operational and Protecting (Device OK)	1	0
MSQI1.Mod.stVal		1	5

device annunciation: 1 - ON
0 - OFF

IEC Status Mod.stVal: 1 - ON
2 - BLOCKED
3 - TEST
4 - TEST/BLOCKED
5 - OFF

MSQI1.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
MSQI1.Health.stVal		3	1

device annunciation: 1 - ON
0 - OFF

IEC Status Health.stVal: 1 - OK
2 - WARNING
3 - ALARM

MSQ11.SeqA

No.	Information	Value		
619	I1 (positive sequence) (I1 =)	MSQ11.SeqA.c1.cVal.mag.f	Measured value	Absolute value
		MSQ11.SeqA.c1.units.SIUnit	5	A (Ampere)
		MSQ11.SeqA.c1.units.multiplier	0	1

No.	Information	Value		
620	I2 (negative sequence) (I2 =)	MSQ11.SeqA.c2.cVal.mag.f	Measured value	Absolute value
		MSQ11.SeqA.c2.units.SIUnit	5	A (Ampere)
		MSQ11.SeqA.c2.units.multiplier	0	1

No.	Information	Value		
610	3I0 (zero sequence) (3I0 =)	MSQ11.SeqA.c3.cVal.mag.f	Measured value	Absolute value
		MSQ11.SeqA.c3.units.SIUnit	5	A (Ampere)
		MSQ11.SeqA.c3.units.multiplier	0	1

MSQ11.SeqV

No.	Information	Value		
634	U1 (positive sequence) (U1 =)	MSQ11.SeqV.c1.cVal.mag.f	Measured value	Absolute value
		MSQ11.SeqV.c1.units.SIUnit	29	V (Volt)
		MSQ11.SeqV.c1.units.multiplier	3	Kilo

No.	Information	Value		
635	U2 (negative sequence) (U2 =)	MSQ11.SeqV.c2.cVal.mag.f	Measured value	Absolute value
		MSQ11.SeqV.c2.units.SIUnit	29	V (Volt)
		MSQ11.SeqV.c2.units.multiplier	3	Kilo

No.	Information	Value		
684	U0 (zero sequence) (U0 =)	MSQ11.SeqV.c3.cVal.mag.f	Measured value	Absolute value
		MSQ11.SeqV.c3.units.SIUnit	29	V (Volt)
		MSQ11.SeqV.c3.units.multiplier	3	Kilo

3.19.9 Power Metering (MMTR1)

MMTR1.Mod

No.	Information		
51	Device is Operational and Protecting (Device OK)	1	0
MMTR1.Mod.stVal		1	5

device annunciation: 1 - ON
0 - OFF

IEC Status Mod.stVal: 1 - ON
2 - BLOCKED
3 - TEST
4 - TEST/BLOCKED
5 - OFF

MMTR1.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
MMTR1.Health.stVal		3	1

device annunciation: 1 - ON
0 - OFF

IEC Status Health.stVal: 1 - OK
2 - WARNING
3 - ALARM

MMTR1.SupWh

No.	Information	Value		
		MMTR1.SupWh.actVal	Metered value	Current value of accumulated interrupted current = actVal × pulsQty
924	Wp Forward (Wp+)=	MMTR1.SupWh.actVal	Metered value	Current value of accumulated interrupted current = actVal × pulsQty
		MMTR1.SupWh.units.SIUnit	72	Wh
		MMTR1.SupWh.units.multiplier	9	Giga
		MMTR1.SupWh.pulsQty	1.154700e-005	Wh / Metered value

MMTR1.SupVArh

No.	Information	Value		
925	Wq Forward (Wq+=)	MMTR1.SupVArh.actVal	Metered value	Current value of acumulated interrupted current = actVal × pulsQty
		MMTR1.SupVArh.units.SIUnit	73	VArh
		MMTR1.SupVArh.units.multiplier	9	Giga
		MMTR1.SupVArh.pulsQty	1.154700e-005	VArh / Metered value

MMTR1.DmdWh

No.	Information	Value		
928	Wp Reverse (Wp=-)	MMTR1.DmdWh.actVal	Metered value	Current value of acumulated interrupted current = actVal × pulsQty
		MMTR1.DmdWh.units.SIUnit	72	Wh
		MMTR1.DmdWh.units.multiplier	9	Giga
		MMTR1.DmdWh.pulsQty	1.154700e-005	Wh / Metered value

MMTR1.DmdVArh

No.	Information	Value		
929	Wq Reverse (Wq=-)	MMTR1.DmdVArh.actVal	Metered value	Current value of acumulated interrupted current = actVal × pulsQty
		MMTR1.DmdVArh.units.SIUnit	73	VArh
		MMTR1.DmdVArh.units.multiplier	9	Giga
		MMTR1.DmdVArh.pulsQty	1.154700e-005	VArh / Metered value

Literature

- /1/ SIPROTEC 4 Ethernet Module EN 100 IEC 61850 Electrical/optical Interface
100 MBit, Manual
C53000-G1176-C167
- /2/ SIPROTEC 4 System Description
E50417-H1176-C151
- /3/ SIPROTEC DIGSI, StartUP
E50417-G1176-C152
- /4/ DIGSI CFC, Manual
E50417-H1176-C098
- /5/ SIPROTEC SIGRA 4, Manual
E50417-H1176-C1100-C070
- /6/ SIPROTEC Distance Protection 7SA6, Manual
C53000-G1176-C156
- /7/ SIPROTEC Distance Protection 7SA522, Manual
C53000-G1176-C155
- /8/ SIPROTEC Line Differential Protection with Distance Protection 7SD5, Manual
C5300-G1176-C169
- /9/ SIPROTEC Differential Protection 7SD610, Manual
C5300-G1176-C145
- /10/ SIPROTEC Breaker Management Relay 7VK61, Manual
C5300-G1176-C159

Index

C

CALH1 34, 57, 213
ErrBoard1 214
ErrBoard2 214
ErrBoard3 214
ErrBoard4 214
ErrBoard5 215
ErrBoard6 215
ErrBoard7 215
GrAlm 213
GrWrn 213
Health 213
Mod 213

D

DAI 33
DOI 33

F

Function parameters 34
Functional Scope
7SA522 39
7SA6 35
7SD5 43
7SD610 48
7VK61 51

L

LD
CTRL (Control) 34, 57
DR (Disturbance Recorder) 34
DR (Disturbance recorder) 57
EXT (Extended) 57
Logical Device 32
MEAS (Measurement) 34, 56
PROT (Protection) 34, 54
LLN0 32, 34, 54, 56, 57
Beh 58, 59
Mod 58, 59
Logical Node 33, 35, 39, 43, 48, 51, 54
LPHD1 32, 34, 56, 57, 212
DevStr 212
PhyHealth 212
Proxy 212

M

MMTR1 34, 56, 240
DmdVArh 241

DmdWh 241
Health 240
Mod 240
SupVArh 241
SupWh 240
MMXU1 34, 56, 216
Health 216
Hz 217
Mod 216
PhV 219
PPV 218
TotPF 217
TotVA 217
TotVAr 217
TotW 217
MMXU2 46, 47, 50, 220
A 221
Health 220
Mod 220
PhV 222
Relld 220
MMXU3 47, 50, 223
A 224
Health 223
Mod 223
PhV 225
Relld 223
MMXU4 47, 226
A 227
Health 226
Mod 226
PhV 228
Relld 226
MMXU5 47, 229
A 230
Health 229
Mod 229
PhV 231
Relld 229
MMXU6 47, 232
A 233
Health 232
Mod 232
PhV 234
Relld 232
MMXU7 46, 47, 235
A 236
Health 235

Mod 235
PhV 237
RelId 235
MSQI1 34, 56, 238
Health 238
Mod 238
SeqA 239
SeqV 239

P

PDIF1 43, 48, 54, 64
Health 64
Mod 64
Op 65
Str 64
PDIF2 65
Health 65
Mod 65
Op 66
Str 66
PDIF3 46, 50, 135
DifAClc 136
Health 135
Mod 135
Op 136
Str 136
Str.dirGeneral 136
PDIS1 39, 43, 54, 74
Health 74
Mod 74
Op 77
Op.phsA 77
Op.phsB 77
Op.phsC 78
Str 75
Str.dirGeneral 76
StrAB 79
StrAG 78
StrBC 79
StrBG 78
StrCA 79
StrCG 78
PDIS10 80
Health 80
Mod 80
Op 83
Op.phsA 83
Op.phsB 83
Op.phsC 84
Str 81
Str.dirGeneral 82
StrAB 85
StrAG 84
StrBC 85
StrBG 84
StrCA 85
StrCG 84
PDIS2 54, 86

Health 86
Mod 86
Op 87
Op.phsA 87
Op.phsB 88
Op.phsC 88
Str 86
Str.dirGeneral 87
PDIS3 89
Health 89
Mod 89
Op 90
Op.phsA 91
Op.phsB 91
Op.phsC 91
Str 90
Str.dirGeneral 90
PDIS4 92
Health 92
Mod 92
Op 93
Op.phsA 94
Op.phsB 94
Op.phsC 94
Str 92
Str.dirGeneral 93
PDIS5 95
Health 95
Mod 95
Op 96
Op.phsA 97
Op.phsB 97
Op.phsC 97
Str 95
Str.dirGeneral 96
PSCH1 35, 39, 44, 54, 116
Echo 120
GrdRx 122
Health 116
LosOfGrd 120
Mod 116
Op 118
Op.CarRx 120
Op.phsA 119
Op.phsB 119
Op.phsC 119
ProRx 117
ProTx 116
RvABlk 122
Str 117
Str.phsA 117
Str.phsB 117
Str.phsC 118
WeiOp.general 121
WeiOp.phsA 121
WeiOp.phsB 121
WeiOp.phsC 121
PSDE1 36, 131

Health 131
 Mod 131
 Op 134
 Str 131
 Str.dirGeneral 132
 Str.dirPhsA 132
 Str.dirPhsB 133
 Str.dirPhsC 134
 Str.phsA 132
 Str.phsB 133
 Str.phsC 133
 PTOC1 36, 55, 137
 Health 137
 Mod 137
 Op 138
 Str 137
 PTOC10 55, 145
 Health 145
 Mod 145
 Op 146
 Str 146
 Str.dirGeneral 146
 PTOC2 40, 44, 48, 51, 55, 138
 Health 138
 Mod 138
 Op 139
 Str 139
 PTOC3 36, 139
 Health 140
 Mod 139
 Op 140
 Str 140
 PTOC4 141
 Health 141
 Mod 141
 Op 142
 Str 142
 PTOC5 36, 40, 44, 55, 123
 Health 123
 Mod 123
 Op 124
 Str 123
 Str.dirGeneral 124
 PTOC6 125
 Health 125
 Mod 125
 Op 126
 Str 125
 Str.dirGeneral 126
 PTOC7 127
 Health 127
 Mod 127
 Op 128
 Str 127
 Str.dirGeneral 128
 PTOC8 129
 Health 129
 Mod 129
 Op 130
 Str 129
 Str.dirGeneral 130
 PTOC9 55, 143
 Health 143
 Mod 143
 Op 144
 Str 144
 Str.dirGeneral 144
 PTOF1 37, 41, 45, 49, 55, 184
 Health 184
 Mod 184
 Op 185
 Str 185
 PTOF2 186
 Health 186
 Mod 186
 Op 187
 Str 187
 PTOF3 188
 Health 188
 Mod 188
 Op 189
 Str 189
 PTOF4 190
 Health 190
 Mod 190
 Op 191
 Str 191
 PTOV1 37, 41, 45, 49, 52, 55, 162
 Health 162
 Mod 162
 Op 163
 Str 162
 Str.phsA 163
 Str.phsB 163
 Str.phsC 163
 PTOV10 175
 Health 175
 Mod 175
 Op 175
 Str 175
 PTOV2 164
 Health 164
 Mod 164
 Op 165
 Str 164
 Str.phsA 165
 Str.phsB 165
 Str.phsC 165
 PTOV3 166
 Health 166
 Mod 166
 Op 167
 Str 166
 Str.phsA 167
 Str.phsB 167
 Str.phsC 167
 PTOV4 168
 Health 168

Mod 168
 Op 169
 Str 168
 Str.phsA 169
 Str.phsB 169
 Str.phsC 169
 PTOV5 170
 Health 170
 Mod 170
 Op 170
 Str 170
 PTOV6 171
 Health 171
 Mod 171
 Op 171
 Str 171
 PTOV7 172
 Health 172
 Mod 172
 Op 172
 Str 172
 PTOV8 173
 Health 173
 Mod 173
 Op 173
 Str 173
 PTOV9 174
 Health 174
 Mod 174
 Op 174
 Str 174
 PTRC1 208
 FinTr 211
 Health 208
 Mod 208
 Str 208
 Str.dirGeneral 209
 Str.neut 210
 Str.phsA 209
 Str.phsB 209
 Str.phsC 209
 Tr.dirGeneral 210
 Tr.phsA 210
 Tr.phsB 210
 Tr.phsC 211
 PTRC2 34, 35, 39, 43, 54, 98
 Health 98
 Mod 98
 Op 101
 Op.phsA 102
 Op.phsB 102
 Op.phsC 102
 Str 98
 Str.dirGeneral 99
 Str.dirPhsA 99
 Str.dirPhsB 100
 Str.dirPhsC 101
 Str.neut 101
 Str.phsA 99, 100, 101
 Str.phsB 100, 101
 Str.phsC 101
 PTRC3 54, 67
 Health 67
 Mod 67
 Op 69
 Op.phsA 70
 Op.phsB 70
 Op.phsC 70
 Str 67
 Str.dirGeneral 68
 Str.dirNeut 69
 Str.dirPhsA 68
 Str.dirPhsB 68
 Str.dirPhsC 69
 Str.neut 69
 Str.phsA 68
 Str.phsB 68
 Str.phsC 69
 StrA 70
 StrAB 72
 StrABC 72
 StrABCG 73
 StrABG 73
 StrAG 71
 StrB 71
 StrBC 72
 StrBCG 73
 StrBG 71
 StrC 71
 StrCA 72
 StrCAG 73
 StrCG 71
 PTRR1 38, 46, 50, 55, 196
 AlmThm 197
 Health 196
 Mod 196
 Op 196
 Str 196
 PTUF1 37, 41, 45, 49, 55, 176
 Health 176
 Mod 176
 Op 177
 Str 177
 PTUF2 178
 Health 178
 Mod 178
 Op 179
 Str 179
 PTUF3 180
 Health 180
 Mod 180
 Op 181
 Str 181
 PTUF4 182
 Health 182
 Mod 182
 Op 183
 Str 183

PTUV1 37, 41, 45, 49, 52, 55, 152

Health 152

Mod 152

Op 153

Str 152

Str.phsA 153

Str.phsB 153

Str.phsC 153

PTUV2 154

Health 154

Mod 154

Op 155

Str 154

Str.phsA 155

Str.phsB 155

Str.phsC 155

PTUV3 156

Health 156

Mod 156

Op 157

Str 156

Str.phsA 157

Str.phsB 157

Str.phsC 157

PTUV4 158

Health 158

Mod 158

Op 159

Str 158

Str.phsA 159

Str.phsB 159

Str.phsC 159

PTUV5 160

Health 160

Mod 160

Op 160

Str 160

PTUV6 161

Health 161

Mod 161

Op 161

Str 161

R

RBRF1 38, 41, 46, 49, 52, 55, 194

Health 194

Mod 194

OpEx 194

Opln 195

Opln.phsA 195

Opln.phsB 195

Opln.phsC 195

Str 194

RDRE1 35, 39, 43, 48, 51, 57, 242

FltNum 243

GriFltNum 243

Health 242

Mod 242

RcdMade 242, 243

RcdStr 243

RFLO1 37, 41, 45, 55, 192

FltDiskm 193

FltDisPrc 193

FltZ 193

Health 192

Mod 192

RPSB1 35, 39, 43, 54, 103

BlkZn 104

Health 103

Mod 103

Str 103

Str.phsA 104

Str.phsB 104

Str.phsC 104

RPSB10 105

BlkZn 106

Health 105

Mod 105

Str 105

Str.phsA 106

Str.phsB 106

Str.phsC 106

RPSB2 107

BlkZn 108

Health 107

Mod 107

Str 107

Str.phsA 108

Str.phsB 108

Str.phsC 108

RPSB3 109

BlkZn 110

Health 109

Mod 109

Str 109

Str.phsA 110

Str.phsB 110

Str.phsC 110

RPSB4 111

BlkZn 112

Health 111

Mod 111

Str 111

Str.phsA 112

Str.phsB 112

Str.phsC 112

RPSB5 113

BlkZn 114

Health 113

Mod 113

Str 113

Str.phsA 114

Str.phsB 114

Str.phsC 114

RPSB6 54, 115

Health 115

Mod 115

Op 115

RREC1 37, 40, 45, 49, 52, 56, 57, 147

AutoRecSt 148

Health 147

Mod 147

Op 148

RSYN1 37, 41, 45, 52, 55, 149

AngInd 150

DifAngClc 151

DifHzClc 151

DifVClc 152

Health 149

HZInd 150

Mod 149

Rel 149

SynPrg 150

VInd 150

SumSwARs 207

X

XCBR1 35, 39, 43, 48, 51, 56, 198

BlkCls 199

BlkOpn 199

CirSpv 199

Health 198

Loc 198

Mod 198

OpCnt 198

Pos 199

SumSwAR1s 200

SumSwAR2s 200

SumSwAR3s 200

XCBR2 35, 39, 43, 48, 51, 56, 201

BlkCls 202

BlkOpn 202

CirSpv 202

Health 201

Loc 201

Mod 201

OpCnt 201

Pos 202

SumSwARs 203

XCBR3 35, 39, 43, 48, 51, 203

BlkCls 204

BlkOpn 204

CirSpv 204

Health 203

Loc 203

Mod 203

OpCnt 204

Pos 204

SumSwARs 205

XCBR4 205

BlkCls 206

BlkOpn 206

CirSpv 206

Health 205

Loc 205

Mod 205

OpCnt 206

Pos 206