



- A
- B
- C
- D
- E
- F
- G
- H
- J
- K
- L

- +24V
- RUN
- ERROR

- TR01-跳500kV断路器1&2
- TR02-关闭主汽门
- TR03-跳发电机出口断路器
- TR04-跳灭磁开关
- TR05-500kV断路器1&2启失灵
- TR06-跳10kV分支A断路器
- TR07-10kV分支A,B,C,D启快切
- TR08-跳10kV分支B断路器
- TR09-跳10kV分支C断路器
- TR10-跳10kV分支D断路器
- TR11-发电机出口断路器启失灵

