



- A
- B
- C
- D
- E
- F
- G
- H
- J
- K
- L

- TR01_Trip 500kV CB1&2
- TR02_Shut-down
- TR03_Trip Generator CB
- TR04_De-excitation
- TR05_Initiate Breaker Failure 500kV CB1&2
- TR06_Trip 10kV CB Branch A
- TR07_Initiate HSBT 10kV Branch A,B,C,D
- TR08_Trip 10kV CB Branch B
- TR09_Trip 10kV CB Branch C
- TR10_Trip 10kV CB Branch D
- TR11_Initiate Breaker Failure Generator CB

- +24V
- RUN
- ERROR

